

18-MONTH OUTLOOK:

An Assessment of the Reliability of the Ontario Electricity System

From April 2008 to September 2009



This page intentionally left blank.

Executive Summary

The reliability outlook for Ontario's electricity sector is positive for the next 18 months. More than 4,500 megawatts (MW) of new supply are scheduled to come into, or return to service, including approximately 3,100 megawatts (MW) of gas-fired generation, 800 MW of nuclear generation, 100 MW of hydroelectric generation and about 600 MW of wind capacity. Most of the new supply projects have started their construction phase. There are also substantial changes planned to the transmission network over the next 18 months.

Over the next year and a half, there should be sufficient supply within Ontario to meet electricity demands under normal weather conditions. This assumes that the planned resource additions meet their stated in service dates and the amount of conservation forecast by the Ontario Power Authority (OPA) is achieved. If these dates and forecasts are not met or if either extreme weather or sub-par performance of existing equipment should occur, Ontario may still need to rely on imports from neighbouring jurisdictions to maintain reliability.

To date, the Independent Electricity System Operator (IESO) has generally limited generators to scheduling their planned maintenance outages during the fall and spring "shoulder months" when demand tends to be lower. With more domestic resources becoming available, limited opportunities now exist for the IESO to accommodate planned generator outages in the winter months as well. These opportunities should provide generators with more flexibility to schedule their maintenance outages which should in turn provide greater assurances going forward that Ontario's generation fleet will be well prepared for the high demand summer months.

Electricity supply from baseload generation including nuclear, hydroelectric and wind sources is expected to increase in the latter half of the Outlook period and may at times exceed demand. Through planning and coordination with market participants, the IESO will be addressing the expected periods of surplus generation to mitigate any potential impacts to reliability. Surplus baseload supply situations have occurred infrequently to date, and have always been accompanied by very low energy prices. The low prices not only serve to discourage additional supply in those hours, but also to encourage any market based pricing consumers to shift whatever consumption they can out of higher priced hours into these very low priced periods.

The Ontario transmission system is expected to be adequate to reliably supply normal demands over the next 18-months. Hydro One is planning to add seven new high voltage shunt capacitors at selected locations in southwestern Ontario, starting in May 2009. These facilities will help accommodate the additional nuclear and wind generation scheduled to come into service in the area prior to the incorporation of the

new 500 kilovolt (kV) transmission line out of Bruce. Until all additional elements are in service, transmission limitations may constrain delivery of some available supply from the Bruce or Southwestern Ontario areas.

Reliability within the Greater Toronto Area (GTA) for both summer 2008 and summer 2009 is expected to be adequate as new facilities are incorporated, but remains dependent on the availability of the autotransformers feeding the GTA, the availability of the Pickering units, and the planned additions of the Portlands Energy Centre and Goreway Station.

The new interconnection between Ontario and Québec is scheduled for completion by March 31, 2009. This will increase Ontario's import-export capability by 1,250 MW, which represents an increase in import capability of about 30%.

The forecast for peak and energy demand is lower than in the previous Outlook due to two main factors; lower industrial demand and conservation initiatives. The energy-intensive sectors of the Ontario economy continue to be impacted by a high Canadian dollar and a sluggish U.S. economy. The broader economy as a whole shows signs of a slowdown, which has further reduced forecast demand. In addition, the shift to a "conservation culture" is reducing peak and energy demand. These aspects, in conjunction with weather, will shape demand over the Outlook period. Energy demand is expected to grow by 0.4% for 2008 (152.2 TWh).

The following table summarizes the peak demands for the upcoming seasons under the Seasonal Normal and Extreme weather scenarios. These peak demands should be mitigated to some extent by the impacts of targeted conservation programs.

| Season | Seasonal Normal Weather Peak (MW) | Extreme Weather Peak (MW) |
|----------------|-----------------------------------|---------------------------|
| Summer 2008 | 25,779 | 27,748 |
| Winter 2008-09 | 24,548 | 25,400 |
| Summer 2009 | 25,969 | 27,939 |

The IESO regularly assesses the adequacy and reliability of Ontario's power system. This 18-Month Outlook provides the IESO's assessment of the reliability of the power system from April 2008 to September 2009. It reflects the most up-to-date forecast information as well as experience gained from past operations.

The 18-Month Outlook is intended for operational planning purposes, and for scheduling generator outage plans. To avoid unacceptably low reserves, it is important to the overall operational planning process that participants adjust their maintenance activities to periods where available resources exceed requirements.

- End of Section

Caution and Disclaimer

The contents of these materials are for discussion and information purposes and are provided “as is” without representation or warranty of any kind, including without limitation, accuracy, completeness or fitness for any particular purpose. The Independent Electricity System Operator (IESO) assumes no responsibility to you or any third party for the consequences of any errors or omissions. The IESO may revise these materials at any time in its sole discretion without notice to you. Although every effort will be made by the IESO to update these materials to incorporate any such revisions it is up to you to ensure you are using the most recent version.

This page intentionally left blank.

Table of Contents

| | |
|---|-------------|
| Executive Summary | iii |
| Table of Contents | vii |
| List of Tables | viii |
| List of Figures | viii |
| 1.0 Introduction | 1 |
| 2.0 Updates to This Outlook | 3 |
| 2.1 Changes to Demand Forecast | 3 |
| 2.2 Updates to Resources | 3 |
| 2.3 Updates to Transmission Outlook | 3 |
| 3.0 Historical Review | 5 |
| 3.1 Weather and Demand Historical Review | 5 |
| 3.2 Operating Procedure Events | 5 |
| 3.3 Hourly Resource Contributions at Time of Weekday Peak | 5 |
| 4.0 Demand Forecast | 9 |
| 5.0 Resource Adequacy Assessment | 11 |
| 5.1 Planned Resource Scenario with Normal and Extreme Weather | 12 |
| 5.2 Firm Resource Scenario with Normal and Extreme Weather | 14 |
| 5.3 Comparison of Resource Scenarios | 16 |
| 5.4 Resource Adequacy Risks | 17 |
| 5.5 Surplus Supply Scenarios | 20 |
| 6.0 Transmission Reliability Assessment | 23 |
| 6.2 Load Supply Enhancements | 23 |
| 6.3 Planned Transmission Outages | 24 |
| 6.4 Transmission System Adequacy | 25 |
| 7.0 Conclusions | 33 |
| Appendix A Resource Adequacy Assessment Details | 37 |
| Appendix B Transmission Projects | 49 |
| Appendix C Planned Transmission Outages | 51 |

List of Tables

| | |
|---|----|
| Table 4.1 Conservation and Demand Management Scenarios | 10 |
| Table 5.1 Existing Installed Generation Resources..... | 11 |
| Table 5.2 Committed and Contracted Generation Resources | 13 |
| Table 5.3 Summary of Available Resources..... | 16 |
| Table A1 Assessment of Resource Adequacy: <u>Normal Weather</u> , Firm Resource Scenario | 37 |
| Table A2 Assessment of Resource Adequacy: <u>Normal Weather</u> , Planned Resource Scenario | 39 |
| Table A4 Demand Forecast Range for Planned Resource Scenario | 42 |
| Table A5 Assessment of Resource Adequacy: <u>Extreme Weather</u> , Firm Resource Scenario | 43 |
| Table A6 Assessment of Resource Adequacy: <u>Extreme Weather</u> , Planned Resource Scenario | 45 |
| Table A7 Energy Production Capability Forecast | 47 |
| Table B Transmission Projects | 49 |
| Table C1 Bruce Zone | 51 |
| Table C2 East Zone | 52 |
| Table C3 Essa Zone | 53 |
| Table C4 Niagara Zone | 53 |
| Table C5 Northeast Zone | 54 |
| Table C6 Northwest Zone | 54 |
| Table C7 Ottawa Zone | 56 |
| Table C8 Southwest Zone | 57 |
| Table C9 Toronto Zone | 58 |
| Table C10 West Zone | 59 |

List of Figures

| | |
|---|----|
| Figure 3.1 Wind Generation Contributions at the Time of Peak Demand..... | 6 |
| Figure 4.1 Demand Forecast Range | 10 |
| Figure 5.1 Reserve Above Requirement: Planned Resource Scenario with Normal vs. Extreme Weather..... | 14 |
| Figure 5.2 Reserve Above Requirement: Firm Resource Scenario with Normal vs. Extreme Weather..... | 15 |
| Figure 5.3 Reserve Above Requirement: Planned Resource Scenario with Present Outlook vs. Previous Outlook..... | 17 |
| Figure 6.1 Greater Toronto Area Electricity System..... | 26 |

1.0 Introduction

This Outlook covers the 18-month period from April 2008 to September 2009. It supersedes the report titled “An Assessment of the Reliability of the Ontario Electricity System from January 2008 to June 2009”, dated December 17, 2007.

The purpose of the 18-Month Outlook is:

- To advise market participants of the resource and transmission reliability of the Ontario electricity system;
- To assess potentially adverse conditions that might be avoided through adjustment or coordination of maintenance plans for generation and transmission equipment; and
- To report on initiatives that are being put in place to improve reliability within the 18-month timeframe of this Outlook.

The contents of this Outlook focus on the assessment of resource and transmission adequacy. Other supporting information and forecasts are contained separately in the following documents that are updated as required:

- “Ontario Demand Forecast from April 2008 to September 2009” (IESO_REP_0473) (found on the IESO web site at http://www.ieso.ca/imoweb/pubs/marketReports/18Month_ODF_2008mar.pdf)
 - Contains a detailed description of the peak and energy demand forecasts used in this Outlook.
- “Methodology to Perform Long Term Assessments” (IESO_REP_0266) (found on the IESO web site at http://www.ieso.ca/imoweb/pubs/marketReports/Methodology_RTAA_2007dec.pdf)
 - Contains information regarding the methodology used to perform the demand forecasts, resource adequacy assessments and transmission reliability assessments in this Outlook.
- “Ontario Transmission System” (IESO_REP_0265) (found on the IESO web site at http://www.ieso.ca/imoweb/pubs/marketReports/OntTxSystem_2008mar.pdf)
 - Provides specific details on the transmission system, including the major internal transmission interfaces and interconnections with neighbouring jurisdictions.

Readers are invited to provide comments on this Outlook report or to give suggestions as to the content of future reports. To do so, please contact us at:

- Toll Free: 1-888-448-7777
- Tel: 905-403-6900
- Fax: 905-403-6921
- E-mail: customer.relations@ieso.ca.

This Outlook presents an assessment of resource and transmission adequacy based on the stated assumptions, using the described methodology. Readers may envision other possible scenarios, recognizing the uncertainties associated with various input assumptions, and are encouraged to use their own judgment in considering possible future scenarios. The tables contained in the document can be downloaded from the Independent Electricity System Operator (IESO) web site in MS Excel format.

In addition to the comprehensive Outlook, the IESO periodically issues Interim Updates to the 18-Month Outlook between full Outlooks. These updates include a spreadsheet which reflects changes to Total Resources, Total Reductions in Resources, and Reserve Above Requirement values for the Planned Resource Scenario. The updates also include a summary of actual demand and forecast demand data. Similar to the full Outlooks, the Interim Updates are posted on the IESO web site. These updates provide Outlook information on a more frequent basis to allow market participants to better adjust their operational plans and outage schedules.

The reader should be aware that [Security and Adequacy Assessments](#) are published on the IESO web site on a weekly and daily basis that progressively supersede information presented in this report.

- End of Section -

2.0 Updates to This Outlook

2.1 Changes to Demand Forecast

The demand forecast has been updated to include the actual demand, weather and economic experience through to the end of January 2008. The economic outlook has been updated based on the most recent data.

Overall, the updated demand forecast has lower peak and energy demands compared to the previous Outlook due to economic impacts and conservation efforts.

2.2 Updates to Resources

Since the previous Outlook report was published, the net installed capacity connected to the IESO grid has increased by 83 MW. The increase is made up by the Ripley Wind Power Project (76 MW) and an upgrade (7 MW) to an existing nuclear unit

There have been updates to the generator outages submitted by market participants. For this Outlook, generation outage plans submitted to the IESO's Integrated Outage Management System (IOMS) as of February 20, 2008 were used.

2.3 Updates to Transmission Outlook

The list of transmission projects, planned transmission outages and actual experience with forced transmission outages have been updated from the previous 18-Month Outlook. For this Outlook, transmission outage plans submitted to the IOMS as of January 22, 2008 were used.

This Outlook also presents discussions on the major transmission enhancements that are forecast to be in service or are under construction within the outlook period, and the effects of generation and transmission project delays on the system's ability to supply the forecast peak demand.

- End of Section -

This page intentionally left blank.

3.0 Historical Review

This section provides a review of past power system operation, including the most recent months of operation, to identify noteworthy observations, emerging problems and variations from forecast.

3.1 Weather and Demand Historical Review

The winter weather of 2007-08 however has been much more typical than in recent years. December's peak came in just below 23,000 MW as temperatures in Toronto dropped below 3° C. January was milder than normal and the peak was only 22,782 MW, the lowest January peak since 2002. Although February data has not been incorporated into this report, the weather has been much colder than normal and peak demand did exceed 23,000 MW.

3.2 Operating Procedure Events

On June 12, 2007 a 5 percent voltage reduction was carried out due to overall adequacy after a transmission contingency rejected 744 MW of generation in the northeast during a period of higher than forecast demand. On June 26, 2007, the IESO asked consumers in the GTA to reduce their use of electricity during peak demand times over the next two days due to excessive autotransformer loadings in the GTA. On August 2, 2007 Ontario experienced hotter temperatures than average in which the IESO made a public appeal for consumers to reduce their electricity consumption.


3.3 Hourly Resource Contributions at Time of Weekday Peak

The figures 3.1 and 3.2 show the contributions made by wind and hydro generators at the time of weekday peak for the period from February 1, 2007 to January 31, 2008. The holiday data was removed from the display of actual hourly data, which tends to eliminate severe spikes in hourly contributions.

During the period of February 2007 and January 2008 the IESO does not see emerging trends or problems in the areas of wind or the net interchange in Ontario. Looking forward, the IESO will address any potential issues in operability studies and stakeholder engagement plans.

Figure 3.1 indicates the wind generation contributions to the wholesale market at the time of peak demand, excluding holidays, compared to the forecast contributions. Currently, IESO assumes an available wind generation contribution of 10 percent of installed capacity, held constant throughout the year. The forecast methodology does not account for seasonal variances in wind patterns, and thus, results in large deviations of actual monthly median contribution from forecast during winter months as compared to summer months.


Figure 3.1 Wind Generation Contributions at the Time of Peak Demand



The IESO is developing monthly assumptions for wind capacity contribution and will incorporate these once technical and stakeholder review has been completed.

Figure 3.2 indicates the actual hydro contributions to energy and operating reserve markets at the time of non holiday weekday peak from February 1, 2007 to January 31, 2008, compared to forecast contributions. The forecast is based on the actual monthly median contributions from May 1, 2002 to April 30, 2007. The forecast values for the past 15 months have been an average 5 percent greater than the actual hydro contributions. The IESO is continuing to monitor the situation and will consider adjustments as appropriate.

Figure 3.2 Hydro Contributions (Energy and Operating Reserve) at the Time of Weekday Peak



- End of Section -

This page intentionally left blank.

4.0 Demand Forecast

The forecast of demand has been updated to reflect the most recent economic, weather and demand information. The Ontario economy continues to be influenced by a number of key developments:

- A Canadian dollar at or near parity with the U.S. dollar and its impact on Ontario's export oriented manufacturing sector.
- A weaker U.S. economy and its impact on Ontario's economy. The close ties between the two and the relative size of the U.S. economy can have implications on our own economic cycle. In particular, the Ontario automotive sector is very dependant on sales south of the border.
- Low interest rates will continue to boost investment. Construction, business investment and domestic consumption have been a strength of the Ontario economy. With further rate cuts likely this will continue to help spur growth in the non-industrial sectors.

The demand models were updated and re-estimated to capture the most recent actual data and economic forecast.

For 2007 actual demand showed a modest increase over 2006 (0.8%). After correcting for weather it shows a small decline (-0.5%). Weather-corrected energy demand continues to lag last year's demand levels due to both conservation efforts and lower demand from energy-intensive industry. In 2007, demand from directly connected industry dropped 4.9% - which followed a 6.8% and 4.6% decline in the previous two years. Peak demands, though lower than the previous forecast, are expected to grow as the weather sensitive portion of demand is driven by the residential and commercial sectors. These sectors are being boosted by the lower interest rates. Overall, conservation savings being pursued by a number of market participants, including the OPA will mitigate this growth in both peak and energy demand.

Demand Forecast Assumptions

The adequacy assessments contained in this Outlook take into consideration a range of peak demands that can occur under various weather conditions with varying probability of occurrence. The IESO focuses on two demand forecast scenarios, which are based on:

- Monthly Normal weather; and
- Extreme weather.

The impact of varying weather is modeled probabilistically in the calculation of the required resources for each week of the study period.

In addition to the weather scenarios, the demand forecast has two scenarios that differ in their treatment of conservation. The Planned Resource scenario includes the impacts of additional conservation programs and initiatives by the OPA and electricity distributors. These impacts are decremented from the forecast. The Firm Resource scenario shows demand with only the existing level of conservation. Demand measures, such as dispatchable loads and responsive demand, are treated as a resource and are further covered in Section 5.1 and 5.2. Table 4.1 shows the various conservation and demand management components and their treatment under the two scenarios.


Table 4.1 Conservation and Demand Management Scenarios

| Conservation and Demand Management Components | Firm Scenario | Planned Scenario | Treatment |
|---|--------------------------|--------------------------|------------------|
| Conservation | Existing levels included | Targeted levels included | Decrement demand |
| OPA Demand Response 1 | Existing levels included | Targeted levels included | Resource |
| OPA Demand Response 2 | None | Targeted levels included | Resource |
| OPA Demand Response 3 | None | Targeted levels included | Resource |
| OPA Contracted Demand Response | Existing levels included | Existing levels included | Resource |
| IESO Dispatchable Demand | Existing levels included | Existing levels included | Resource |

Economic and demographic growth will be the factors driving energy and peak demand up during the forecast, and conservation will act to slow that growth. Under the Firm Resource Scenario energy demand will increase 0.4% in 2008 (152.2 TWh) and 0.1% in 2009 (152.3 TWh). The summer 2008 monthly normal peak is expected to be 25,493 MW. Under the Planned Resource scenario energy demand is expected to decrease by 0.1% in 2008 3(151.41 TWh) and 0.7% in 2009 (150.40 TWh) as conservation initiatives further reduce electricity demand. Under this scenario, the monthly normal peak demand for the summer of 2008 is expected to be 24,892 MW.

Figure 4.1 shows the Monthly Normal and Extreme (Firm Resource Scenario) weather demands assumed for each week in the study period.

Figure 4.1 Demand Forecast Range



For further discussion of how we identify peak demands and treat demand measures please refer to the Ontario Demand Forecast document, Section 3.0 *Forecasting Process and Assumptions*.

- End of Section -

5.0 Resource Adequacy Assessment

This section provides an assessment of the adequacy of resources to meet the forecast demand. From this assessment generator owners receive guidance for planning outages. When planned outages would adversely affect the reliability of the grid, as indicated by reserves below required levels, the IESO has the authority to deny approval of outages based on their order of precedence.

In recognition of the uncertainty that exists regarding the future availability of resources, two resource scenarios are described in this section: the Firm Resource Scenario (FRS) and the Planned Resource Scenario (PRS).

The IESO assumes in the FRS that a limited set of planned resource additions will occur on their forecast in-service dates, whereas the PRS is developed on the assumption that all planned resource changes will occur as scheduled.

The demand forecast for the PRS includes conservation measures that are not part of the FRS.

For both scenarios, all generating resources (excluding the units that are scheduled to retire), already in-service or, once in-service are assumed to remain in-service for the duration of the study period, except for periods of time that the generator owner/operator has submitted planned outages for their generating units.

As was reported in the previous report, the supply picture is expected to change significantly. More than 4,500 MW of new supply are scheduled to come into, or return to service, including approximately 3,100 MW of gas-fired generation, 800 MW of nuclear generation, 100 MW of hydroelectric generation and 700 MW of wind capacity. Most of the new supply projects have started their construction phase. In addition, the new interconnection with Quebec will increase transfer capabilities by 1,250 MW.

Table 5.1 Existing Installed Generation Resources

| Fuel Type | Total Capacity (MW) | Number of Stations |
|------------------------|---------------------|--------------------|
| Nuclear | 11,426 | 5 |
| Hydroelectric | 7,788 | 68 |
| Coal | 6,434 | 4 |
| Oil / Gas | 5,103 | 22 |
| Wind | 471 | 5 |
| Biomass / Landfill Gas | 75 | 5 |
| Total | 31,297 | 109 |

5.1 Planned Resource Scenario with Normal and Extreme Weather

Resource Assumptions

The PRS assumes quantities of demand measures and generation capacity based on existing resources plus significant resource changes that are scheduled to occur within the 18-month study period. These include:

- A. Existing Installed Resources: total capacity of 31,297 MW (refer to Table 5.1)
- B. New generation facilities and capacity changes to the existing facilities (refer to Table 5.2)
 - o Includes generation projects in the IESO's Connection Assessment and Approval Process (CAA) that are under construction and projects contracted by the OPA. Details regarding the IESO's CAA process and the status of all projects in the CAA queue, including copies of available Preliminary Assessment and System Impact Assessment Reports, can be found on the IESO's web site at <http://www.ieso.ca/imoweb/connassess/ca.asp>.
 - o The estimated effective date shown in Table 5.2 indicates the date on which additional capacity is assumed to be available to meet Ontario demand. For projects that are under contract, the estimated effective date is the best estimate of the date when the contract requires the additional capacity to be available. In the event that a project is delayed, such that the commercial in-service date is expected to be later than the contract date, the estimated effective date will be the best estimate of the commercial in-service date for the project.
- C. Demand Forecast:
 - o The demand forecast is reduced for the impacts of targeted conservation.
 - o Demand measures include dispatchable loads and loads contracted with the OPA which vary from 411 MW to 541 MW (refer to column "Demand Measures" in Table A2 or A7 in Appendix A).
 - o Based on historical data, it is assumed that 55% of dispatchable demand is available at the time of the weekly peak.
 - o Demand measures are forecast based on market participant information and actual market experience.

Table 5.2 Committed and Contracted Generation Resources

| Proponent/Project Name | Zone | Fuel Type | Estimated Effective Date | Project Status | Capacity Considered in Resource Scenario (MW) | |
|---|-----------|----------------|--------------------------|-----------------------|---|--------------|
| | | | | | FRS | PRS |
| Durham College District Energy Project | Toronto | Gas | 2008-Q1 | Construction | 2 | 2 |
| Great Northern Tri-Gen Facility | West | Gas | 2008-Q2 ⁽¹⁾ | Commissioning | 12 | 12 |
| Countryside London Cogeneration Facility | West | Gas | 2008-Q2 | Construction | 12 | 12 |
| Portlands Energy Centre Phase I | Toronto | Gas | 2008-Q2 | Construction | 250 | 250 |
| Warden Energy Centre | Toronto | Gas | 2008-Q2 | Construction | 5 | 5 |
| Umbata Falls Hydroelectric Project | Northwest | Water | 2008-Q2 | Construction | 23 | 23 |
| Lac Seul Project - English River | Northwest | Water | 2008-Q3 ⁽¹⁾ | Construction | | 13 |
| Greenfield Energy Centre | West | Gas | 2008-Q4 | Construction | | 1,005 |
| Kruger Energy Port Alma Wind Power Project | West | Wind | 2008-Q4 | Construction | | 101 |
| Wolfe Island Wind Project | East | Wind | 2008-Q4 | Approvals & Permits | | 198 |
| Nuclear Upgrade | N/A | Uranium | 2008-Q4 | Construction | 27 | 27 |
| Melancthon II Wind Project | Southwest | Wind | 2008-Q4 | Construction | | 132 |
| Enbridge Ontario Wind Power Project | Southwest | Wind | 2008-Q4 | Construction | | 200 |
| Retirement of Lower Sturgeon 25 Hz generation to convert to 60 Hz | Northeast | Water | 2009-Q1 | Connection Assessment | -5 | -5 |
| St. Clair Energy Centre | West | Gas | 2009-Q1 | Construction | | 570 |
| Return of Unit 7 at Beck 1 as a 60 Hz unit | Niagara | Water | 2009-Q1 | Construction | 59 | 59 |
| Retirement of Sandy Falls 25 Hz generation to convert to 60 Hz | Northeast | Water | 2009-Q2 | Connection Assessment | -3 | -3 |
| Goreway Station | Toronto | Gas | 2009-Q2 ⁽¹⁾ | Construction | | 860 |
| Retirement of the 25 Hz Frequency Changer and Units 1 & 2 at Beck 1 | Niagara | Water | 2009-Q2 | Connection Assessment | -50 | -50 |
| Algoma Energy Cogeneration Facility | Northeast | Industrial Gas | 2009-Q2 | Construction | | 63 |
| Portlands Energy Centre Phase II | Toronto | Gas | 2009-Q2 | Construction | | 288 |
| Bruce Unit 2 | Bruce | Uranium | 2009-Q2 | Construction | | 750 |
| East Windsor Cogeneration Centre | West | Gas | 2009-Q2 | Construction | | 84 |
| Total | | | | | 331 | 4,594 |

Notes to Table 5.2:

The total may not add up due to rounding.

(1). The estimated effective quarter and/or the year for the project has changed from the last Outlook.

Project status provides a general indication of the project progress. The standard milestones used are: Connection Assessment, Approvals & Permits, Construction, and Commissioning.

- o "Connection Assessment" indicates that the project is undergoing a system impact assessment with the IESO.
- o "Approvals & Permits" indicates that the project proponent is in the process of acquiring major approvals and permits required to start construction (e.g. environmental assessment, municipal approvals etc). "Construction" means that the project is under construction,
- o "Commissioning" indicates that the project is undergoing commissioning tests with the IESO.

Connection Assessment may run concurrently with the other three milestones which are sequential.


The generation capability assumptions are as follows:

- Hydroelectric capability, which includes energy and operating reserve is based on median historical values of hydroelectric hourly energy production and capacity contribution to operating reserve during weekday peak demand hours from May 2002 to April 2007.
- Capacity and energy contributions from thermal generators based on market participant submissions, including planned outages, expected forced outage rates and seasonal deratings.
- Wind-powered generation capacity at the time of weekday peak is assumed to be 10% and total energy contribution is assumed to be 30%,

Weekly Adequacy Assessments

Reserve Above Requirement levels, which represent the difference between Available Resources and Required Resources, are shown in Figure 5.1.

Figure 5.1 Reserve Above Requirement: Planned Resource Scenario with Normal vs. Extreme Weather



5.2 Firm Resource Scenario with Normal and Extreme Weather

Resource Assumptions

The FRS assumes quantities of demand measures and generation capacity based on the existing resources and a limited set of planned capacity increases or additions (refer to Table 5.2, column labeled “FRS” under heading “Considered in Resource Scenario”). This scenario includes:

- Existing Installed Resources: total capacity of 31,297 MW (refer to Table 5.1).
- Capacity changes to some existing facilities.
- Additional generating resources that have started their commissioning activities with contributions beginning on the date that the facility is expected to be in-service.
- Additional generating resources that are expected to become available in the first three months of the Outlook study period (regardless of commissioning status), with contributions beginning on the date that the facility is expected to be in-service.


- E. Existing demand measures assumed at 298 MW for the entire period of the Outlook (refer to column "Demand Measures" in Table A1 or A6 in Appendix A). Demand values (Table A4 in Appendix A) exclude targeted conservation.

With respect to forecasts of generation capabilities, the FRS is based on the same assumptions as the PRS.

Weekly Adequacy Assessments

Reserve Above Requirement levels, which represent the difference between Available Resources and Required Resources, are shown in Figure 5.2.

Figure 5.2 Reserve Above Requirement: Firm Resource Scenario with Normal vs. Extreme Weather



5.3 Comparison of Resource Scenarios

Table 5.3 shows a snapshot of the forecast available resources, under the two scenarios, at the time of the seasonal peak demands over the study period.

The monthly forecast of energy production capability, as provided by market participants, is included in Appendix A, Table A7.

Table 5.3 Summary of Available Resources

| Notes | Description | Summer Peak 2008 | | Winter Peak 2009 | | Summer Peak 2009 | |
|-------|------------------------------------|------------------------|---------------------------|------------------------|---------------------------|------------------------|---------------------------|
| | | Firm Resource Scenario | Planned Resource Scenario | Firm Resource Scenario | Planned Resource Scenario | Firm Resource Scenario | Planned Resource Scenario |
| 1 | Installed Resources (MW) | 31,601 | 31,601 | 31,628 | 33,276 | 31,632 | 35,891 |
| 2 | Imports (MW) | 0 | 0 | 0 | 0 | 0 | 0 |
| 3 | Total Resources (MW) | 31,601 | 31,601 | 31,628 | 33,276 | 31,632 | 35,891 |
| 4 | Total Reductions in Resources (MW) | 3,600 | 3,333 | 2,782 | 3,456 | 3,620 | 4,538 |
| 5 | Demand Measures (MW) | 298 | 541 | 298 | 541 | 298 | 541 |
| 6 | Available Resources (MW) | 28,299 | 28,809 | 29,144 | 30,361 | 28,310 | 31,895 |


Notes to Table 5.3:

1. Installed Resources (MW): This is the total capacity of the generation resources in Ontario assumed to be installed at the time of the summer and winter peaks in the 18 month time span. Initially, this value includes all generators registered to participate in the IESO-administered markets at the beginning of the 18 month study period. Additional generation capacity that was assumed under the applicable resource scenario is progressively included, according to the estimated in-service dates.
2. Imports (MW): Represents the amount of external capacity considered to be delivered to Ontario.
3. Total Resources (MW): This is the sum of Installed Resources (line 1) and Imports (line 2).
4. Total Reductions in Resources (MW): These reductions represent the sum of generator deratings, generator planned outages, generation limitations due to transmission interface constraints, generation constraints due to transmission outages/limitations and allowance for generation capability levels below rated installed capacity.
5. Demand Measures: This is the amount of demand assumed available to be reduced, under each resource scenario.
6. Available Resources (MW): This equals Total Resources (line 3) minus Total Reductions in Resources (line 4) plus Demand Measures (line 5).

Weekly Adequacy Assessments

Figure 5.3 provides a comparison between the forecast Reserve Above Requirement values in the present Outlook and the forecast Reserve Above Requirement values in the previous Outlook published on December 17, 2007.

Figure 5.3 Reserve Above Requirement: Planned Resource Scenario with Present Outlook vs. Previous Outlook



5.4 Resource Adequacy Risks

The forecast reserve levels for both the FRS and the PRS should be assessed bearing in mind the risks discussed below.

5.4.1 Extreme Weather

The FRS and the PRS are based on the assumption of normal (average) weather. However, peak demands in both summer and winter typically occur during periods of extreme weather. Unfortunately, the occurrence and timing of extreme weather is impossible to accurately forecast far in advance. As a result, the impact of extreme weather is modeled probabilistically in the calculation of the required resources for each week of the study period. The impact of extreme weather was demonstrated in the first week of August 2006, when Ontario established an all-time record demand of 27,005 MW. Over 3,000 MW of this demand was due to the higher than average heat and humidity.

In order to illustrate the impact of extreme weather on forecast reserve levels during the Outlook period, both the FRS and the PRS were re-calculated assuming extreme weather in each week instead of normal weather. The probability of this occurring in every week is very small; however the probability of an occurrence in any given week is greater (about 2.5 percent). When one looks at the entire summer or winter periods, the expectation of at least one period of extreme weather becomes very likely.

The magnitude of resource deficiencies, under extreme weather (as seen earlier in Figures 5.1 and 5.2), clearly illustrates there are circumstances under which reliance on a combination of interconnected supply, rejection of planned generator maintenance or emergency actions may be required. This emphasizes the continued need for a mix of resources that provides for a reliable supply, conservation programs and demand measures within Ontario.

5.4.2 New Facilities

For the 18 month period under study, the improving demand-supply situation, seen mainly in the PRS, is dependent on the additional generation, conservation programs and demand measures coming into service as forecast. Some of the risks the projects face are regulatory approvals, construction delays and untimely equipment deliveries by suppliers. Many timely regulatory approvals for a significant number of the new supply projects and transmission enhancements are required in a short period of time

Some transmission delays have already been experienced and others are growing in potential. The development of expedited, but thorough, approvals processes is needed to ensure timely completion of the new facilities.

Since the last report, most of the projects have started their construction phases. While there will undoubtedly be adjustments to schedules between now and when each facility is declared commercially in service, having these projects under construction represents a significant reduction in risk for the future

The OPA monitors and reports on the progress of the electricity supply contract projects on a quarterly basis at their web site found below:

<http://www.powerauthority.on.ca/Page.asp?PageID=122&ContentID=6465&SiteNodeID=120>

5.4.3 Generator Planned Outages

A number of large generating units are scheduled to return to service from outage prior to summers 2008 and 2009. Meeting these schedules is critical to maintaining adequate reserve levels. Delays in returning generators to service from maintenance outages could lead to reliance on imports and/or cancellation of other planned generator outages.

With the transition from winter peaking to summer peaking over the last number of years Ontario has experienced several years where the dual peaking nature of the Ontario system (roughly equivalent peaks in winter and summer) meant that outages must be scheduled in shorter spring and fall periods. Inevitably this meant that some long duration outages had to be scheduled into the start of the peak seasons, creating the potential that any extensions of these outages would occur when the generation is most needed.

To date, the Independent Electricity System Operator (IESO) has generally limited generators to scheduling their planned maintenance outages during the fall and spring “shoulder months” when demand tends to be lower. With more domestic resources becoming available, limited opportunities now exist for the IESO to accommodate planned generator outages in the winter months as well. These opportunities should provide generators with more flexibility to schedule their maintenance outages which should in turn provide greater assurances going forward that Ontario’s generation fleet will be well prepared for the high demand summer months.

In the event that generator outages must be delayed due to reliability concerns, it will be necessary for outages to be rescheduled to a more suitable time period. However outage rescheduling could stretch the ability of generator owners/operators to accommodate larger number and magnitude of outages over shorter time periods and may increase forced outage occurrences. Operational experience so far indicates generator owners are usually able to adapt their outage plans.

5.4.4 Lower than Forecast Generator Availability

IESO resource adequacy assessments include a probabilistic allowance for random generator forced outages based on generator reliability information provided by market participants, or on industry-wide data for similar facilities. Along with weather-related demand impacts, the impact of generator forced outages is included in the determination of required resources.

5.4.5 Lower than Forecast Hydroelectric Resources

IESO resource adequacy assessments include hydroelectric generation outputs based on median historical values of hydroelectric production plus operating reserve during weekday peak demand hours and energy capability provided by market participants. The amount of available hydroelectric generation is greatly influenced both by water-flow conditions on the respective river systems and by the way in which water is utilized.

Water-flow conditions are primarily influenced by the amount of precipitation received. To accurately forecast precipitation amounts far in advance is not possible. Drought conditions over some or all of the study period would lower the amount of generation available from hydroelectric resources. Low water conditions can result in significant challenges to maintaining reliability, as was experienced in the summer of 2005.

5.4.6 Wind Resource Risks

Wind generator output varies on a continuous basis due to the variability of wind. This Outlook assumes that 10% of the installed capacity of wind power generators is available at the time of the weekly peak. There is a risk that wind power output could be less than 10% at the time of the weekly peak if:

- the wind isn't blowing, or
- extreme cold weather or high wind speeds necessitate that wind generator output be curtailed to prevent equipment damage (these conditions are expected to be rare).

The geographic diversity of Ontario wind resources, as levels increase, should mitigate some of the risk associated with wind speed variability.

IESO is examining wind issues with stakeholders in the Wind Power Standing Committee (SE-29). The assumed capacity factor at the time of the peak is an issue this stakeholdering process is examining.

5.4.7 Capacity Limitations

There is a risk that any given generator may not be capable of producing the maximum capacity that the market participant has forecast to be available at the time of peak demand. There may be several reasons for these differences.

Forecast models include an equivalent forced outage rate that is intended to capture the random nature of generator capacity limitations, deratings, and forced outages. There is a risk that actual outages and deratings may be higher than forecast, and there is also a risk that certain types of deratings or outages may not be completely random. Some outages and deratings, such as environmental limitations and high ambient temperature deratings, may be more likely to occur at roughly the same time as the extreme weather conditions that drive peaks in demand.

For example, there are risks that gas-fired generators may not be capable of producing the maximum capacity that the market participant has forecast to be available at the time of peak. The natural gas and electricity sectors are converging as natural gas becomes one of the more common fuels in North America for electric power generation. The IESO is jointly working with the Ontario gas transportation industry to identify and address issues.

5.4.8 Transmission Constrained Resource Utilization

Transmission constraints may occur more often than expected due to multiple unplanned outages and may also have greater impact than expected on the ability to deliver generation to load centres. Transmission equipment failures could occur and significantly impact the utilization of resources until repairs are made. This is particularly true for large transformers whose repair or replacement time can be much longer than for transmission lines. Although a large number of transmission limitations are modeled in accordance with recognized reliability standards, there is a risk that certain transmission limitations resulting from multiple forced transmission outages, which exceed the levels modelled, may have an unforeseen impact.

Constraints may also occur due to weather conditions that result in high demand and contribute to higher than normal equipment limitations. For example periods of low wind combined with hot weather not only cause higher demands but also result in lower transmission capability. This can affect the utilization of internal generation and imports from neighbouring systems. Transmission constraints that result from loop flows can be particularly hard to predict because they result not only from the conditions within Ontario but from the dynamic patterns that are taking place within and between other areas.

During high demand periods, the availability of high-voltage capacitors and the capability of generators to deliver their full reactive capability also becomes critically important to permit the higher power transfers that are required. Outages or de-ratings to these reactive resources can restrict power transfer from generators and imports, and make it difficult to satisfy the peak demands.

5.4.9 Conservation and Demand Management

Since the targeted levels of conservation and demand management are significant, there is an associated risk should actual results fall short of those targets. The risk comes from both the level and the timing of conservation and demand management impacts. The PRS includes the impact of those targets and allows the IESO to study the benefits to system reliability from conservation and demand management programs. However, due to the ambitious nature of these targets it is prudent to study system reliability under the FRS which does not include those demand reductions.

5.5 Surplus Supply Scenarios

Previous reports have focused exclusively on peak demand periods. However, reliability risks can also occur when electricity demand is at its lowest such as during the overnight and weekend hours of temperate weather periods. Certain types of generation such as nuclear and some hydroelectric generators must maintain minimum output levels to ensure the generation is available in future high demand hours, or to respect environmental or other operational

constraints. At the same time, wind generators can also be contributing, as they operate whenever they have the right conditions.

Electricity supply from baseload generation including nuclear, hydroelectric and wind sources is expected to increase in the latter half of the Outlook period and may at times exceed demand. Through planning and coordination with market participants, the IESO will be addressing the expected periods of surplus generation to mitigate any potential impacts to reliability. Surplus baseload supply situations have occurred infrequently to date, and have always been accompanied by very low energy prices. The low prices not only serve to discourage additional supply in those hours, but also to encourage any market based pricing consumers to shift whatever consumption they can out of higher priced hours into these very low priced periods.

- End of Section -

This page intentionally left blank.

6.0 Transmission Reliability Assessment

This section provides an assessment of the reliability of the Ontario transmission system for the 18 month study period of this Outlook.

A main objective of the transmission reliability assessment is to introduce all major transmission and load supply projects that are planned for completion during the next 18 months and to present their reliability benefits.

A second objective of the transmission reliability assessment is to forecast any reduction in transmission capacity brought about by specific transmission outages. For a major transmission interface or interconnection, the reduction in transmission capacity due to an outage condition can be expressed as a change in the base flow limit associated with the interface or interconnection.

A third objective of the transmission reliability assessment is to identify the possibility of any security related events on the IESO controlled grid that could require contingency planning by market participants or by the IESO. As a result, planned transmission outages are reviewed in correlation with major planned resource outages and also the scheduled completion dates of new generation and transmission projects to identify transmission system reliability concerns and to highlight those outages that should be rescheduled or changed.

6.1 Transmission Projects

The IESO relies on the transmitters to provide information on the transmission projects that are planned for completion within the 18 month period. The complete list of major transmission projects is shown in Appendix B. The list also includes some projects with in-service dates just outside the period under study. Projects that are either in service or whose completion has been deferred well beyond the period of this outlook were removed from the list. The list includes only the transmission projects that represent major modifications or are considered to provide significant improvement to system reliability. Minor transmission equipment replacements or refurbishments are excluded. For projects assessed or being assessed under the Connection Assessment and Approval process, the assigned identification number is included for cross referencing.

Additional information regarding the transmission projects that have been assessed by the IESO can be found at the IESO's Connection Assessments web page, at the following location:
<http://www.ieso.ca/imoweb/connAssess/ca.asp>.

6.2 Load Supply Enhancements

The electricity demand growth experienced in Ontario in the last decade has resulted in a number of area loads reaching or exceeding the capability of the existing transformer stations. To address this problem and provide additional transformer capacity for future load growth, Ontario transmitters and distributors have initiated plans to build new transformer stations and replace existing transformers where appropriate. Five new and upgraded load supply transformer stations will be placed in service during the timeframe of this Outlook and shortly after.

Connection assessments performed by the IESO concluded that the new and upgraded transformer stations will provide relief to the existing stations, some of which are presently overloaded, and will improve the supply to various load areas. In some other cases the IESO found that the local transmission system may be reaching its maximum capability and identified the need for additional transmission reinforcements and installation of local voltage support equipment. In response to these findings the transmitter, Hydro One, initiated the installation of reactive compensation at a number of locations in the system.

Transmission assessments performed by transmitters in collaboration with local distribution companies also identified transmission reinforcements required to ensure adequate deliverability of supply to meet the Ontario electricity demand. The required reinforcements were also confirmed by the IESO during connection assessments performed for various new facilities. A number of such transmission reinforcements are currently under construction and planned for service during the study period of this Outlook. The new Essa to Stayner 230 kV transmission lined and voltage support devices installed at number of stations are examples of new transmission reinforcements that will be in service by the end of 2009 and result in an increase in load supply security.

The implementation of these projects will provide considerable improvements to the load supply reliability beyond the timeframe of this Outlook.

6.3 Planned Transmission Outages

The assessment of transmission outages for this Outlook has been limited to those outages with a scheduled duration of greater than five days or to those outages associated with a project where there is a significant collection of outages which have a combined scheduled duration of greater than five days. The IESO recognizes that additional outage requirements and changes are expected as time approaches the Outlook study period and that transmission capacity will be impacted by outages with a scheduled duration of five days or less. Prior to approving and releasing an outage, the IESO will reassess the outage for potential system impacts, taking into account all current and forecasted conditions.

The IESO's assessment of the impact of the transmission outage plans is shown in Appendix C, Tables C1 to C10. In these tables, each element is assessed individually by indicating the possible impacts and the reduction in transmission interface and interconnection limits. Where multiple outages are scheduled during the same period, the combined effect of all outages on the reduction in transmission interface and interconnection limits is presented. Where multiple outages are scheduled during the same period and reliability is affected the IESO requests the transmitter to reschedule some of the outages. The methodology used to assess the transmission outage plans is described in the IESO document titled "Methodology to Perform Long Term Assessments" (IESO_REP_0266).

The planned transmission outages are also reviewed in correlation with major planned resource outages and also the scheduled completion dates of new generation and transmission projects to identify transmission system reliability concerns and to highlight those outages that should be rescheduled or changed. As an example, a change to an outage may include rescheduling the outage, reducing the scheduled duration or reducing recall time.

The assessment of transmission outages will also identify any resources that have potential or are forecast to be constrained due to transmission outage conditions. Transmitters and generators are expected to have a mutual interest in developing an ongoing arrangement to coordinate their

outage planning activities. Transmission outages that may affect generation access to the IESO controlled grid should be coordinated with the generator operators involved, especially at times when the forecast of reserve is deficient. Under the Market Rules, where the scheduling of planned outages by different market participants conflicts such that both or all outages cannot be approved by the IESO, the IESO will inform the affected market participants and request that they resolve the conflict. If the conflict remains unresolved, the IESO will determine which of the planned outages can be approved according to the priority of each planned outage as determined by the Market Rules detailed in Chapter 5, Sections 6.4.13 to 6.4.18. For this Outlook, transmission outage plans submitted to the IESO's Integrated Outage Management System (IOMS) as of January 22, 2008 were used.

There is a substantial number of planned outages identified during the period of this Outlook that are required to accommodate system maintenance or future changes. Their specific impact on reliability is identified in subsequent sections of this report.

6.4 Transmission System Adequacy

The Ontario transmission system with the planned system enhancements is expected to be adequate to supply the demand under the normal weather conditions forecast for the 18-month period of this Outlook. However, an assessment of the scheduled generation outages in conjunction with the transmission outages and in conjunction with the projected capability of the transmission interfaces and the inter-ties shows that Ontario may be faced with a tight supply situation during the first two weeks of September 2008. If extreme weather conditions occur at this time, some of these outages may have to be rescheduled.

IESO Outlooks identify various areas of the IESO controlled grid where the projected extreme weather loading is expected to approach or exceed the capability of the transmission facilities for the conditions forecast in the planning period. This could result in congestion of low priced resources that must be replaced by higher priced resources, and would increase costs to market loads. Where the loading was projected to exceed the capability of the transmission facilities, there is also an increased risk of load interruptions.

IESO continues to work with Hydro One and other Ontario transmitters, to identify the highest priority transmission needs, and to ensure that those projects whose in service dates are at risk are given as much priority as is practical, especially those addressing reliability needs for summer 2008 and 2009. IESO has also been working closely with the OPA to specify the locations, timing and minimum generation requirements to satisfy reliability standards.

6.4.1 Toronto and Surrounding Area

The greater Toronto area electricity supply is mainly provided by the Trafalgar, Claireville, Parkway and Cherrywood autotransformers and Pickering GS units as depicted in Figure 6.1. The availability of these facilities is critical to ensure adequate electricity supply for Toronto and surrounding area.

Figure 6.1 Greater Toronto Area Electricity System



Following last year's outages and deratings associated with the 500/230 kV autotransformers, Hydro One implemented an extensive auto transformer remediation program. One spare autotransformer is currently available and two additional spares autotransformers will be available before to the end of 2008.

For the summer 2008 and summer 2009 extreme weather forecast conditions, the projected power flows over the Trafalgar, Claireville and Cherrywood autotransformers, with all elements in service, are expected to be within their continuous capability but the total station spare capability will be low. For summer 2008, the spare capability at Claireville, the highest loaded

autotransformer station in the area, may go as low as 4%. With one autotransformer out of service the continuous capability of some autotransformers may be exceeded but the loading will be within their long term emergency capability, which is only available for a limited time. Load reduction measures may be required following the unlikely forced outage of one additional autotransformer at Claireville or Cherrywood to reduce the remaining autotransformer loadings within applicable limits. For summer 2009, the presence of Goreway Station will reduce the loading of Claireville autotransformers to below their continuous ratings even when one transformer is out of service. Following the loss of an additional transformer at Claireville load reduction measures will likely not be required.

During summer 2008 and 2009, the reliable supply of GTA loads under extreme weather forecast conditions requires that all autotransformers at Trafalgar, Claireville, Parkway and Cherrywood and a minimum of four Pickering units be in service. Under these minimum conditions equipment loading should not exceed the long term emergency capability following the forced outage of one autotransformer at Trafalgar, Claireville or Parkway or one additional Pickering unit. Subsequent forced outages may require load curtailment to reduce the loading of remaining autotransformers within long term emergency limits.

Cherrywood autotransformer loading is strongly influenced by Pickering generation. If two Pickering units connected to the same 230 kV Cherrywood bus are unavailable, load reduction measures may be required to prevent equipment overloading following the loss of one Cherrywood autotransformer connected to the same bus. Availability of the Portlands Energy Centre generation may reduce, but is unlikely to fully eliminate, the necessary amount of load curtailment for Cherrywood area outages.

The Parkway autotransformers are adequate to supply the load forecast within the timeframe of this Outlook. Under certain conditions their spare capability may be useful to provide temporary relief of the Claireville or Cherrywood autotransformers.

Power advisories for the GTA may be issued following outages of more than two Pickering units and a single autotransformer in the GTA. Supplementary contingencies or 500 kV line outages may require load reduction measures ranging from voltage reduction to load curtailment, to control equipment loadings or system voltages in the GTA.

The supply to central Toronto will be improved during the period of this Outlook. The John TS to Esplanade TS link by Hydro One, which provides an additional 90 MW of load transfer capability from Leaside to the Manby West, was completed in December 2007 ahead of schedule. In addition, the completion of the Portland Energy Centre phase 1, currently scheduled to go in service before this summer, and phase 2, currently scheduled to go in service in spring 2009 will assist in eliminating possible overloads of the Manby TS and Leaside TS autotransformers.

The shunt capacitor at Richview TS which suffered significant damage at the beginning of 2007, as reported in the previous Outlook Report has returned to service at full capacity.

The IESO expects to be able to supply the extreme weather forecast GTA demand assuming that the availability of Pickering generation will be comparable to summer 2005 and 2006 and higher than summer 2007. Nevertheless, under certain demand or outage conditions, the portion of the grid supplying the GTA may still be stressed.

The GTA West transmission corridor between Trafalgar and Richview which supplies Brampton, Mississauga and parts of Caledon and Halton Hills may become loaded above capability during summer 2009 under extreme weather conditions. Transmission reinforcements which will relieve

the loading of this corridor and alleviate this problem are planned for in service before summer 2010.

In the York Region, the transformer station capacity in the Newmarket and Aurora area has been exceeded due to the rapidly growing loads. There is an immediate need for a new transformer station in the area. A new transformer station is planned to be in service before the end of 2009. Until then, the immediate needs will be addressed by load transfers, increasing the equipment operating ratings, by incentives for demand response programs in the area.

6.4.2 Bruce and Southwest Zones

Planned refurbishments at the Bruce nuclear station and proposed wind farm developments in southwestern Ontario will result in increased generation capacity from that region. To avoid the potential bottling of this generation a number of transmission enhancements are planned for the near term and the long term. Reinforcements that will increase the transfer capability out of Bruce in the near term include the up-rating of the Hanover to Orangeville 230 kV circuits and the installation of additional shunt capacitor facilities at Buchanan, Middleport and Nanticoke. These projects are of a high priority and are staged for completion between May to October 2009. Some bottling of Bruce area or west of London area generation may occur between the times when the seventh Bruce unit is returned to service until all shunt capacitors are placed in service. Additional facilities are likely required shortly after the 18 months study period to address this issue.

In addition to the near-term reinforcements described above, interim measures are being planned for the period before the new 500 kV line between Bruce to Milton is placed in service. The interim measures include additional voltage control facilities which together with the shunt capacitors and deployment of existing special protection systems will reduce potential generation bottling. In the longer-term, the new 500 kV double-circuit line from Bruce to Milton will provide the required transmission capability to deliver the full benefits of the Bruce refurbishment project and the development of new renewable resources in the area.

The new manufacturing development in the Woodstock area will result in increased stresses on the transmission system and low voltages in the area during extreme weather conditions. To alleviate these concerns Hydro One is planning to add a second supply point to the area by extending the 230 kV transmission lines from Ingersoll to Woodstock area, installing a new transformer station and installing additional low voltage shunt capacitors. This plan will provide an increased level of supply reliability, and support further load growth in the area.

Multiple long term outages associated with transmission equipment at Detweiler and Middleport are scheduled during the second and third quarter of 2008 and will result in a reduction in Flow Away from Bruce Complex (FABC) of up to 400 MW.

Limitations associated with the Burlington TS, previously identified by the IESO, are to be resolved partly before summer 2008 and completely by the end of 2010. This work which includes one transformer upgrade and the replacement of other limiting components will alleviate concerns related to the ability of the transmission system to supply the Burlington area loads.

6.4.3 Niagara Zone and the New York Interconnection

The situation with the Queenston Flow West project has not changed since the last Outlook. The completion date for transmission reinforcement between Niagara region into the Hamilton-Burlington area continues to be delayed. The limitations affect the use of both the available Ontario generation and imports into the province, particularly during hot weather, high demand periods.

Once in service, the reinforcement project will increase the capability of the transmission system connecting the Niagara River generation at Queenston to the grid in the Hamilton area by about 800 MW. This enhancement will permit increased imports from New York of at least 350 MW, and up to 800 MW depending on the load and generation dispatch in Ontario.

A forced outage associated with one of Ontario to New York interconnection circuits at Niagara which is expected to last for most of this year, results in a reduction in import and export capability of 500 MW and 600 MW respectively. Other planned outages to these interconnection circuits that are currently scheduled during April 2008, will reduce the import and export capability of the Ontario-New York interconnection at Niagara even further. The outages are required by the New York Power Authority (NYPA) to allow dam inspection at their Lewiston facilities. An examination of the planned Ontario resources for this period revealed several weekly periods when major Ontario generators are also scheduled for outage. The resource adequacy assessment results show that under the Planned Resource Scenario and normal weather conditions the Reserve above Requirement levels are positive. This indicates that Ontario may not need to rely on imports to supply the forecast demand for this period and the reduced import capability is not a concern. However, for the extreme weather scenario the Reserve above Requirement levels are negative and the system reliability could be affected due to the combined effect of interconnection and generation outages. The IESO will be monitoring the situation closely and will take any necessary mitigating action.

6.4.4 East Zone and Ottawa Zone

The 1,250 MW interconnection between Hawthorne TS in Ontario and Outaouais station in Québec is scheduled for completion by March 31, 2009. The construction of the 230 kV double circuit line from Hawthorne to the border is underway and planned for completion by November 2008. The new interconnection will be accompanied by a new Special Protection System (SPS) to be installed at Hawthorne TS and modifications of the existing St. Lawrence TS SPS. The new SPS will maximize simultaneous imports from Québec and New York while maintaining the functionality of the existing St. Lawrence SPS.

The new Reliability Must Run (RMR) contract with OPG for Lennox GS that covers the period October 2007 to September 2008 was approved by the OEB in December. Studies performed by the IESO indicate that there could be significant adverse local area reliability impacts if Lennox is removed from the IESO-controlled grid and the IESO-administered markets without adequate replacement.

Lennox GS is presently needed to maintain local area reliability in the Ottawa area and the area of Ontario that is located east of the Flow East Toward Toronto (FETT) interface. When the new interconnection with Québec is completed, the resulting transmission improvements in the Ottawa area may reduce reliance on Lennox for the local Ottawa area need. Similarly, supply improvements from new generation and conservation in and around Toronto through 2010 are

expected to reduce the need for Lennox to control flows on the FETT interface. However, Lennox GS is also critical to provincial resource adequacy, and must be retained or replaced. This resource adequacy requirement cannot be achieved through an RMR under the current Market Rules. The Integrated Power System Plan filed by the OPA with the OEB in August assumes that Lennox remains in service and is categorized as a planned gas resource starting in 2011. The IESO will continue to negotiate RMR contracts for Lennox GS within the existing market rule structure, as necessary, until the local area requirements are met.

6.4.5 West Zone and the Michigan Interconnection

Extensive work needs to be completed at the Lambton switchyard to prepare the power system to reliably incorporate additional generation facilities consisting of Greenfield Energy Centre and St. Clair Power. The modifications are required to connect the new generation facilities and to manage the expected increase in short circuit levels when new generation facilities at St. Clair Power and Greenfield Energy Centre begin their commissioning activities while generating units at Lambton continue to operate. To complete the work on time, a large volume of equipment outages must proceed as scheduled.

The multiple outages related to Lambton and Sarnia-Scott station reconfigurations and refurbishments, Longwood station equipment refurbishments and other line work scheduled throughout 2008 will result in reductions in the FABC limit, the Buchanan Longwood Input (BLIP) limit and the Negative Buchanan Longwood Input (NBLIP) limit as well as a reduction of the import and export capability of the Ontario - Michigan interconnection. Outages that coincide with the 2008 summer peak period could reduce the FABC limit by up to 400 MW, and the BLIP/NBLIP limit by up to 500 MW. Outages that coincide with the 2008-2009 winter period could also reduce the FABC limit by up to 150 MW, the BLIP/NBLIP limit by up to 500 MW. Most of these outages are not recallable.

An assessment of the scheduled generation outages in conjunction with the transmission outages and in conjunction with the projected capability of the transmission interfaces and the inter-ties shows that the transmission system will be adequate to supply the normal weather load forecast for the Outlook period but the supply situation appears to be tight during the first two weeks of September 2008 under extreme weather conditions.

Hydro One plans to enhance the transmission system in the Windsor area to address voltage and overload concerns and increase the transmission capability to supply the area load. The enhancements include a new 230 kV power supply point to Kingsville TS, upgrading 115 kV transmission circuits in the Windsor area the replacement of Keith TS autotransformers. As a secondary benefit, these upgrades will also alleviate the transmission limitations internal to Ontario which could, under specific generation dispatch scenarios, limit the Michigan import capability.

Phase angle regulators (PARs) are installed on the Michigan - Ontario interconnection at Lambton TS and Scott TS but are not available to regulate flows except in emergencies. The IESO, the Midwest ISO, Hydro One and International Transmission Company, agreed to temporarily bypass those phase angle regulators for normal operation until an agreement is reached to make full use of their regulating capability. The PAR controlling the tie flow on 230 kV circuit B3N, which is located in Michigan at the Bunce Creek terminal, is also unavailable and undergoing replacement.

Hydro One and the International Transmission Company signed a facility agreement on the Michigan-Ontario interconnection phase angle regulators. Operating agreements and instructions are currently being negotiated between the IESO and Hydro One, and the IESO and the Mid-west ISO. The available phase angle regulators are expected to become operational in the second quarter of 2008. The operation of the phase angle regulators will control circulating flows and assist in management of system congestion.

6.4.6 Northern Ontario

The transmission corridor east of Mississagi has been experiencing increased congestion due to the connection of the 200 MW Prince Park Wind Farm and the unbottling of Brookfield generation following the completion of the Great Lakes Power (GLP) 230 kV transmission reinforcement between Wawa TS and Third Line TS. It is expected that congestion will increase even further when the recently contracted Algoma Energy co-generation project is complete in mid 2009.

For the near-term, the IESO has recommended that the existing Mississagi TS and Algoma TS generation rejection schemes be enhanced as soon as possible to unbottle the generation west of Mississagi and eliminate the congestion over this transmission interface. Hydro One is planning to implement the required modifications before the end of 2008.

Extensive line work that's scheduled to begin early 2008 and last for most of the year is required to replace tower structures of the 230 kV circuits in the Kenora area. This series of outages can reduce the Ontario – Manitoba interface transfer capacity by up to 250 MW and result in a reduction of the North West - North East interface capability by up to 200 MW at times.

To resolve customer power quality supply issues Hydro One has decided to contract with OPG the return to service of the Thunder Bay C1. The condenser is scheduled to return to service by the summer of 2008.

6.4.7 Ontario 25 Hz System

The gradual retirement of the Niagara 25 Hz system is well underway. As mentioned in previous Outlooks, the IESO advised the 25 Hz customers in 2005 that the 25 Hz supply would be retired in April 2009, and in January 2007 National Grid, a transmission entity in the United States, informed the IESO that it had retired the US portion of the Niagara 25 Hz system. These activities pave the way for the retirement of the supporting transmission and generation facilities at the Sir Adam Beck 1 Generating Station. The IESO has approved the decertification request for the 25 Hz Niagara frequency changer and the remaining 25 Hz generation units at Beck No.1 effective April 30, 2009.

In Northeastern Ontario most of the 25 Hz generation facilities are scheduled to be retired in the first half of 2009 and Ontario Power Generation is planning to commence the replacement of these generating facilities with 60 Hz facilities shortly after. There is no longer any 25 Hz load in Northern Ontario.

- End of Section -

This page intentionally left blank.

7.0 Conclusions

The following conclusions are based on the results of the assessment carried out for this Outlook.

Resource Adequacy

- Under the Planned Resource-Normal Weather Scenario, forecast reserves within Ontario are sufficient to meet requirements for all weeks in the study period. Opportunities will exist for additional planned generator maintenance and exports in most of the weeks of the Outlook period. It is expected that generator owners will consider any future outages only when reserve levels are larger than the generator capacity being considered for outage.
- Under the Firm Resource-Normal Weather Scenario, the reserves are forecast to be below requirements for 19 of 78 weeks of the Outlook timeframe.
- Extreme weather during the peak periods will result in significantly increased reliance on imports to supplement Ontario generation and higher potential for the IESO to reject planned outages and use emergency operating procedures.
- Results of the resource adequacy assessment are summarized in the matrix below. The different shadings are intended to suggest the degree of concern regarding the supply/demand situation under each resource-weather scenario combination.

| | Normal Weather Scenario | Extreme Weather Scenario |
|---------------------------|--|--|
| Planned Resource Scenario | <ul style="list-style-type: none"> - there is no week when reserves are lower than required - opportunities for additional outages/exports exist in most of the weeks | <ul style="list-style-type: none"> - many planned outages at risk - imports required during some peak periods - higher risk of requiring emergency operating procedures |
| Firm Resource Scenario | <ul style="list-style-type: none"> - there are 19 weeks when reserves are lower than required (planned outages at risk or imports potentially required) - opportunities for additional outages/exports exist in many other weeks | <ul style="list-style-type: none"> - many planned outages at risk - imports required during some peak periods - higher risk of requiring emergency operating procedures |

- For the Normal Weather Planned Resource Scenario to exhibit positive supply margins in all weeks covered by this Outlook, all of the planned resource additions must meet their stated in service targets and the conservation targets set by the Ontario Power Authority (OPA) must be achieved.
- Even if that does occur, Ontario may need to rely on imports from neighbouring jurisdictions to maintain reliability if extreme weather occurs or if equipment performance is below normal.

- A number of large generating units are scheduled to return to service from outage prior to the summers of 2008 and 2009. Meeting these planned outage schedules is critical to maintaining adequate reserve levels over the peak season.
- Reserves are higher than required during the winter under the Normal Weather, Planned Resource Scenario allowing opportunities for additional generator outages in these periods. Air conditioning load growth, combined with minimal growth in heating load has led to the transition from winter peaking to summer peaking over the last ten years. This gap continues to grow. The development of new capabilities and resources to meet the higher summer peaks increases the capability to accommodate planned generator maintenance over the winter months.
- High generator unavailability, whether caused by higher forced outage rates or delays in returning generators to service, could lead to greater reliance on imports. Under these circumstances, opportunities for planned outages, especially during the peak summer period, would be limited.
- The IESO is examining options to mitigate the impacts from surplus supply scenarios, which could include improving the advance knowledge of such potential conditions to better facilitate coordination efforts and market responses.
- Lennox GS is presently needed to maintain local area reliability in the Ottawa area and the area of Ontario that is located east of the Flow East Toward Toronto (FETT) interface. When the new interconnection with Québec is completed, the resulting transmission improvements in the Ottawa area may reduce reliance on Lennox for the local Ottawa area need. Similarly, supply improvements from new generation and conservation in and around Toronto through 2010 are expected to reduce the need for Lennox to control flows on the FETT interface. However, Lennox GS is also critical to provincial resource adequacy, and must be retained or replaced. This resource adequacy requirement cannot be achieved through an RMR under the current Market Rules. The Integrated Power System Plan filed by the OPA with the OEB in August assumes that Lennox remains in service and is categorized as a planned gas resource starting in 2011. The IESO will continue to negotiate RMR contracts for Lennox GS within the existing market rule structure, as necessary, until the local area requirements are met.
- Over the 18 month period under study, the Northeast Power Coordinating Council resource adequacy criterion is expected to be met. As permitted to meet the criterion, the IESO forecast considers periodic reliance on interconnection benefits and potential use of other operating actions including outage rescheduling and emergency operating procedures.

Transmission Adequacy

- The Ontario transmission system is expected to be adequate to supply the 2008 and 2009 demand under normal weather load, but Ontario may be faced with a tight supply situation during the first two weeks of September 2008 if extreme weather conditions occur under the assumed generation and transmission outage schedule.
- The supply to central Toronto will be improved during the period of this Outlook with the scheduled completion of Portlands generation and the presence of the John to Esplanade link which was completed in December 2007.

- The IESO expects to be able to supply the extreme weather forecast GTA demand assuming all autotransformers at Trafalgar, Claireville, Parkway and Cherrywood and a minimum of four Pickering units are available. To minimize the risks to the GTA as the summer of 2008 approaches, the IESO will continue to monitor three key aspects:
 - availability and general condition of the 12 autotransformers feeding the GTA from Claireville, Trafalgar Parkway and Cherrywood TS,
 - availability of no less than four Pickering units during the summer months, and
 - progress of Portlands Phase 1, expected in service just prior to summer 2008
- Five new and upgraded load supply transformer stations will be placed in service during the timeframe of this Outlook and shortly after to help relieve loadings of existing transformer stations and provide additional transformer capacity for future load growth.
- Particular areas of concern include Brampton, Northern Mississauga and Northern York.
- A number of transmission reinforcements required to ensure adequate supply to meet the Ontario electricity demand in the near future are currently under construction and planned to be in service during the study period of this Outlook.
- The 1,250 MW interconnection between Hawthorne TS in Ontario and Outaouais station in Québec is scheduled for completion by March 31, 2009. The construction of the 230 kV double circuit line from Hawthorne to the border is planned for completion by November 2008.
- The multiple outages related to Lambton and Sarnia-Scott station reconfigurations and refurbishments, Longwood station equipment refurbishments and other lines work scheduled during 2008 will result in a reduction in FABC limit, BLIP limit and NBLIP limit as well as a reduction of the import and export capability of the Ontario - Michigan interconnection. Outside of the first two weeks of September 2008, concerns were not identified with respect to the adequacy of the transmission system to supply the load or to the reduced capability of the Michigan to Ontario interconnection for the period of these outages.
- Hydro One and the International Transmission Company signed a facility agreement on the Michigan-Ontario interconnection phase angle regulators. The phase angle regulators are expected to become operational in the second quarter of 2008.
- Hydro One will enhance the existing Mississagi TS and Algoma TS generation rejection schemes by the end of 2008 to unbottle the generation west of Mississagi and eliminate the congestion over the transmission corridor East of Mississagi.
- The retirement of the Niagara 25 Hz system and the deregistration of all the Northeast 25 Hz generation stations except one, will be completed during the period covered in this Outlook report.

- End of Section -

This page intentionally left blank.

Appendix A Resource Adequacy Assessment Details

Table A1 Assessment of Resource Adequacy: Normal Weather,
Firm Resource Scenario

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 06-Apr-08 | 31,299 | 7,858 | 298 | 23,740 | 23,319 | 15.2 | 3,136 | 13.2 | 2,715 | 421 |
| 13-Apr-08 | 31,299 | 7,321 | 298 | 24,277 | 22,534 | 23.1 | 4,558 | 14.3 | 2,815 | 1,743 |
| 20-Apr-08 | 31,299 | 7,107 | 298 | 24,491 | 22,546 | 24.3 | 4,783 | 14.4 | 2,838 | 1,945 |
| 27-Apr-08 | 31,299 | 7,300 | 298 | 24,298 | 21,786 | 26.6 | 5,108 | 13.5 | 2,596 | 2,512 |
| 04-May-08 | 31,311 | 6,835 | 298 | 24,774 | 22,139 | 28.8 | 5,533 | 15.1 | 2,898 | 2,635 |
| 11-May-08 | 31,311 | 7,743 | 298 | 23,866 | 22,326 | 21.0 | 4,149 | 13.2 | 2,609 | 1,540 |
| 18-May-08 | 31,311 | 6,663 | 298 | 24,946 | 22,787 | 24.5 | 4,907 | 13.7 | 2,748 | 2,159 |
| 25-May-08 | 31,311 | 6,586 | 298 | 25,023 | 23,422 | 22.6 | 4,620 | 14.8 | 3,019 | 1,601 |
| 01-Jun-08 | 31,311 | 5,926 | 298 | 25,683 | 24,060 | 24.0 | 4,972 | 16.2 | 3,349 | 1,623 |
| 08-Jun-08 | 31,578 | 6,718 | 298 | 25,158 | 24,861 | 16.7 | 3,605 | 15.4 | 3,308 | 297 |
| 15-Jun-08 | 31,578 | 5,752 | 298 | 26,124 | 27,188 | 10.9 | 2,573 | 15.4 | 3,637 | -1,064 |
| 22-Jun-08 | 31,578 | 4,464 | 298 | 27,412 | 28,518 | 11.6 | 2,857 | 16.1 | 3,963 | -1,106 |
| 29-Jun-08 | 31,578 | 4,445 | 298 | 27,431 | 28,100 | 14.1 | 3,389 | 16.9 | 4,058 | -669 |
| 06-Jul-08 | 31,601 | 3,650 | 298 | 28,249 | 27,340 | 17.9 | 4,281 | 14.1 | 3,372 | 909 |
| 13-Jul-08 | 31,601 | 3,661 | 298 | 28,238 | 28,614 | 13.2 | 3,293 | 14.7 | 3,669 | -376 |
| 20-Jul-08 | 31,601 | 3,600 | 298 | 28,299 | 29,528 | 11.0 | 2,806 | 15.8 | 4,035 | -1,229 |
| 27-Jul-08 | 31,601 | 3,646 | 298 | 28,253 | 28,138 | 14.6 | 3,596 | 14.1 | 3,481 | 115 |
| 03-Aug-08 | 31,601 | 3,812 | 298 | 28,087 | 27,050 | 18.5 | 4,392 | 14.2 | 3,355 | 1,037 |
| 10-Aug-08 | 31,601 | 3,881 | 298 | 28,018 | 28,357 | 13.4 | 3,304 | 14.7 | 3,643 | -339 |
| 17-Aug-08 | 31,601 | 3,817 | 298 | 28,082 | 27,939 | 15.0 | 3,664 | 14.4 | 3,521 | 143 |
| 24-Aug-08 | 31,601 | 3,891 | 298 | 28,008 | 26,828 | 19.4 | 4,540 | 14.3 | 3,360 | 1,180 |
| 31-Aug-08 | 31,601 | 5,036 | 298 | 26,863 | 27,179 | 12.1 | 2,909 | 13.5 | 3,225 | -316 |
| 07-Sep-08 | 31,601 | 6,423 | 298 | 25,476 | 26,188 | 13.1 | 2,942 | 16.2 | 3,654 | -712 |
| 14-Sep-08 | 31,601 | 6,485 | 298 | 25,414 | 25,331 | 17.3 | 3,746 | 16.9 | 3,663 | 83 |
| 21-Sep-08 | 31,601 | 7,397 | 298 | 24,502 | 24,188 | 18.0 | 3,734 | 16.5 | 3,420 | 314 |
| 28-Sep-08 | 31,601 | 7,757 | 298 | 24,142 | 22,673 | 19.5 | 3,939 | 12.2 | 2,470 | 1,469 |
| 05-Oct-08 | 31,601 | 7,422 | 298 | 24,477 | 22,015 | 26.3 | 5,090 | 13.6 | 2,628 | 2,462 |
| 12-Oct-08 | 31,601 | 7,169 | 298 | 24,730 | 22,216 | 26.0 | 5,102 | 13.2 | 2,588 | 2,514 |
| 19-Oct-08 | 31,601 | 7,619 | 298 | 24,280 | 22,571 | 21.2 | 4,241 | 12.6 | 2,532 | 1,709 |
| 26-Oct-08 | 31,601 | 7,636 | 298 | 24,263 | 23,136 | 18.4 | 3,764 | 12.9 | 2,637 | 1,127 |
| 02-Nov-08 | 31,601 | 8,408 | 298 | 23,491 | 24,069 | 10.8 | 2,290 | 13.5 | 2,868 | -578 |
| 09-Nov-08 | 31,628 | 7,315 | 298 | 24,611 | 24,131 | 14.8 | 3,174 | 12.6 | 2,694 | 480 |
| 16-Nov-08 | 31,628 | 7,705 | 298 | 24,221 | 24,708 | 10.1 | 2,223 | 12.3 | 2,710 | -487 |
| 23-Nov-08 | 31,628 | 5,973 | 298 | 25,953 | 25,261 | 15.8 | 3,539 | 12.7 | 2,847 | 692 |
| 30-Nov-08 | 31,628 | 5,948 | 298 | 25,978 | 25,256 | 15.8 | 3,546 | 12.6 | 2,824 | 722 |
| 07-Dec-08 | 31,628 | 5,322 | 298 | 26,604 | 26,292 | 14.0 | 3,256 | 12.6 | 2,944 | 312 |
| 14-Dec-08 | 31,628 | 3,833 | 298 | 28,093 | 26,470 | 19.4 | 4,571 | 12.5 | 2,948 | 1,623 |
| 21-Dec-08 | 31,628 | 3,288 | 298 | 28,638 | 26,402 | 22.8 | 5,309 | 13.2 | 3,073 | 2,236 |
| 28-Dec-08 | 31,628 | 2,857 | 298 | 29,069 | 25,903 | 27.6 | 6,279 | 13.7 | 3,113 | 3,166 |

Note: The reader should be aware that [Security and Adequacy Assessments](#) are published on the IESO web site on a weekly and daily basis that progressively supersedes information presented in this report.

(Table A1 continued)

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 04-Jan-09 | 31,628 | 2,861 | 298 | 29,065 | 24,821 | 33.3 | 7,261 | 13.8 | 3,017 | 4,244 |
| 11-Jan-09 | 31,628 | 2,771 | 298 | 29,155 | 26,976 | 21.8 | 5,214 | 12.7 | 3,035 | 2,179 |
| 18-Jan-09 | 31,628 | 2,782 | 298 | 29,144 | 27,397 | 19.8 | 4,809 | 12.6 | 3,062 | 1,747 |
| 25-Jan-09 | 31,628 | 2,771 | 298 | 29,155 | 27,155 | 20.9 | 5,041 | 12.6 | 3,041 | 2,000 |
| 01-Feb-09 | 31,628 | 2,771 | 298 | 29,155 | 26,803 | 22.6 | 5,372 | 12.7 | 3,020 | 2,352 |
| 08-Feb-09 | 31,623 | 2,813 | 298 | 29,108 | 26,894 | 21.9 | 5,223 | 12.6 | 3,009 | 2,214 |
| 15-Feb-09 | 31,623 | 2,961 | 298 | 28,960 | 26,558 | 23.0 | 5,421 | 12.8 | 3,019 | 2,402 |
| 22-Feb-09 | 31,623 | 2,961 | 298 | 28,960 | 26,354 | 23.9 | 5,584 | 12.7 | 2,978 | 2,606 |
| 01-Mar-09 | 31,623 | 3,466 | 298 | 28,455 | 25,978 | 24.4 | 5,573 | 13.5 | 3,096 | 2,477 |
| 08-Mar-09 | 31,623 | 4,576 | 298 | 27,345 | 25,662 | 22.0 | 4,932 | 14.5 | 3,249 | 1,683 |
| 15-Mar-09 | 31,623 | 6,369 | 298 | 25,552 | 24,621 | 16.6 | 3,640 | 12.4 | 2,709 | 931 |
| 22-Mar-09 | 31,623 | 6,647 | 298 | 25,274 | 24,333 | 17.3 | 3,726 | 12.9 | 2,785 | 941 |
| 29-Mar-09 | 31,623 | 6,690 | 298 | 25,231 | 23,610 | 20.7 | 4,332 | 13.0 | 2,711 | 1,621 |
| 05-Apr-09 | 31,682 | 6,990 | 298 | 24,990 | 23,584 | 20.6 | 4,268 | 13.8 | 2,862 | 1,406 |
| 12-Apr-09 | 31,682 | 6,884 | 298 | 25,096 | 22,698 | 26.7 | 5,289 | 14.6 | 2,891 | 2,398 |
| 19-Apr-09 | 31,682 | 7,006 | 298 | 24,974 | 22,665 | 26.0 | 5,154 | 14.4 | 2,845 | 2,309 |
| 26-Apr-09 | 31,682 | 9,457 | 298 | 22,523 | 22,181 | 16.7 | 3,228 | 15.0 | 2,886 | 342 |
| 03-May-09 | 31,682 | 9,455 | 298 | 22,525 | 22,322 | 16.4 | 3,179 | 15.4 | 2,976 | 203 |
| 10-May-09 | 31,632 | 9,633 | 298 | 22,297 | 22,611 | 11.9 | 2,376 | 13.5 | 2,690 | -314 |
| 17-May-09 | 31,632 | 9,704 | 298 | 22,226 | 23,016 | 9.9 | 1,999 | 13.8 | 2,789 | -790 |
| 24-May-09 | 31,632 | 8,651 | 298 | 23,279 | 23,765 | 13.1 | 2,689 | 15.4 | 3,175 | -486 |
| 31-May-09 | 31,632 | 7,020 | 298 | 24,910 | 24,155 | 19.2 | 4,005 | 15.6 | 3,250 | 755 |
| 07-Jun-09 | 31,632 | 6,743 | 298 | 25,187 | 24,610 | 17.6 | 3,770 | 14.9 | 3,193 | 577 |
| 14-Jun-09 | 31,632 | 5,738 | 298 | 26,192 | 27,345 | 10.3 | 2,448 | 15.2 | 3,601 | -1,153 |
| 21-Jun-09 | 31,632 | 4,899 | 298 | 27,031 | 28,624 | 9.4 | 2,319 | 15.8 | 3,912 | -1,593 |
| 28-Jun-09 | 31,632 | 4,468 | 298 | 27,462 | 28,216 | 13.4 | 3,235 | 16.5 | 3,989 | -754 |
| 05-Jul-09 | 31,632 | 4,533 | 298 | 27,397 | 26,645 | 17.5 | 4,085 | 14.3 | 3,333 | 752 |
| 12-Jul-09 | 31,632 | 4,508 | 298 | 27,422 | 28,877 | 8.9 | 2,250 | 14.7 | 3,705 | -1,455 |
| 19-Jul-09 | 31,632 | 3,620 | 298 | 28,310 | 29,657 | 10.2 | 2,626 | 15.5 | 3,973 | -1,347 |
| 26-Jul-09 | 31,632 | 3,629 | 298 | 28,301 | 28,257 | 13.9 | 3,461 | 13.8 | 3,417 | 44 |
| 02-Aug-09 | 31,632 | 3,623 | 298 | 28,307 | 27,116 | 18.6 | 4,447 | 13.7 | 3,256 | 1,191 |
| 09-Aug-09 | 31,632 | 3,831 | 298 | 28,099 | 28,452 | 12.9 | 3,212 | 14.3 | 3,565 | -353 |
| 16-Aug-09 | 31,632 | 3,843 | 298 | 28,087 | 28,037 | 14.3 | 3,503 | 14.1 | 3,453 | 50 |
| 23-Aug-09 | 31,632 | 3,842 | 298 | 28,088 | 26,893 | 18.9 | 4,455 | 13.8 | 3,260 | 1,195 |
| 30-Aug-09 | 31,632 | 3,841 | 298 | 28,089 | 27,305 | 16.5 | 3,970 | 13.2 | 3,186 | 784 |
| 06-Sep-09 | 31,632 | 4,552 | 298 | 27,378 | 26,554 | 20.5 | 4,654 | 16.9 | 3,830 | 824 |
| 13-Sep-09 | 31,632 | 5,707 | 298 | 26,223 | 25,466 | 20.0 | 4,363 | 16.5 | 3,606 | 757 |
| 20-Sep-09 | 31,632 | 6,715 | 298 | 25,215 | 24,330 | 20.3 | 4,258 | 16.1 | 3,373 | 885 |
| 27-Sep-09 | 31,632 | 7,272 | 298 | 24,658 | 22,845 | 21.0 | 4,276 | 12.1 | 2,463 | 1,813 |

**Table A2 Assessment of Resource Adequacy: Normal Weather,
Planned Resource Scenario**

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 06-Apr-08 | 31,299 | 7,872 | 411 | 23,839 | 22,705 | 18.9 | 3,791 | 13.3 | 2,657 | 1,134 |
| 13-Apr-08 | 31,299 | 7,334 | 411 | 24,377 | 21,972 | 27.2 | 5,208 | 14.6 | 2,803 | 2,405 |
| 20-Apr-08 | 31,299 | 7,121 | 411 | 24,590 | 21,975 | 28.4 | 5,443 | 14.8 | 2,828 | 2,615 |
| 27-Apr-08 | 31,299 | 7,261 | 411 | 24,450 | 21,242 | 31.1 | 5,795 | 13.9 | 2,587 | 3,208 |
| 04-May-08 | 31,311 | 6,821 | 411 | 24,901 | 21,619 | 32.9 | 6,169 | 15.4 | 2,887 | 3,282 |
| 11-May-08 | 31,311 | 7,729 | 411 | 23,993 | 21,863 | 24.6 | 4,739 | 13.6 | 2,609 | 2,130 |
| 18-May-08 | 31,311 | 6,696 | 411 | 25,026 | 22,328 | 27.8 | 5,446 | 14.0 | 2,748 | 2,698 |
| 25-May-08 | 31,311 | 6,588 | 411 | 25,134 | 22,958 | 26.0 | 5,184 | 15.1 | 3,008 | 2,176 |
| 01-Jun-08 | 31,311 | 5,926 | 411 | 25,796 | 23,535 | 27.6 | 5,585 | 16.5 | 3,324 | 2,261 |
| 08-Jun-08 | 31,578 | 6,437 | 541 | 25,682 | 24,321 | 22.1 | 4,652 | 15.7 | 3,291 | 1,361 |
| 15-Jun-08 | 31,578 | 5,471 | 541 | 26,648 | 26,530 | 15.8 | 3,642 | 15.3 | 3,524 | 118 |
| 22-Jun-08 | 31,578 | 4,196 | 541 | 27,923 | 27,711 | 16.9 | 4,031 | 16.0 | 3,819 | 212 |
| 29-Jun-08 | 31,578 | 4,179 | 541 | 27,940 | 27,431 | 18.9 | 4,447 | 16.8 | 3,938 | 509 |
| 06-Jul-08 | 31,601 | 3,383 | 541 | 28,759 | 26,790 | 22.9 | 5,367 | 14.5 | 3,398 | 1,969 |
| 13-Jul-08 | 31,601 | 3,395 | 541 | 28,747 | 27,832 | 18.3 | 4,455 | 14.6 | 3,540 | 915 |
| 20-Jul-08 | 31,601 | 3,333 | 541 | 28,809 | 28,799 | 15.7 | 3,917 | 15.7 | 3,907 | 10 |
| 27-Jul-08 | 31,601 | 3,379 | 541 | 28,763 | 27,454 | 19.7 | 4,724 | 14.2 | 3,415 | 1,309 |
| 03-Aug-08 | 31,601 | 3,545 | 541 | 28,597 | 26,488 | 23.8 | 5,490 | 14.6 | 3,381 | 2,109 |
| 10-Aug-08 | 31,601 | 3,614 | 541 | 28,528 | 27,702 | 18.0 | 4,353 | 14.6 | 3,527 | 826 |
| 17-Aug-08 | 31,601 | 3,549 | 541 | 28,593 | 27,305 | 19.9 | 4,746 | 14.5 | 3,458 | 1,288 |
| 24-Aug-08 | 31,601 | 3,624 | 541 | 28,518 | 26,294 | 24.5 | 5,610 | 14.8 | 3,386 | 2,224 |
| 31-Aug-08 | 31,601 | 4,769 | 541 | 27,373 | 26,486 | 17.1 | 3,991 | 13.3 | 3,104 | 887 |
| 07-Sep-08 | 31,613 | 6,169 | 541 | 25,986 | 25,606 | 18.0 | 3,958 | 16.2 | 3,578 | 380 |
| 14-Sep-08 | 31,613 | 6,231 | 541 | 25,924 | 24,805 | 22.6 | 4,785 | 17.3 | 3,666 | 1,119 |
| 21-Sep-08 | 31,613 | 7,143 | 541 | 25,012 | 23,617 | 23.9 | 4,818 | 17.0 | 3,423 | 1,395 |
| 28-Sep-08 | 31,613 | 7,503 | 541 | 24,652 | 22,211 | 25.1 | 4,951 | 12.7 | 2,510 | 2,441 |
| 05-Oct-08 | 32,618 | 7,464 | 541 | 25,696 | 21,700 | 36.0 | 6,795 | 14.8 | 2,799 | 3,996 |
| 12-Oct-08 | 32,618 | 7,165 | 541 | 25,995 | 21,932 | 35.6 | 6,825 | 14.4 | 2,762 | 4,063 |
| 19-Oct-08 | 32,618 | 7,615 | 541 | 25,545 | 22,274 | 30.5 | 5,976 | 13.8 | 2,705 | 3,271 |
| 26-Oct-08 | 32,618 | 7,633 | 541 | 25,527 | 22,833 | 27.5 | 5,498 | 14.0 | 2,804 | 2,694 |
| 02-Nov-08 | 32,917 | 8,704 | 541 | 24,755 | 23,486 | 19.7 | 4,069 | 13.5 | 2,800 | 1,269 |
| 09-Nov-08 | 32,944 | 7,582 | 541 | 25,904 | 23,630 | 24.2 | 5,044 | 13.3 | 2,770 | 2,274 |
| 16-Nov-08 | 32,944 | 7,972 | 541 | 25,514 | 24,039 | 19.0 | 4,075 | 12.1 | 2,600 | 1,475 |
| 23-Nov-08 | 32,944 | 6,216 | 541 | 27,270 | 24,814 | 24.7 | 5,402 | 13.5 | 2,946 | 2,456 |
| 30-Nov-08 | 32,944 | 6,214 | 541 | 27,272 | 24,767 | 24.8 | 5,427 | 13.4 | 2,922 | 2,505 |
| 07-Dec-08 | 32,944 | 5,590 | 541 | 27,896 | 25,681 | 22.7 | 5,164 | 13.0 | 2,949 | 2,215 |
| 14-Dec-08 | 32,944 | 4,097 | 541 | 29,389 | 26,002 | 28.4 | 6,503 | 13.6 | 3,116 | 3,387 |
| 21-Dec-08 | 32,944 | 3,531 | 541 | 29,955 | 25,939 | 32.0 | 7,255 | 14.3 | 3,239 | 4,016 |
| 28-Dec-08 | 32,944 | 3,320 | 541 | 30,166 | 25,481 | 35.9 | 7,966 | 14.8 | 3,281 | 4,685 |

Note: The reader should be aware that [Security and Adequacy Assessments](#) are published on the IESO web site on a weekly and daily basis that progressively supersedes information presented in this report.

(Table A2 continued)

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 04-Jan-09 | 32,944 | 3,452 | 541 | 30,034 | 24,392 | 41.6 | 8,826 | 15.0 | 3,184 | 5,642 |
| 11-Jan-09 | 33,276 | 3,435 | 541 | 30,382 | 26,272 | 31.7 | 7,308 | 13.9 | 3,198 | 4,110 |
| 18-Jan-09 | 33,276 | 3,456 | 541 | 30,361 | 26,665 | 29.5 | 6,920 | 13.8 | 3,224 | 3,696 |
| 25-Jan-09 | 33,276 | 3,375 | 541 | 30,442 | 26,411 | 31.2 | 7,235 | 13.8 | 3,204 | 4,031 |
| 01-Feb-09 | 33,276 | 3,450 | 541 | 30,367 | 26,057 | 32.8 | 7,493 | 13.9 | 3,183 | 4,310 |
| 08-Feb-09 | 33,271 | 3,449 | 541 | 30,363 | 26,183 | 32.0 | 7,354 | 13.8 | 3,174 | 4,180 |
| 15-Feb-09 | 33,271 | 3,721 | 541 | 30,091 | 25,848 | 32.8 | 7,426 | 14.0 | 3,183 | 4,243 |
| 22-Feb-09 | 33,271 | 3,637 | 541 | 30,175 | 25,658 | 34.0 | 7,662 | 14.0 | 3,145 | 4,517 |
| 01-Mar-09 | 33,271 | 4,005 | 541 | 29,807 | 25,256 | 35.5 | 7,813 | 14.8 | 3,262 | 4,551 |
| 08-Mar-09 | 33,841 | 5,419 | 541 | 28,963 | 25,016 | 34.5 | 7,422 | 16.1 | 3,475 | 3,947 |
| 15-Mar-09 | 33,841 | 7,347 | 541 | 27,035 | 23,989 | 28.4 | 5,980 | 13.9 | 2,934 | 3,046 |
| 22-Mar-09 | 33,841 | 7,636 | 541 | 26,746 | 23,731 | 29.2 | 6,044 | 14.6 | 3,029 | 3,015 |
| 29-Mar-09 | 33,841 | 7,659 | 541 | 26,723 | 23,030 | 33.2 | 6,667 | 14.8 | 2,974 | 3,693 |
| 05-Apr-09 | 34,756 | 7,914 | 541 | 27,384 | 23,035 | 37.7 | 7,499 | 15.8 | 3,150 | 4,349 |
| 12-Apr-09 | 34,756 | 7,865 | 541 | 27,433 | 22,198 | 44.2 | 8,412 | 16.7 | 3,177 | 5,235 |
| 19-Apr-09 | 34,756 | 8,059 | 541 | 27,239 | 22,183 | 43.0 | 8,193 | 16.5 | 3,137 | 5,056 |
| 26-Apr-09 | 34,756 | 10,520 | 541 | 24,778 | 21,662 | 33.9 | 6,274 | 17.1 | 3,158 | 3,116 |
| 03-May-09 | 34,756 | 10,582 | 541 | 24,716 | 21,800 | 33.1 | 6,149 | 17.4 | 3,233 | 2,916 |
| 10-May-09 | 34,706 | 10,738 | 541 | 24,510 | 22,059 | 27.3 | 5,260 | 14.6 | 2,809 | 2,451 |
| 17-May-09 | 34,706 | 10,870 | 541 | 24,378 | 22,394 | 24.8 | 4,837 | 14.6 | 2,853 | 1,984 |
| 24-May-09 | 34,706 | 10,271 | 541 | 24,977 | 23,240 | 25.3 | 5,047 | 16.6 | 3,310 | 1,737 |
| 31-May-09 | 34,706 | 8,126 | 541 | 27,122 | 23,754 | 34.0 | 6,879 | 17.3 | 3,511 | 3,368 |
| 07-Jun-09 | 35,891 | 7,497 | 541 | 28,936 | 24,280 | 39.8 | 8,237 | 17.3 | 3,581 | 4,656 |
| 14-Jun-09 | 35,891 | 6,281 | 541 | 30,152 | 26,722 | 31.2 | 7,162 | 16.2 | 3,732 | 3,430 |
| 21-Jun-09 | 35,891 | 5,537 | 541 | 30,896 | 27,951 | 29.1 | 6,962 | 16.8 | 4,017 | 2,945 |
| 28-Jun-09 | 35,891 | 5,706 | 541 | 30,727 | 27,528 | 31.9 | 7,428 | 18.2 | 4,229 | 3,199 |
| 05-Jul-09 | 35,891 | 5,638 | 541 | 30,795 | 26,196 | 37.1 | 8,336 | 16.6 | 3,737 | 4,599 |
| 12-Jul-09 | 35,891 | 5,534 | 541 | 30,899 | 28,156 | 26.9 | 6,545 | 15.6 | 3,802 | 2,743 |
| 19-Jul-09 | 35,891 | 4,538 | 541 | 31,895 | 28,848 | 28.9 | 7,141 | 16.5 | 4,094 | 3,047 |
| 26-Jul-09 | 35,891 | 4,607 | 541 | 31,826 | 27,688 | 32.7 | 7,841 | 15.4 | 3,703 | 4,138 |
| 02-Aug-09 | 35,891 | 4,767 | 541 | 31,666 | 26,660 | 37.7 | 8,675 | 16.0 | 3,669 | 5,006 |
| 09-Aug-09 | 35,891 | 4,814 | 541 | 31,619 | 27,847 | 31.5 | 7,571 | 15.8 | 3,799 | 3,772 |
| 16-Aug-09 | 35,891 | 4,824 | 541 | 31,609 | 27,556 | 32.8 | 7,798 | 15.7 | 3,745 | 4,053 |
| 23-Aug-09 | 35,891 | 4,874 | 541 | 31,559 | 26,493 | 38.3 | 8,739 | 16.1 | 3,673 | 5,066 |
| 30-Aug-09 | 35,891 | 4,854 | 541 | 31,579 | 26,900 | 35.4 | 8,256 | 15.3 | 3,577 | 4,679 |
| 06-Sep-09 | 35,891 | 5,739 | 541 | 30,694 | 26,108 | 40.1 | 8,782 | 19.2 | 4,196 | 4,586 |
| 13-Sep-09 | 35,891 | 6,427 | 541 | 30,006 | 25,108 | 42.0 | 8,878 | 18.8 | 3,980 | 4,898 |
| 20-Sep-09 | 35,891 | 7,456 | 541 | 28,977 | 23,944 | 43.5 | 8,780 | 18.6 | 3,747 | 5,033 |
| 27-Sep-09 | 35,891 | 8,056 | 541 | 28,377 | 22,520 | 44.7 | 8,771 | 14.9 | 2,914 | 5,857 |

Table A3 Demand Forecast Range for Firm Resource Scenario

| Week Ending Day | Ontario Demand Normal Weather MW | Ontario Demand Extreme Weather MW | Week Ending Day | Ontario Demand Normal Weather MW | Ontario Demand Extreme Weather MW |
|-----------------|----------------------------------|-----------------------------------|-----------------|----------------------------------|-----------------------------------|
| 06-Apr-08 | 20,604 | 22,276 | 04-Jan-09 | 21,804 | 23,110 |
| 13-Apr-08 | 19,719 | 20,903 | 11-Jan-09 | 23,941 | 24,938 |
| 20-Apr-08 | 19,708 | 22,161 | 18-Jan-09 | 24,335 | 25,400 |
| 27-Apr-08 | 19,190 | 22,153 | 25-Jan-09 | 24,114 | 25,290 |
| 04-May-08 | 19,241 | 21,850 | 01-Feb-09 | 23,783 | 24,931 |
| 11-May-08 | 19,717 | 22,438 | 08-Feb-09 | 23,885 | 25,011 |
| 18-May-08 | 20,039 | 21,883 | 15-Feb-09 | 23,539 | 24,584 |
| 25-May-08 | 20,403 | 22,769 | 22-Feb-09 | 23,376 | 24,296 |
| 01-Jun-08 | 20,711 | 23,898 | 01-Mar-09 | 22,882 | 24,134 |
| 08-Jun-08 | 21,553 | 24,438 | 08-Mar-09 | 22,413 | 23,941 |
| 15-Jun-08 | 23,551 | 25,890 | 15-Mar-09 | 21,912 | 23,262 |
| 22-Jun-08 | 24,555 | 27,015 | 22-Mar-09 | 21,548 | 22,792 |
| 29-Jun-08 | 24,042 | 26,648 | 29-Mar-09 | 20,899 | 22,173 |
| 06-Jul-08 | 23,968 | 25,685 | 05-Apr-09 | 20,722 | 22,429 |
| 13-Jul-08 | 24,945 | 26,763 | 12-Apr-09 | 19,807 | 20,991 |
| 20-Jul-08 | 25,493 | 27,748 | 19-Apr-09 | 19,820 | 22,342 |
| 27-Jul-08 | 24,657 | 26,630 | 26-Apr-09 | 19,295 | 22,356 |
| 03-Aug-08 | 23,695 | 25,388 | 03-May-09 | 19,346 | 22,047 |
| 10-Aug-08 | 24,714 | 27,661 | 10-May-09 | 19,921 | 22,634 |
| 17-Aug-08 | 24,418 | 26,833 | 17-May-09 | 20,227 | 22,064 |
| 24-Aug-08 | 23,468 | 26,091 | 24-May-09 | 20,590 | 22,957 |
| 31-Aug-08 | 23,954 | 26,184 | 31-May-09 | 20,905 | 24,079 |
| 07-Sep-08 | 22,534 | 26,012 | 07-Jun-09 | 21,417 | 24,555 |
| 14-Sep-08 | 21,668 | 25,777 | 14-Jun-09 | 23,744 | 26,083 |
| 21-Sep-08 | 20,768 | 24,867 | 21-Jun-09 | 24,712 | 27,171 |
| 28-Sep-08 | 20,203 | 23,299 | 28-Jun-09 | 24,227 | 26,833 |
| 05-Oct-08 | 19,387 | 22,678 | 05-Jul-09 | 23,312 | 25,388 |
| 12-Oct-08 | 19,628 | 20,293 | 12-Jul-09 | 25,172 | 26,989 |
| 19-Oct-08 | 20,039 | 20,962 | 19-Jul-09 | 25,684 | 27,939 |
| 26-Oct-08 | 20,499 | 21,258 | 26-Jul-09 | 24,840 | 26,813 |
| 02-Nov-08 | 21,201 | 21,890 | 02-Aug-09 | 23,860 | 25,553 |
| 09-Nov-08 | 21,437 | 22,237 | 09-Aug-09 | 24,887 | 27,834 |
| 16-Nov-08 | 21,998 | 22,932 | 16-Aug-09 | 24,584 | 26,999 |
| 23-Nov-08 | 22,414 | 23,429 | 23-Aug-09 | 23,633 | 26,256 |
| 30-Nov-08 | 22,432 | 23,917 | 30-Aug-09 | 24,119 | 26,350 |
| 07-Dec-08 | 23,348 | 24,602 | 06-Sep-09 | 22,724 | 26,262 |
| 14-Dec-08 | 23,522 | 24,632 | 13-Sep-09 | 21,860 | 25,907 |
| 21-Dec-08 | 23,329 | 24,637 | 20-Sep-09 | 20,957 | 25,058 |
| 28-Dec-08 | 22,790 | 24,056 | 27-Sep-09 | 20,382 | 23,478 |

Table A4 Demand Forecast Range for Planned Resource Scenario

| Week Ending Day | Ontario Demand Normal Weather MW | Ontario Demand Extreme Weather MW | Week Ending Day | Ontario Demand Normal Weather MW | Ontario Demand Extreme Weather MW |
|-----------------|----------------------------------|-----------------------------------|-----------------|----------------------------------|-----------------------------------|
| 06-Apr-08 | 20,048 | 21,720 | 04-Jan-09 | 21,208 | 22,514 |
| 13-Apr-08 | 19,169 | 20,352 | 11-Jan-09 | 23,074 | 24,071 |
| 20-Apr-08 | 19,147 | 21,600 | 18-Jan-09 | 23,441 | 24,507 |
| 27-Apr-08 | 18,655 | 21,618 | 25-Jan-09 | 23,207 | 24,383 |
| 04-May-08 | 18,732 | 21,341 | 01-Feb-09 | 22,874 | 24,021 |
| 11-May-08 | 19,254 | 21,975 | 08-Feb-09 | 23,009 | 24,135 |
| 18-May-08 | 19,580 | 21,423 | 15-Feb-09 | 22,665 | 23,710 |
| 25-May-08 | 19,950 | 22,317 | 22-Feb-09 | 22,513 | 23,432 |
| 01-Jun-08 | 20,211 | 23,398 | 01-Mar-09 | 21,994 | 23,246 |
| 08-Jun-08 | 21,030 | 23,914 | 08-Mar-09 | 21,541 | 23,069 |
| 15-Jun-08 | 23,006 | 25,345 | 15-Mar-09 | 21,055 | 22,405 |
| 22-Jun-08 | 23,892 | 26,352 | 22-Mar-09 | 20,702 | 21,947 |
| 29-Jun-08 | 23,493 | 26,099 | 29-Mar-09 | 20,056 | 21,330 |
| 06-Jul-08 | 23,392 | 25,110 | 05-Apr-09 | 19,885 | 21,592 |
| 13-Jul-08 | 24,292 | 26,110 | 12-Apr-09 | 19,021 | 20,206 |
| 20-Jul-08 | 24,892 | 27,147 | 19-Apr-09 | 19,046 | 21,568 |
| 27-Jul-08 | 24,039 | 26,013 | 26-Apr-09 | 18,504 | 21,564 |
| 03-Aug-08 | 23,107 | 24,800 | 03-May-09 | 18,567 | 21,268 |
| 10-Aug-08 | 24,175 | 27,122 | 10-May-09 | 19,250 | 21,963 |
| 17-Aug-08 | 23,847 | 26,262 | 17-May-09 | 19,541 | 21,379 |
| 24-Aug-08 | 22,908 | 25,531 | 24-May-09 | 19,930 | 22,297 |
| 31-Aug-08 | 23,382 | 25,612 | 31-May-09 | 20,243 | 23,417 |
| 07-Sep-08 | 22,028 | 25,507 | 07-Jun-09 | 20,699 | 23,837 |
| 14-Sep-08 | 21,139 | 25,248 | 14-Jun-09 | 22,990 | 25,329 |
| 21-Sep-08 | 20,194 | 24,294 | 21-Jun-09 | 23,934 | 26,394 |
| 28-Sep-08 | 19,701 | 22,797 | 28-Jun-09 | 23,299 | 25,905 |
| 05-Oct-08 | 18,901 | 22,192 | 05-Jul-09 | 22,459 | 24,535 |
| 12-Oct-08 | 19,170 | 19,835 | 12-Jul-09 | 24,354 | 26,171 |
| 19-Oct-08 | 19,569 | 20,492 | 19-Jul-09 | 24,754 | 27,009 |
| 26-Oct-08 | 20,029 | 20,787 | 26-Jul-09 | 23,985 | 25,958 |
| 02-Nov-08 | 20,686 | 21,375 | 02-Aug-09 | 22,991 | 24,684 |
| 09-Nov-08 | 20,860 | 21,660 | 09-Aug-09 | 24,048 | 26,995 |
| 16-Nov-08 | 21,439 | 22,373 | 16-Aug-09 | 23,811 | 26,226 |
| 23-Nov-08 | 21,868 | 22,883 | 23-Aug-09 | 22,820 | 25,444 |
| 30-Nov-08 | 21,845 | 23,330 | 30-Aug-09 | 23,323 | 25,554 |
| 07-Dec-08 | 22,732 | 23,987 | 06-Sep-09 | 21,912 | 25,450 |
| 14-Dec-08 | 22,886 | 23,995 | 13-Sep-09 | 21,128 | 25,175 |
| 21-Dec-08 | 22,700 | 24,008 | 20-Sep-09 | 20,197 | 24,298 |
| 28-Dec-08 | 22,200 | 23,466 | 27-Sep-09 | 19,606 | 22,703 |

**Table A5 Assessment of Resource Adequacy: Extreme Weather,
Firm Resource Scenario**

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 06-Apr-08 | 31,299 | 7,848 | 298 | 23,750 | 25,139 | 6.6 | 1,474 | 12.9 | 2,863 | -1,389 |
| 13-Apr-08 | 31,299 | 7,300 | 298 | 24,298 | 23,482 | 16.2 | 3,395 | 12.3 | 2,579 | 816 |
| 20-Apr-08 | 31,299 | 7,102 | 298 | 24,496 | 25,024 | 10.5 | 2,335 | 12.9 | 2,863 | -528 |
| 27-Apr-08 | 31,299 | 7,324 | 298 | 24,274 | 24,849 | 9.6 | 2,121 | 12.2 | 2,696 | -575 |
| 04-May-08 | 31,311 | 6,835 | 298 | 24,774 | 24,656 | 13.4 | 2,924 | 12.8 | 2,806 | 118 |
| 11-May-08 | 31,311 | 7,743 | 298 | 23,866 | 25,448 | 6.4 | 1,428 | 13.4 | 3,010 | -1,582 |
| 18-May-08 | 31,311 | 6,654 | 298 | 24,955 | 24,725 | 14.0 | 3,072 | 13.0 | 2,842 | 230 |
| 25-May-08 | 31,311 | 6,571 | 298 | 25,038 | 25,756 | 10.0 | 2,269 | 13.1 | 2,987 | -718 |
| 01-Jun-08 | 31,311 | 5,899 | 298 | 25,710 | 26,975 | 7.6 | 1,812 | 12.9 | 3,077 | -1,265 |
| 08-Jun-08 | 31,578 | 6,718 | 298 | 25,158 | 27,683 | 3.0 | 720 | 13.3 | 3,245 | -2,525 |
| 15-Jun-08 | 31,578 | 5,752 | 298 | 26,124 | 29,415 | 0.9 | 234 | 13.6 | 3,525 | -3,291 |
| 22-Jun-08 | 31,578 | 4,439 | 298 | 27,437 | 30,617 | 1.6 | 422 | 13.3 | 3,602 | -3,180 |
| 29-Jun-08 | 31,578 | 4,389 | 298 | 27,487 | 30,207 | 3.2 | 839 | 13.4 | 3,559 | -2,720 |
| 06-Jul-08 | 31,601 | 3,561 | 298 | 28,338 | 28,934 | 10.3 | 2,653 | 12.7 | 3,249 | -596 |
| 13-Jul-08 | 31,601 | 3,645 | 298 | 28,254 | 30,241 | 5.6 | 1,491 | 13.0 | 3,478 | -1,987 |
| 20-Jul-08 | 31,601 | 3,569 | 298 | 28,330 | 31,373 | 2.1 | 582 | 13.1 | 3,625 | -3,043 |
| 27-Jul-08 | 31,601 | 3,641 | 298 | 28,258 | 30,090 | 6.1 | 1,628 | 13.0 | 3,460 | -1,832 |
| 03-Aug-08 | 31,601 | 3,824 | 298 | 28,075 | 28,620 | 10.6 | 2,687 | 12.7 | 3,232 | -545 |
| 10-Aug-08 | 31,601 | 3,895 | 298 | 28,004 | 31,309 | 1.2 | 343 | 13.2 | 3,648 | -3,305 |
| 17-Aug-08 | 31,601 | 3,808 | 298 | 28,091 | 30,358 | 4.7 | 1,258 | 13.1 | 3,525 | -2,267 |
| 24-Aug-08 | 31,601 | 3,907 | 298 | 27,992 | 29,461 | 7.3 | 1,901 | 12.9 | 3,370 | -1,469 |
| 31-Aug-08 | 31,601 | 5,049 | 298 | 26,850 | 29,542 | 2.5 | 666 | 12.8 | 3,358 | -2,692 |
| 07-Sep-08 | 31,601 | 6,212 | 298 | 25,687 | 29,373 | -1.3 | -325 | 12.9 | 3,361 | -3,686 |
| 14-Sep-08 | 31,601 | 6,088 | 298 | 25,811 | 29,107 | 0.1 | 34 | 12.9 | 3,330 | -3,296 |
| 21-Sep-08 | 31,601 | 7,360 | 298 | 24,539 | 28,077 | -1.3 | -328 | 12.9 | 3,210 | -3,538 |
| 28-Sep-08 | 31,601 | 7,764 | 298 | 24,135 | 26,223 | 3.6 | 836 | 12.6 | 2,924 | -2,088 |
| 05-Oct-08 | 31,601 | 7,426 | 298 | 24,473 | 25,567 | 7.9 | 1,795 | 12.7 | 2,889 | -1,094 |
| 12-Oct-08 | 31,601 | 7,132 | 298 | 24,767 | 22,784 | 22.1 | 4,474 | 12.3 | 2,491 | 1,983 |
| 19-Oct-08 | 31,601 | 7,622 | 298 | 24,277 | 23,434 | 15.8 | 3,315 | 11.8 | 2,472 | 843 |
| 26-Oct-08 | 31,601 | 7,605 | 298 | 24,294 | 23,796 | 14.3 | 3,036 | 11.9 | 2,538 | 498 |
| 02-Nov-08 | 31,601 | 8,440 | 298 | 23,459 | 24,701 | 7.2 | 1,569 | 12.8 | 2,811 | -1,242 |
| 09-Nov-08 | 31,628 | 7,368 | 298 | 24,558 | 24,970 | 10.4 | 2,321 | 12.3 | 2,733 | -412 |
| 16-Nov-08 | 31,628 | 7,793 | 298 | 24,133 | 25,736 | 5.2 | 1,201 | 12.2 | 2,804 | -1,603 |
| 23-Nov-08 | 31,628 | 6,061 | 298 | 25,865 | 26,299 | 10.4 | 2,436 | 12.3 | 2,870 | -434 |
| 30-Nov-08 | 31,628 | 6,004 | 298 | 25,922 | 26,872 | 8.4 | 2,005 | 12.4 | 2,955 | -950 |
| 07-Dec-08 | 31,628 | 5,368 | 298 | 26,558 | 27,624 | 8.0 | 1,956 | 12.3 | 3,022 | -1,066 |
| 14-Dec-08 | 31,628 | 3,997 | 298 | 27,929 | 27,626 | 13.4 | 3,297 | 12.2 | 2,994 | 303 |
| 21-Dec-08 | 31,628 | 3,382 | 298 | 28,544 | 27,624 | 15.9 | 3,907 | 12.1 | 2,987 | 920 |
| 28-Dec-08 | 31,628 | 2,939 | 298 | 28,987 | 27,042 | 20.5 | 4,931 | 12.4 | 2,986 | 1,945 |

(Table A5 continued)

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 04-Jan-09 | 31,628 | 2,972 | 298 | 28,954 | 25,991 | 25.3 | 5,844 | 12.5 | 2,881 | 2,963 |
| 11-Jan-09 | 31,628 | 2,904 | 298 | 29,022 | 27,865 | 16.4 | 4,084 | 11.7 | 2,927 | 1,157 |
| 18-Jan-09 | 31,628 | 2,884 | 298 | 29,042 | 28,430 | 14.3 | 3,642 | 11.9 | 3,030 | 612 |
| 25-Jan-09 | 31,628 | 2,837 | 298 | 29,089 | 28,288 | 15.0 | 3,799 | 11.9 | 2,998 | 801 |
| 01-Feb-09 | 31,628 | 2,871 | 298 | 29,055 | 27,856 | 16.5 | 4,124 | 11.7 | 2,925 | 1,199 |
| 08-Feb-09 | 31,623 | 2,882 | 298 | 29,039 | 27,959 | 16.1 | 4,028 | 11.8 | 2,948 | 1,080 |
| 15-Feb-09 | 31,623 | 2,961 | 298 | 28,960 | 27,470 | 17.8 | 4,376 | 11.7 | 2,886 | 1,490 |
| 22-Feb-09 | 31,623 | 2,961 | 298 | 28,960 | 27,169 | 19.2 | 4,664 | 11.8 | 2,873 | 1,791 |
| 01-Mar-09 | 31,623 | 3,466 | 298 | 28,455 | 27,139 | 17.9 | 4,321 | 12.5 | 3,005 | 1,316 |
| 08-Mar-09 | 31,623 | 4,550 | 298 | 27,371 | 26,882 | 14.3 | 3,430 | 12.3 | 2,941 | 489 |
| 15-Mar-09 | 31,623 | 6,346 | 298 | 25,575 | 26,170 | 9.9 | 2,313 | 12.5 | 2,908 | -595 |
| 22-Mar-09 | 31,623 | 6,632 | 298 | 25,289 | 25,698 | 11.0 | 2,497 | 12.8 | 2,906 | -409 |
| 29-Mar-09 | 31,623 | 6,665 | 298 | 25,256 | 24,981 | 13.9 | 3,083 | 12.7 | 2,808 | 275 |
| 05-Apr-09 | 31,682 | 6,990 | 298 | 24,990 | 25,324 | 11.4 | 2,561 | 12.9 | 2,895 | -334 |
| 12-Apr-09 | 31,682 | 6,862 | 298 | 25,118 | 23,612 | 19.7 | 4,127 | 12.5 | 2,621 | 1,506 |
| 19-Apr-09 | 31,682 | 6,994 | 298 | 24,986 | 25,236 | 11.8 | 2,644 | 13.0 | 2,894 | -250 |
| 26-Apr-09 | 31,682 | 9,405 | 298 | 22,575 | 25,676 | 1.0 | 219 | 14.9 | 3,320 | -3,101 |
| 03-May-09 | 31,682 | 9,405 | 298 | 22,575 | 25,256 | 2.4 | 528 | 14.6 | 3,209 | -2,681 |
| 10-May-09 | 31,632 | 9,584 | 298 | 22,346 | 25,820 | -1.3 | -288 | 14.1 | 3,186 | -3,474 |
| 17-May-09 | 31,632 | 9,578 | 298 | 22,352 | 25,163 | 1.3 | 288 | 14.1 | 3,099 | -2,811 |
| 24-May-09 | 31,632 | 8,640 | 298 | 23,290 | 26,267 | 1.5 | 333 | 14.4 | 3,310 | -2,977 |
| 31-May-09 | 31,632 | 6,954 | 298 | 24,976 | 27,208 | 3.7 | 897 | 13.0 | 3,129 | -2,232 |
| 07-Jun-09 | 31,632 | 6,743 | 298 | 25,187 | 27,705 | 2.6 | 632 | 12.8 | 3,150 | -2,518 |
| 14-Jun-09 | 31,632 | 5,738 | 298 | 26,192 | 29,570 | 0.4 | 109 | 13.4 | 3,487 | -3,378 |
| 21-Jun-09 | 31,632 | 4,868 | 298 | 27,062 | 30,736 | -0.4 | -109 | 13.1 | 3,565 | -3,674 |
| 28-Jun-09 | 31,632 | 4,389 | 298 | 27,541 | 30,342 | 2.6 | 708 | 13.1 | 3,509 | -2,801 |
| 05-Jul-09 | 31,632 | 4,472 | 298 | 27,458 | 28,567 | 8.2 | 2,070 | 12.5 | 3,179 | -1,109 |
| 12-Jul-09 | 31,632 | 4,473 | 298 | 27,457 | 30,508 | 1.7 | 468 | 13.0 | 3,519 | -3,051 |
| 19-Jul-09 | 31,632 | 3,594 | 298 | 28,336 | 31,512 | 1.4 | 397 | 12.8 | 3,573 | -3,176 |
| 26-Jul-09 | 31,632 | 3,591 | 298 | 28,339 | 30,180 | 5.7 | 1,526 | 12.6 | 3,367 | -1,841 |
| 02-Aug-09 | 31,632 | 3,628 | 298 | 28,302 | 28,660 | 10.8 | 2,749 | 12.2 | 3,107 | -358 |
| 09-Aug-09 | 31,632 | 3,846 | 298 | 28,084 | 31,422 | 0.9 | 250 | 12.9 | 3,588 | -3,338 |
| 16-Aug-09 | 31,632 | 3,834 | 298 | 28,096 | 30,447 | 4.1 | 1,097 | 12.8 | 3,448 | -2,351 |
| 23-Aug-09 | 31,632 | 3,858 | 298 | 28,072 | 29,564 | 6.9 | 1,816 | 12.6 | 3,308 | -1,492 |
| 30-Aug-09 | 31,632 | 3,854 | 298 | 28,076 | 29,678 | 6.6 | 1,726 | 12.6 | 3,328 | -1,602 |
| 06-Sep-09 | 31,632 | 4,481 | 298 | 27,449 | 29,612 | 4.5 | 1,187 | 12.8 | 3,350 | -2,163 |
| 13-Sep-09 | 31,632 | 5,711 | 298 | 26,219 | 29,203 | 1.2 | 312 | 12.7 | 3,296 | -2,984 |
| 20-Sep-09 | 31,632 | 6,680 | 298 | 25,250 | 28,179 | 0.8 | 192 | 12.5 | 3,121 | -2,929 |
| 27-Sep-09 | 31,632 | 7,281 | 298 | 24,649 | 26,375 | 5.0 | 1,171 | 12.3 | 2,897 | -1,726 |

**Table A6 Assessment of Resource Adequacy: Extreme Weather,
Planned Resource Scenario**

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 06-Apr-08 | 31,299 | 7,862 | 411 | 23,849 | 24,461 | 9.8 | 2,129 | 12.6 | 2,741 | -612 |
| 13-Apr-08 | 31,299 | 7,313 | 411 | 24,398 | 22,911 | 19.9 | 4,046 | 12.6 | 2,559 | 1,487 |
| 20-Apr-08 | 31,299 | 7,116 | 411 | 24,595 | 24,340 | 13.9 | 2,995 | 12.7 | 2,740 | 255 |
| 27-Apr-08 | 31,299 | 7,286 | 411 | 24,425 | 24,217 | 13.0 | 2,807 | 12.0 | 2,599 | 208 |
| 04-May-08 | 31,311 | 6,821 | 411 | 24,901 | 24,010 | 16.7 | 3,560 | 12.5 | 2,669 | 891 |
| 11-May-08 | 31,311 | 7,729 | 411 | 23,993 | 24,908 | 9.2 | 2,018 | 13.4 | 2,933 | -915 |
| 18-May-08 | 31,311 | 6,640 | 411 | 25,082 | 24,149 | 17.1 | 3,659 | 12.7 | 2,726 | 933 |
| 25-May-08 | 31,311 | 6,573 | 411 | 25,149 | 25,213 | 12.7 | 2,832 | 13.0 | 2,896 | -64 |
| 01-Jun-08 | 31,311 | 5,899 | 411 | 25,823 | 26,392 | 10.4 | 2,425 | 12.8 | 2,994 | -569 |
| 08-Jun-08 | 31,578 | 6,437 | 541 | 25,682 | 27,053 | 7.4 | 1,768 | 13.1 | 3,139 | -1,371 |
| 15-Jun-08 | 31,578 | 5,471 | 541 | 26,648 | 28,749 | 5.1 | 1,303 | 13.4 | 3,404 | -2,101 |
| 22-Jun-08 | 31,578 | 4,166 | 541 | 27,953 | 29,858 | 6.1 | 1,601 | 13.3 | 3,506 | -1,905 |
| 29-Jun-08 | 31,578 | 4,108 | 541 | 28,011 | 29,565 | 7.3 | 1,912 | 13.3 | 3,466 | -1,554 |
| 06-Jul-08 | 31,601 | 3,294 | 541 | 28,848 | 28,238 | 14.9 | 3,738 | 12.5 | 3,128 | 610 |
| 13-Jul-08 | 31,601 | 3,379 | 541 | 28,763 | 29,443 | 10.2 | 2,653 | 12.8 | 3,333 | -680 |
| 20-Jul-08 | 31,601 | 3,302 | 541 | 28,840 | 30,682 | 6.2 | 1,693 | 13.0 | 3,535 | -1,842 |
| 27-Jul-08 | 31,601 | 3,374 | 541 | 28,768 | 29,333 | 10.6 | 2,755 | 12.8 | 3,320 | -565 |
| 03-Aug-08 | 31,601 | 3,558 | 541 | 28,584 | 27,910 | 15.3 | 3,784 | 12.5 | 3,110 | 674 |
| 10-Aug-08 | 31,601 | 3,628 | 541 | 28,514 | 30,690 | 5.1 | 1,392 | 13.2 | 3,568 | -2,176 |
| 17-Aug-08 | 31,601 | 3,541 | 541 | 28,601 | 29,662 | 8.9 | 2,339 | 13.0 | 3,400 | -1,061 |
| 24-Aug-08 | 31,601 | 3,640 | 541 | 28,502 | 28,788 | 11.6 | 2,971 | 12.8 | 3,257 | -286 |
| 31-Aug-08 | 31,601 | 4,782 | 541 | 27,360 | 28,850 | 6.8 | 1,748 | 12.6 | 3,238 | -1,490 |
| 07-Sep-08 | 31,613 | 5,958 | 541 | 26,197 | 28,757 | 2.7 | 690 | 12.7 | 3,250 | -2,560 |
| 14-Sep-08 | 31,613 | 5,833 | 541 | 26,322 | 28,476 | 4.3 | 1,074 | 12.8 | 3,228 | -2,154 |
| 21-Sep-08 | 31,613 | 7,106 | 541 | 25,049 | 27,404 | 3.1 | 755 | 12.8 | 3,110 | -2,355 |
| 28-Sep-08 | 31,613 | 7,510 | 541 | 24,645 | 25,601 | 8.1 | 1,848 | 12.3 | 2,804 | -956 |
| 05-Oct-08 | 32,618 | 7,423 | 541 | 25,737 | 24,970 | 16.0 | 3,545 | 12.5 | 2,778 | 767 |
| 12-Oct-08 | 32,618 | 7,129 | 541 | 26,031 | 22,505 | 31.2 | 6,196 | 13.5 | 2,670 | 3,526 |
| 19-Oct-08 | 32,618 | 7,619 | 541 | 25,541 | 23,093 | 24.6 | 5,049 | 12.7 | 2,601 | 2,448 |
| 26-Oct-08 | 32,618 | 7,602 | 541 | 25,558 | 23,388 | 23.0 | 4,771 | 12.5 | 2,601 | 2,170 |
| 02-Nov-08 | 32,917 | 8,736 | 541 | 24,723 | 24,074 | 15.7 | 3,348 | 12.6 | 2,699 | 649 |
| 09-Nov-08 | 32,944 | 7,636 | 541 | 25,850 | 24,322 | 19.3 | 4,190 | 12.3 | 2,662 | 1,528 |
| 16-Nov-08 | 32,944 | 8,060 | 541 | 25,426 | 25,054 | 13.7 | 3,053 | 12.0 | 2,681 | 372 |
| 23-Nov-08 | 32,944 | 6,304 | 541 | 27,182 | 25,645 | 18.8 | 4,299 | 12.1 | 2,762 | 1,537 |
| 30-Nov-08 | 32,944 | 6,271 | 541 | 27,215 | 26,148 | 16.7 | 3,885 | 12.1 | 2,818 | 1,067 |
| 07-Dec-08 | 32,944 | 5,635 | 541 | 27,851 | 26,868 | 16.1 | 3,864 | 12.0 | 2,881 | 983 |
| 14-Dec-08 | 32,944 | 4,264 | 541 | 29,222 | 26,982 | 21.8 | 5,227 | 12.5 | 2,987 | 2,240 |
| 21-Dec-08 | 32,944 | 3,650 | 541 | 29,836 | 27,091 | 24.3 | 5,828 | 12.8 | 3,083 | 2,745 |
| 28-Dec-08 | 32,944 | 3,268 | 541 | 30,218 | 26,614 | 28.8 | 6,752 | 13.4 | 3,148 | 3,604 |

(Table A6 continued)

| Week Ending Day | Total Resources MW | Total Reductions in Resources MW | Demand Measures MW | Available Resources MW | Required Resources MW | Available Reserve % | Available Reserve MW | Required Reserve % | Required Reserve MW | Reserve Above Requirement MW |
|-----------------|--------------------|----------------------------------|--------------------|------------------------|-----------------------|---------------------|----------------------|--------------------|---------------------|------------------------------|
| 04-Jan-09 | 32,944 | 3,374 | 541 | 30,112 | 25,569 | 33.8 | 7,598 | 13.6 | 3,055 | 4,543 |
| 11-Jan-09 | 33,276 | 3,548 | 541 | 30,269 | 27,126 | 25.8 | 6,198 | 12.7 | 3,055 | 3,143 |
| 18-Jan-09 | 33,276 | 3,458 | 541 | 30,359 | 27,562 | 23.9 | 5,852 | 12.5 | 3,055 | 2,797 |
| 25-Jan-09 | 33,276 | 3,410 | 541 | 30,407 | 27,438 | 24.7 | 6,024 | 12.5 | 3,055 | 2,969 |
| 01-Feb-09 | 33,276 | 3,444 | 541 | 30,373 | 27,075 | 26.4 | 6,352 | 12.7 | 3,054 | 3,298 |
| 08-Feb-09 | 33,271 | 3,492 | 541 | 30,320 | 27,189 | 25.6 | 6,185 | 12.7 | 3,054 | 3,131 |
| 15-Feb-09 | 33,271 | 3,638 | 541 | 30,174 | 26,756 | 27.3 | 6,464 | 12.9 | 3,046 | 3,418 |
| 22-Feb-09 | 33,271 | 3,579 | 541 | 30,233 | 26,478 | 29.0 | 6,801 | 13.0 | 3,046 | 3,755 |
| 01-Mar-09 | 33,271 | 4,005 | 541 | 29,807 | 26,399 | 28.2 | 6,561 | 13.6 | 3,153 | 3,408 |
| 08-Mar-09 | 33,841 | 5,227 | 541 | 29,155 | 26,107 | 26.4 | 6,086 | 13.2 | 3,038 | 3,048 |
| 15-Mar-09 | 33,841 | 7,150 | 541 | 27,232 | 25,241 | 21.5 | 4,827 | 12.7 | 2,836 | 1,991 |
| 22-Mar-09 | 33,841 | 7,459 | 541 | 26,923 | 24,852 | 22.7 | 4,976 | 13.2 | 2,905 | 2,071 |
| 29-Mar-09 | 33,841 | 7,535 | 541 | 26,847 | 24,252 | 25.9 | 5,517 | 13.7 | 2,922 | 2,595 |
| 05-Apr-09 | 34,756 | 7,807 | 541 | 27,491 | 24,535 | 27.3 | 5,899 | 13.6 | 2,943 | 2,956 |
| 12-Apr-09 | 34,756 | 7,794 | 541 | 27,504 | 23,158 | 36.1 | 7,298 | 14.6 | 2,952 | 4,346 |
| 19-Apr-09 | 34,756 | 8,060 | 541 | 27,238 | 24,539 | 26.3 | 5,670 | 13.8 | 2,971 | 2,699 |
| 26-Apr-09 | 34,756 | 10,457 | 541 | 24,841 | 24,598 | 15.2 | 3,277 | 14.1 | 3,034 | 243 |
| 03-May-09 | 34,756 | 10,464 | 541 | 24,834 | 24,250 | 16.8 | 3,566 | 14.0 | 2,982 | 584 |
| 10-May-09 | 34,706 | 10,573 | 541 | 24,675 | 24,935 | 12.4 | 2,712 | 13.5 | 2,972 | -260 |
| 17-May-09 | 34,706 | 10,581 | 541 | 24,667 | 24,213 | 15.4 | 3,288 | 13.3 | 2,834 | 454 |
| 24-May-09 | 34,706 | 10,135 | 541 | 25,113 | 25,347 | 12.6 | 2,816 | 13.7 | 3,050 | -234 |
| 31-May-09 | 34,706 | 7,860 | 541 | 27,388 | 26,313 | 17.0 | 3,971 | 12.4 | 2,896 | 1,075 |
| 07-Jun-09 | 35,891 | 7,260 | 541 | 29,173 | 26,826 | 22.4 | 5,336 | 12.5 | 2,989 | 2,347 |
| 14-Jun-09 | 35,891 | 6,105 | 541 | 30,328 | 28,493 | 19.7 | 4,999 | 12.5 | 3,164 | 1,835 |
| 21-Jun-09 | 35,891 | 5,299 | 541 | 31,134 | 29,617 | 18.0 | 4,740 | 12.2 | 3,223 | 1,517 |
| 28-Jun-09 | 35,891 | 5,370 | 541 | 31,063 | 29,188 | 19.9 | 5,158 | 12.7 | 3,283 | 1,875 |
| 05-Jul-09 | 35,891 | 5,487 | 541 | 30,946 | 27,805 | 26.1 | 6,411 | 13.3 | 3,270 | 3,141 |
| 12-Jul-09 | 35,891 | 5,409 | 541 | 31,024 | 29,439 | 18.5 | 4,853 | 12.5 | 3,268 | 1,585 |
| 19-Jul-09 | 35,891 | 4,429 | 541 | 32,004 | 30,305 | 18.5 | 4,995 | 12.2 | 3,296 | 1,699 |
| 26-Jul-09 | 35,891 | 4,502 | 541 | 31,931 | 29,254 | 23.0 | 5,973 | 12.7 | 3,296 | 2,677 |
| 02-Aug-09 | 35,891 | 4,574 | 541 | 31,859 | 27,980 | 29.1 | 7,175 | 13.4 | 3,296 | 3,879 |
| 09-Aug-09 | 35,891 | 4,631 | 541 | 31,802 | 30,288 | 17.8 | 4,807 | 12.2 | 3,293 | 1,514 |
| 16-Aug-09 | 35,891 | 4,634 | 541 | 31,799 | 29,519 | 21.3 | 5,573 | 12.6 | 3,293 | 2,280 |
| 23-Aug-09 | 35,891 | 4,741 | 541 | 31,692 | 28,737 | 24.6 | 6,248 | 12.9 | 3,293 | 2,955 |
| 30-Aug-09 | 35,891 | 4,727 | 541 | 31,706 | 28,847 | 24.1 | 6,152 | 12.9 | 3,293 | 2,859 |
| 06-Sep-09 | 35,891 | 5,512 | 541 | 30,921 | 28,685 | 21.5 | 5,471 | 12.7 | 3,235 | 2,236 |
| 13-Sep-09 | 35,891 | 6,238 | 541 | 30,195 | 28,234 | 19.9 | 5,020 | 12.2 | 3,059 | 1,961 |
| 20-Sep-09 | 35,891 | 7,293 | 541 | 29,140 | 27,169 | 19.9 | 4,842 | 11.8 | 2,871 | 1,971 |
| 27-Sep-09 | 35,891 | 7,945 | 541 | 28,488 | 25,529 | 25.5 | 5,785 | 12.5 | 2,826 | 2,959 |

Table A7 Energy Production Capability Forecast

| Month | Firm Resource Scenario Forecast Energy Production Capability (GWh) | Planned Resource Scenario Forecast Energy Production Capability (GWh) |
|----------|--|---|
| Apr 2008 | 13,830 | 13,830 |
| May 2008 | 16,507 | 16,507 |
| Jun 2008 | 16,861 | 16,861 |
| Jul 2008 | 17,896 | 17,896 |
| Aug 2008 | 17,511 | 17,511 |
| Sep 2008 | 15,534 | 15,542 |
| Oct 2008 | 13,948 | 14,596 |
| Nov 2008 | 15,854 | 16,545 |
| Dec 2008 | 17,948 | 18,663 |
| Jan 2009 | 18,430 | 19,218 |
| Feb 2009 | 16,544 | 17,256 |
| Mar 2009 | 16,729 | 17,880 |
| Apr 2009 | 14,127 | 15,770 |
| May 2009 | 16,894 | 18,593 |
| Jun 2009 | 17,327 | 19,700 |
| Jul 2009 | 17,653 | 20,104 |
| Aug 2009 | 17,416 | 19,867 |
| Sep 2009 | 16,635 | 19,008 |

- End of Section -

This page intentionally left blank.

Appendix B Transmission Projects

Table B Transmission Projects

| Zone | CAA-ID# | Transmitter | Description | Proposed I/S Date |
|-----------|------------|--------------------------|---|-------------------|
| East | 2007-Ex333 | Hydro One Networks Inc. | Whitby DESN 1: New shunt capacitor | 2008-Q3 |
| | N/A | Hydro One Networks Inc. | Kingston-Gardiner TS#2 new transformer station | 2008-Q4 |
| | 2000-001 | Hydro One Networks Inc. | Hawthorne TS: Switchyard expansion to facilitate connection of the HQ 230 kV ties lines. | 2008-Q4 |
| | 2000-001 | Hydro One Networks Inc. | Hawthorne to Quebec border 230 kV double circuit interconnection line | 2009-Q1 |
| | 2006-245 | Hydro Ottawa | Cyrville TS new transformer station | 2008-Q3 |
| Essa | 2006-233 | Hydro One Networks Inc. | Orangeville TS Shunt Capacitor | 2008-Q2 |
| | 2006-211 | Hydro One Networks Inc. | Holland Marsh TS new transformer station | 2009-Q3 |
| | 2005-190 | Hydro One Networks Inc. | Stayner TS modifications and new 230 kV line | 2009-Q2 |
| Niagara | 2002-085 | Hydro One Networks Inc. | Queenston Flow West | To be determined |
| | 2007-257 | Hydro One Networks Inc. | Improve thermal rating of 115 kV circuits D9HS, D10S and Q11S | 2009-Q2 2010-Q2 |
| | | Hydro One Networks Inc. | Venessa jct to Norfolk TS new 115 kV | 2009-Q2 |
| | | Hydro One Networks Inc. | Retirement of Q5G (25 Hz CCT) | 2008 - Q4 |
| | | Hydro One Networks Inc. | Reconnect of Beck G7 to 60 Hz | 2008 - Q4 |
| | | Hydro One Networks Inc. | Thermal upgrade of Q4N | 2009 - Q2 |
| | | Hydro One Networks Inc. | Retirement of Niagara 25 Hz system | 2009 - Q2 |
| Northeast | N/A | Great Lakes Power Ltd. | Maggie TS 115 kV structure replacement | 2008-Q4 |
| | N/A | Great Lakes Power Ltd. | Mackay TS 115 kV yard refurbishment - on going | 2008-Q4 |
| | N/A | Great Lakes Power Ltd. | Third Line TS 115 kV yard refurbishment - on going | 2009-Q4 |
| | 2005-207 | Five Nations Energy Inc. | New transformer at Kashechewan | 2009-Q3 |
| | 2005-207 | Five Nations Energy Inc. | New back up transformer at Fort Albany | 2008-Q3 |
| | 2000-015 | Five Nations Energy Inc. | New 115 kV transmission line from Moosonee to Victor Mine | 2008-Q1 |
| | 2002-086 | Hydro One Networks Inc. | Reinforce existing transmission facilities to supply Victor Mine | 2008-Q2 |
| Northwest | 2006-247 | Hydro One Networks Inc. | Lakehead TS static var compensator (SVC) | 2009-Q4 |
| Southwest | 2006-225 | Hydro One Networks Inc. | Woodstock TS low voltage shunt capacitors | 2008-Q2 |
| | 2006-221 | Hydro One Networks Inc. | Halton TS and Meadowvale TS low voltage shunt capacitors | 2009-Q2 |
| | 2006-EX299 | Hydro One Networks Inc. | Burlington TS: Replace the lower rated 230/115 kV transformer and buswork that limits the station capability. | 2008-Q2 2010-Q3 |
| | 2006-249 | Hydro One Networks Inc. | Bruce to Orangeville 230 kV circuits upgrade | 2009-Q1 |
| | 2007-295 | Hydro One Networks Inc. | Middleport TS 4x250 MVAR cap banks | 2009 - Q2 |
| | 2007-295 | Hydro One Networks Inc. | Buchanan TS 1x200 MVAR cap bank | 2009 - Q3 |
| | 2007-295 | Hydro One Networks Inc. | Nanticoke TS 2x250 MVAR cap banks | 2009 - Q4 |
| Toronto | 2006-213 | Hydro One Networks Inc. | Pleasant TS new transformer station | 2008-Q2 |
| West | 2007-EX318 | Hydro One Networks Inc. | Belle River TS low voltage shunt capacitors | 2008-Q2 |
| | 2007-EX328 | Hydro One Networks Inc. | Lambton TS: Replace Air Blast breakers with SF6 breakers, replace buswork (strain bus with rigid bus) and reconfigure lines | 2009-Q1 |
| | 2007-265 | Hydro One Networks Inc. | Keith autotransformers replacement | 2009-Q4 |

This page intentionally left blank.

- End of Section -

Appendix C Planned Transmission Outages

The following tables list the planned transmission outages by transmission zone, for transmission outages with an expected duration greater than five days, and/or for those transmission outages associated with a major project.

Table C1 Bruce Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|---------------------|---|-------------------|-------------|------|---------------------------------------|--|
| Oct 20 2008 5:00 AM | Oct 26 2008 6:00 PM | Bruce A TS: 21-B562L, B562L::LONGWOOD_TS::BRUCE_A_TS, W52-B562L, B562L::LONGWOOD_TS::BRUCE_A_TS | 4675791 | 8 Hour | CWW | FABC NBLIP | Oct 20 to Oct 24 1100 - 1200 MW when BLIP positive 750 - 850 MW when BLIP negative Oct 24 to Oct 26 950 MW when BLIP positive 600 MW when BLIP negative 500 MW |
| Oct 18 2008 7:00 AM | Oct 24 2008 5:00 PM | Longwood TS: HL562, B562L::LONGWOOD_TS::BRUCE_A_TS, PL562, W52-B562L, W52-B562L, 21-B562L, B562L::LONGWOOD_TS::BRUCE_A_TS | 5046792 | 3 Hour | CWW | FABC NBLIP | 1100 - 1200 MW when BLIP positive 750 - 850 MW when BLIP negative 500 MW |

Table C2 East Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|----------------------|---|-------------------|-------------|------|---------------------------------------|--------------------|
| May 30 2008 2:01 PM | Oct 31 2008 2:01 PM | Dobbin TS: T2-K, T2, T2-A | 4796540 | Immediate | CWW | None | |
| Oct 06 2008 4:01 AM | Oct 31 2008 4:01 PM | Galetta JCT: C27P::GALETTA_JCT::CHATS_FALLS_SS, DL33, AL27, C27P::GALETTA_JCT::CHATS_FALLS_SS, DL3, C27P::DOBBIN_TS::GALETTA_JCT, C27P::DOBBIN_TS::GALETTA_JCT, HL27, D_BUS | 5277035 | 8 Hour | CWW | FIO | 30 MW |
| Sep 08 2008 6:00 AM | Sep 26 2008 6:00 PM | St.Lawrence TS: 49-L20H, L20H::CROSBY_JCT::HINCHINBROOKE_SS, L20H::ST.LAWRENCE_TS::EASTON_JCT, T2-L20H, L20H::ST.LAWRENCE_TS::EASTON_JCT, L20H::EASTON_JCT::BROCKVILLE_TS, L20H::CROSBY_JCT::HINCHINBROOKE_SS, L20H::EASTON_JCT::BROCKVILLE_TS, L20H::EASTON_JCT::CROSBY_JCT, 24T2-L20H, L20H::EASTON_JCT::CROSBY_JCT, L20H::CROSBY_JCT::CROSBY_TS, L20H::CROSBY_JCT::CROSBY_TS, T3-L20H, 10-L20H | 5299333 | 12 Hour | CWW | None | |
| Sep 21 2009 6:00 AM | Oct 09 2009 4:00 PM | Easton Yule JCT: L22H::EASTON_YULE_JCT::SMITHS_FALLS_TS, L22H::EASTON_JCT::HINCHINBROOKE_SS, L22H::EASTON_YULE_JCT::SMITHS_FALLS_TS, L22H::EASTON_YULE_JCT::EASTON_JCT, L22H::EASTON_JCT::HINCHINBROOKE_SS, L22H::EASTON_YULE_JCT::EASTON_JCT, L22H::BROCKVILLE_TS::EASTON_JCT, L22H::EASTON_YULE_JCT::ST.LAWRENCE_TS, 49-L22H, 24T1-L22H, 10-L22H, T3-L22H, L22H::EASTON_YULE_JCT::ST.LAWRENCE_TS, L22H::BROCKVILLE_TS::EASTON_JCT | 5310000 | 8 Hour | CWW | None | |
| Mar 09 2009 6:00 AM | Mar 27 2009 6:00 PM | Hinchinbrooke SS: L21H::CROSBY_JCT::HINCHINBROOKE_SS, L21H::CROSBY_JCT::CROSBY_TS, L21H::EASTON_YULE_JCT::SMITHS_FALLS_TS, L21H::EASTON_YULE_JCT::SMITHS_FALLS_TS, L21H::CROSBY_JCT::CROSBY_TS, 49-L21H, T1-L21H, T3-L21H, L21H::CROSBY_JCT::HINCHINBROOKE_SS, L21H::EASTON_YULE_JCT::CROSBY_JCT, L21H::EASTON_YULE_JCT::CROSBY_JCT, L21H::ST.LAWRENCE_TS::EASTON_YULE_JCT, 10-L21H, T4-L21H, L21H::ST.LAWRENCE_TS::EASTON_YULE_JCT | 5326751 | 8 Hour | CWW | None | |
| Oct 13 2008 5:00 AM | Nov 07 2008 6:00 PM | Dobbin TS: T5, T5-H, T5-D | 5541971 | 8 Hour | CWW | None | |
| Aug 25 2008 5:00 AM | Oct 02 2008 6:00 PM | St.Lawrence TS: R33, PS33-1, PS33-1, PS33-2, PS33-2, PS33, PS33-S, R33-2, R33-1, PS33-2, L33P::FDRX-USA_LXP_TS::ST.LAWRENCE_TS, L33P::FDRX-USA_LXP_TS::ST.LAWRENCE_TS, PS33-S | 5542138 | 16 Hour | CWW | None | |
| Apr 21 2008 8:00 AM | May 02 2008 4:00 PM | Chenau TS: 4X6 | 5564362 | 8 Hour | CWW | None | |
| Apr 14 2008 7:00 AM | Apr 21 2008 4:00 PM | Chats Falls SS: AH | 5564691 | 8 Hour | CWW | None | |
| Apr 22 2008 7:00 AM | Apr 29 2008 4:00 PM | Chats Falls SS: HL3 | 5564757 | 8 Hour | CWW | None | |
| Sep 09 2008 7:00 AM | Sep 26 2008 5:00 PM | Smiths Falls TS: L21H::EASTON_YULE_JCT::SMITHS_FALLS_TS, L21H::ST.LAWRENCE_TS::EASTON_YULE_JCT, L21H::ST.LAWRENCE_TS::EASTON_YULE_JCT, L21H::EASTON_YULE_JCT::CROSBY_JCT, L21H::EASTON_YULE_JCT::CROSBY_JCT, L21H::CROSBY_JCT::HINCHINBROOKE_SS, L21H::CROSBY_JCT::HINCHINBROOKE_SS, L21H::EASTON_YULE_JCT::SMITHS_FALLS_TS, T1-L21H, 10-L21H, L21H::CROSBY_JCT::CROSBY_TS, L21H::CROSBY_JCT::CROSBY_TS, T3-L21H, 49-L21H, T4-L21H | 5567386 | 8 Hour | CWW | None | |
| Aug 25 2008 8:00 AM | Oct 02 2008 4:00 PM | St.Lawrence TS: PS33-2, R33-1, R33, PS33-1, PS33, R33-2, PS33-S, L33P::FDRX-USA_LXP_TS::ST.LAWRENCE_TS, L33P::FDRX-USA_LXP_TS::ST.LAWRENCE_TS, PS33-2 | 5572275 | 4 Hour | CWW | None | |
| May 12 2008 4:30 AM | May 23 2008 4:00 PM | St.Lawrence TS: AL31 | 5636475 | 24 Hour | CWW | None | |
| Sep 22 2008 4:30 AM | Sep 28 2008 4:00 PM | Napanee TS: X22::GRETNA_JCT::NAPANEE_TS, X22::GRETNA_JCT::NAPANEE_TS, X22::GRETNA_JCT::LENNOX_TS, T2-X22, T2-X22, X22::GRETNA_JCT::PICTON_TS, X22::GRETNA_JCT::PICTON_TS, 12-X22, X22::GRETNA_JCT::LENNOX_TS | 5667103 | 8 Hour | CWW | None | |
| Jun 01 2008 2:01 PM | Oct 31 2008 2:01 PM | Dobbin TS: T2-K, T2, T2-A | 5679026 | Immediate | CWW | None | |
| Jan 22 2008 3:15 PM | Jun 02 2008 1:20 PM | Dobbin TS: T2-A, T2-A | 5679511 | Immediate | CWW | None | |
| Nov 10 2008 6:00 AM | Nov 18 2008 12:00 PM | Hinchinbrooke SS: L3L23, P_BUS, H51L3, T2L3, T2L5, X3H::CATARAQUI_TS::HINCHINBROOKE_SS, X3H::CATARAQUI_TS::LENNOX_TS, X3H::CATARAQUI_TS::LENNOX_TS, HL3, T2, DL3, X3H::CATARAQUI_TS::HINCHINBROOKE_SS | 5701131 | 3 Day | CWW | None | |

Table C3 Essa Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|---------------------|--|-------------------|----------------|------|---------------------------------------|--------------------|
| Mar 24 2008 3:00 PM | Apr 25 2008 7:00 PM | Essa TS: 18-E8V, 2-S2E, S2E::STAYNER_TS::ESSA_TS, S2E::STAYNER_TS::ESSA_TS, 18-E9V, 18-S2E | 5362870 | 3 Day | CWW | None | |
| Apr 28 2008 5:00 AM | May 09 2008 6:00 PM | Essa TS: T3-J, T3, 18T3-AT3, T3-R3 | 5541981 | 8 Hour | CWW | None | |
| May 12 2008 5:00 AM | May 23 2008 6:00 PM | Essa TS: T4-D, T4, 18T4-HT4 | 5542008 | 8 Hour | CWW | None | |
| Sep 11 2008 5:00 PM | Sep 25 2008 7:00 AM | Essa TS: L7L8 | 5579073 | Non-Recallable | CWW | None | |
| Mar 24 2008 4:00 AM | Apr 25 2008 7:00 PM | Essa TS: AL8, 18-E8V, L7L8 | 5579134 | 4 Hour | CWW | None | |
| Sep 02 2008 5:00 AM | Sep 14 2008 9:00 PM | Essa TS: 18-X504E, X504E::HANMER_TS::ESSA_TS, 33-X504E, X504E::HANMER_TS::ESSA_TS | 5682719 | 36 Hour | CWW | FN FS | 1400 MW 600 MW |

Table C4 Niagara Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|----------------------|---------------------|---|-------------------|----------------|------|---------------------------------------|--------------------|
| Mar 31 2007 11:00 PM | Jan 22 2008 3:15 PM | Swann Rd 4: 1306, 1306 | 5006424 | Non-Recallable | CWW | None | |
| Apr 07 2008 5:00 AM | Apr 12 2008 6:00 PM | Beck #2 TS: PA301::BECK_#2_TS::NIAGARA_345_CTS, PA301::BECK_#2_TS::NIAGARA_345_CTS, 28-PA301 | 5128143 | 48 Hour | CWW | NY import W NY export W | 550 MW 540 MW |
| Apr 07 2008 7:00 AM | Apr 18 2008 5:00 PM | Beck #2 TS: TL21L23 | 5205809 | 6 Day | CWW | None | |
| Apr 28 2008 7:00 AM | May 09 2008 5:00 PM | Beck #2 TS: DL24 | 5205847 | 6 Day | CWW | None | |
| May 19 2008 7:00 AM | May 30 2008 5:00 PM | Beck #2 TS: KL23 | 5205899 | 6 Day | CWW | None | |
| Jun 02 2008 7:00 AM | Jun 13 2008 5:00 PM | Beck #2 TS: L25T302 | 5205913 | 6 Day | CWW | None | |
| May 12 2008 4:00 AM | May 23 2008 6:00 PM | Louth JCT: 69D10S-4, D10S::LOUTH_JCT::CARLTON_TS, D10S::LOUTH_JCT::CARLTON_TS, 69D10S-23, 40-D10S | 5287194 | 4 Hour | CWW | None | |
| May 27 2008 4:00 AM | Jun 06 2008 6:00 PM | Louth JCT: D9HS::VANSICKLE_TS::LOUTH_JCT, D9HS::VANSICKLE_TS::LOUTH_JCT, T5-D9HS, D9HS::HOOPER'S_JCT::VANSICKLE_TS, 69D9HS-4, 23-D9HS, 40-D9HS, D9HS::DECEW_FALLS_SS::HOOPER'S_JCT, D9HS::DECEW_FALLS_SS::HOOPER'S_JCT, D9HS::LOUTH_JCT::CARLTON_TS, D9HS::LOUTH_JCT::CARLTON_TS, D9HS::HOOPER'S_JCT::VANSICKLE_TS, D9HS::LOUTH_JCT::CARLTON_TS | 5287421 | 4 Hour | CWW | None | |
| Apr 14 2008 5:00 AM | Apr 19 2008 6:00 PM | Beck #2 TS: PA302::BECK_#2_TS::NIAGARA_345_CTS, PA302::BECK_#2_TS::NIAGARA_345_CTS, 28-PA302 | 5499751 | 48 Hour | CWW | NY import W NY export W | 550 MW 540 MW |
| Sep 14 2008 11:00 PM | Dec 12 2008 6:00 PM | Beck #1 SS: E7_BUS | 5797599 | 48 Hour | CWW | None | |

Table C5 Northeast Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|----------------------|--|-------------------|----------------|------|---------------------------------------|--------------------|
| Sep 09 2008 8:00 AM | Sep 14 2008 5:00 PM | Ansonville TS: T2, T2-H1, T2-LT2 | 5066717 | 4 Hour | CWW | None | |
| Jul 07 2008 5:30 AM | Jul 18 2008 4:00 PM | Martindale TS: S1R::MARTINDALE_TS::COPPER_CLIFF_JCT, S1R::MARTINDALE_TS::COPPER_CLIFF_JCT, T1-L | 5482202 | 4 Hour | CWW | None | |
| Aug 25 2008 5:00 AM | Sep 18 2008 6:00 PM | Crystal Falls TS: T6-H24S, 1820H24S-7, 9-H24S | 5503015 | 4 Hour | CWW | None | |
| Oct 06 2008 5:00 AM | Oct 24 2008 6:00 PM | Clarabelle JCT: S22A::CLARABELLE_JCT::ALGOMA_TS, 26-S22A, 9-S22A, S22A::MARTINDALE_TS::CLARABELLE_JCT, T2-S22A, S22A::CLARABELLE_JCT::CLARABELLE_TS, S22A::CLARABELLE_JCT::CLARABELLE_TS, S22A::CLARABELLE_JCT::ALGOMA_TS, S22A::MARTINDALE_TS::CLARABELLE_JCT | 5525309 | 4 Hour | CWW | EWTE | 50 MW |
| Mar 10 2008 6:00 AM | Apr 25 2008 7:00 PM | Tembec Smooth Rk JCT: 33H9K-27, 42H9K-MSO-2 | 5527123 | 4 Hour | CWW | None | |
| Jul 07 2008 5:00 AM | Jul 25 2008 6:00 PM | Widdifield SS: 38H24S-6, H24S::OTTO_HOLDEN_TS::WIDDIFIELD_SS, 6-H24S, 38H24S-6, H24S::OTTO_HOLDEN_TS::WIDDIFIELD_SS, 6-H24S | 5528280 | 4 Hour | CWW | None | |
| Jul 21 2008 5:00 AM | Aug 01 2008 6:00 PM | Porcupine TS: T7, 30T7-T, 30T7-H | 5542165 | 8 Hour | CWW | None | |
| Aug 11 2008 5:00 AM | Aug 22 2008 6:00 PM | Porcupine TS: T8, 30T8-H2, 30T8-T | 5542170 | 8 Hour | CWW | None | |
| Sep 08 2008 7:00 AM | Sep 19 2008 4:00 PM | Hanmer TS: W6L502, 33T6-W, W6L504 | 5578904 | 4 Hour | CWW | None | |
| Nov 10 2008 5:30 AM | Nov 21 2008 6:00 PM | Cobden JCT: T1B::RED_ROCK_CGS::COBDEN_JCT, 69T1B-38, T1B::RED_ROCK_CGS::COBDEN_JCT | 5579029 | 4 Hour | CWW | None | |
| May 26 2008 5:30 AM | Jun 06 2008 4:00 PM | Martindale TS: KT22, L23T22, T22, T22-22, T22-22, T22-E | 5630294 | 4 Hour | CWW | None | |
| Jun 01 2008 4:00 AM | Jun 29 2008 7:00 PM | Sudbury JCT: L1S-LC1, 9-L1S | 5782338 | 1 Day | CWW | None | |
| May 22 2008 5:00 PM | Jun 19 2008 9:00 AM | Mackay TS: #-1-GARTSHORE, #-1-GARTSHORE | 5783654 | Non-Recallable | CWW | None | |
| Jul 07 2008 6:00 AM | Jul 21 2008 8:00 AM | Mackay TS: 667, 783, NORTH BUS, 1416, 773 | 5784659 | 2 Day | CWW | None | |
| Jul 21 2008 1:00 PM | Aug 05 2008 10:00 AM | Gartshore TS: GRTSH2::MACKAY_T.S.:GARTSHORE_TS, GRTSH2::MACKAY_T.S.:GARTSHORE_TS | 5789119 | 2 Day | CWW | None | |
| Aug 06 2008 2:30 PM | Aug 25 2008 9:00 AM | Mackay TS: NORTH BUS, 661, 670, 793, 639, 660 | 5789476 | 2 Day | CWW | None | |
| Aug 25 2008 9:30 AM | Sep 08 2008 3:00 PM | Mackay TS: 670, 661, 666 | 5789564 | 2 Day | CWW | None | |

Table C6 Northwest Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|---------------------|---|-------------------|-------------|------|---|---|
| Apr 07 2008 7:00 AM | May 16 2008 7:00 PM | Dryden TS: 25-M2D, M2D-D | 5405100 | 4 Hour | CWW | None | |
| Mar 26 2008 7:00 AM | Apr 01 2008 5:00 PM | Whiteshell CTS: K22W::WHITESHELL_CTS::KENOR A_TS, K22W::WHITESHELL_CTS::KENOR A_TS, 34-K22W | 5443018 | 4 Hour | CWW | OMTE, OMTW, EWTE | OMTE - 100 MW OMTW - 100 MW EWTE - 50 MW |
| Apr 09 2008 7:00 AM | Apr 15 2008 5:00 PM | Kenora TS: 34-K22W, K22W::WHITESHELL_CTS::KENOR A_TS, K22W::WHITESHELL_CTS::KENOR A_TS | 5443022 | 4 Hour | CWW | OMTE, OMTW, EWTE | OMTE - 100 MW OMTW - 100 MW EWTE - 50 MW |
| Apr 23 2008 7:00 AM | Apr 29 2008 5:00 PM | Whiteshell CTS: K22W::WHITESHELL_CTS::KENOR A_TS, K22W::WHITESHELL_CTS::KENOR A_TS, 34-K22W | 5443026 | 4 Hour | CWW | Note: This outage is coincident with a W22M outage. EWTE, EWTW, OMTE, OMTW | These penalties are for K22W + W22M outage. EWTE - 105 MW EWTW - 100 MW OMTE - 125 MW OMTW - 100 MW |

(Table C6 continued)

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|----------------------|---|-------------------|-------------|------|---|--|
| May 21 2008 7:00 AM | May 27 2008 5:00 PM | Kenora TS: K21W::WHITESHELL_CTS::KENOR A_TS, 34-K21W, K21W::WHITESHELL_CTS::KENOR A_TS | 5443030 | 4 Hour | CWW | OMTE, OMTW, EWTE | OMTE - 100 MW OMTW - 100 MW EWTE - 50 MW |
| Jun 18 2008 7:00 AM | Jun 24 2008 5:00 PM | Kenora TS: K24F::KENORA_TS::FORT_FRANCE S_TS, K24F::KENORA_TS::FORT_FRANCE S_TS, 22-K24F, 34-K24F | 5443051 | 4 Hour | CWW | OMTE, OMTW, EWTE, MPFN, MPFS | OMTE - 50 MW OMTW - 250 MW EWTE - 75 MW MPFN - 50 MW MPFS - 140 MW |
| Jul 02 2008 7:00 AM | Jul 08 2008 5:00 PM | Kenora TS: K24F::KENORA_TS::FORT_FRANCE S_TS, 22-K24F, 34-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS | 5443056 | 4 Hour | CWW | OMTE, OMTW, EWTE, MPFN, MPFS | OMTE - 50 MW OMTW - 250 MW EWTE - 75 MW MPFN - 50 MW MPFS - 140 MW |
| Jul 16 2008 7:00 AM | Jul 22 2008 5:00 PM | Kenora TS: 34-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS, 22-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS | 5443061 | 4 Hour | CWW | OMTE, OMTW, EWTE, MPFN, MPFS | OMTE - 50 MW OMTW - 250 MW EWTE - 75 MW MPFN - 50 MW MPFS - 140 MW |
| Jul 30 2008 7:00 AM | Aug 05 2008 5:00 PM | Fort Frances TS: 22-K24F, 34-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS, K24F::KENORA_TS::FORT_FRANCE S_TS | 5443066 | 4 Hour | CWW | OMTE, OMTW, EWTE, MPFN, MPFS | OMTE - 50 MW OMTW - 250 MW EWTE - 75 MW MPFN - 50 MW MPFS - 140 MW |
| Aug 13 2008 7:00 AM | Aug 19 2008 5:00 PM | Kenora TS: 34-K24F, 22-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS, K24F::KENORA_TS::FORT_FRANCE S_TS | 5443071 | 4 Hour | CWW | OMTE, OMTW, EWTE, MPFN, MPFS | OMTE - 50 MW OMTW - 250 MW EWTE - 75 MW MPFN - 50 MW MPFS - 140 MW |
| Aug 27 2008 7:00 AM | Sep 02 2008 5:00 PM | Kenora TS: 34-K24F, 22-K24F, K24F::KENORA_TS::FORT_FRANCE S_TS, K24F::KENORA_TS::FORT_FRANCE S_TS | 5443076 | 4 Hour | CWW | Note: This outage is coincident with a W21M outage. EWTE, EWTW, OMTE, OMTW, MPFN, MPFS | These penalties are for K24F + W21M outage. EWTE - 105 MW EWTW - 200 MW OMTE - 150 MW OMTW - 250 MW MPFN - 50 MW MPFS - 140 MW |
| Apr 15 2008 9:00 AM | Apr 22 2008 12:00 PM | Port Arthur TS #1: 2P5M | 5648582 | 1 Hour | CWW | None | |
| Aug 18 2008 8:00 AM | Sep 11 2008 6:00 PM | Marathon TS: 15-W21M, W21M::WAWA_TS::MARATHON_TS , 14-W21M, W21M::WAWA_TS::MARATHON_TS | 5808939 | 2 Hour | CWW | EWTE, EWTW, OMTE, OMTW | EWTE - 105 MW EWTW - 100 MW OMTE - 50 MW OMTW - 50 MW |
| Apr 21 2008 8:00 AM | May 01 2008 6:00 PM | Marathon TS: 15-W22M, W22M::WAWA_TS::MARATHON_TS , 14-W22M, W22M::WAWA_TS::MARATHON_TS | 5808929 | 2 Hour | CWW | EWTE, EWTW, OMTE, OMTW | EWTE - 105 MW EWTW - 100 MW OMTE - 50 MW OMTW - 50 MW |
| Sep 15 2008 8:00 AM | Sep 25 2008 6:00 PM | Wawa TS: W22M::WAWA_TS::MARATHON_TS , 15-W22M, W22M::WAWA_TS::MARATHON_TS , 14-W22M | 5808934 | 2 Hour | CWW | EWTE, EWTW, OMTE, OMTW | EWTE - 105 MW EWTW - 100 MW OMTE - 50 MW OMTW - 50 MW |

Table C7 Ottawa Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|----------------------|----------------------|---|-------------------|----------------|------|---------------------------------------|--------------------|
| Oct 14 2008 5:00 AM | Oct 31 2008 4:00 PM | Merivale TS: L31L32 | 5505242 | 24 Hour | CWW | None | |
| Sep 18 2008 5:00 AM | Oct 10 2008 3:00 PM | Merivale TS: PL31 | 5505258 | 24 Hour | CWW | None | |
| Jun 01 2008 10:00 AM | Jun 08 2008 10:00 AM | OHSC JCT: 4803MSO-36 | 5563641 | Non-Recallable | CWW | None | |
| Sep 28 2008 6:00 AM | Oct 04 2008 5:00 PM | Merivale TS: P2-P3, PL31, T21-P3, P2_BUS, P3_BUS, PL30, P1_BUS, P1-P2, P1-P2 | 5608381 | 4 Hour | CWW | None | |
| Nov 10 2008 6:00 AM | Nov 15 2008 5:00 PM | Merivale TS: K1_BUS, K1-K2, KL32, KL29, K1-K2, K2_BUS, T22-K2 | 5608415 | 4 Hour | CWW | None | |
| Mar 16 2008 5:00 PM | May 03 2008 7:00 PM | Hawthorne TS: T9-D, T1-K | 5619315 | 3 Day | CWW | None | |
| May 05 2008 5:00 AM | May 15 2008 7:00 PM | Hawthorne TS: X522A::LENNOX_TS::HAWTHORNE_TS, X522A::LENNOX_TS::HAWTHORNE_TS, T3-LT3, 48-X522A, LT3W67, LT3_BUS, 12-X522A, DLT3 | 5619739 | 4 Hour | CWW | FIO | 400 MW |
| May 20 2008 5:00 AM | May 29 2008 7:00 PM | Hawthorne TS: DLT3, 84T2-M30A, M30A::ALBION_TS::MERIVALE_TS, M30A::ALBION_TS::MERIVALE_TS, LT3_BUS, 48-M30A, T3-LT3, 6-M30A, M30A::ALBION_TS::HAWTHORNE_TS, LT3W67, M30A::ALBION_TS::HAWTHORNE_TS | 5619782 | 8 Hour | CWW | None | |

Table C8 Southwest Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|---------------------|---|-------------------|-------------|------|---------------------------------------|---|
| Jan 05 2009 6:00 AM | Jan 30 2009 3:00 PM | Trafalgar TS: K1K2 | 4702290 | 3 Day | CWW | None | |
| Mar 25 2008 6:45 AM | Apr 04 2008 4:00 PM | Burlington TS: H2L36 | 5182548 | 6 Hour | CWW | None | |
| Apr 07 2008 7:00 AM | Apr 18 2008 5:00 PM | Burlington TS: H2L23 | 5286504 | 6 Day | CWW | None | |
| May 19 2008 7:00 AM | May 30 2008 5:00 PM | Burlington TS: L23L37 | 5286569 | 6 Day | CWW | None | |
| May 05 2008 7:00 AM | May 16 2008 5:00 PM | Middleport TS: L5L25 | 5286665 | 6 Day | CWW | None | |
| Jun 02 2008 7:00 AM | Jun 13 2008 5:00 PM | Burlington TS: A2L25 | 5286681 | 6 Day | CWW | None | |
| Jun 02 2008 7:00 AM | Jun 13 2008 5:00 PM | Middleport TS: KL25 | 5286695 | 6 Day | CWW | None | |
| Sep 15 2008 7:00 AM | Sep 26 2008 5:00 PM | Middleport TS: KL30 | 5286709 | 6 Day | CWW | None | |
| Sep 29 2008 7:00 AM | Oct 10 2008 5:00 PM | Middleport TS: L1L30 | 5286754 | 6 Day | CWW | None | |
| Oct 14 2008 7:00 AM | Oct 24 2008 5:00 PM | Burlington TS: A2L37 | 5286839 | 6 Day | CWW | None | |
| Oct 27 2008 7:00 AM | Nov 07 2008 5:00 PM | Burlington TS: H2L36 | 5286908 | 6 Day | CWW | None | |
| Sep 02 2008 6:00 AM | Nov 21 2008 3:00 PM | Milton SS: L70L73 | 5335735 | 5 Day | CWW | None | |
| Nov 04 2008 6:00 AM | Nov 14 2008 2:00 PM | Middleport TS: T3, T3-TL580, T3-LT3 | 5541951 | 8 Hour | CWW | FABC | 0 - 50 MW |
| Jun 16 2008 6:00 AM | Sep 05 2008 7:00 PM | Nanticoke TS: T11-E, T11-H, T11 | 5542119 | 36 Hour | CWW | None | |
| Sep 11 2008 7:00 AM | Sep 11 2008 5:00 PM | Detweiler TS: 26-D9G, 60-D9G-26, 60-D9G-67, 60-D9G-K5, 5A1-D9G, D9G::SIEBERT_JCT::KITCHENER_#6_JCT, D9G::FREEPORT_JCT::SPEEDSVILLE_JCT, D9G::SIEBERT_JCT::KITCHENER_#6_JCT, D9G::C.G.E._JCT::SPEEDSVILLE_JCT | 5546380 | 1 Hour | CWW | None | |
| Sep 08 2008 7:45 AM | Sep 19 2008 6:00 PM | Nanticoke TS: T7L581 | 5555508 | 4 Hour | CWW | None | |
| Jul 21 2008 7:00 AM | Aug 01 2008 6:00 PM | Nanticoke TS: T6T11 | 5555708 | 4 Hour | CWW | None | |
| Jun 16 2008 8:45 AM | Sep 05 2008 3:00 PM | Nanticoke TS: T11-H, T11, T11-E | 5555841 | 4 Hour | CWW | None | |
| Mar 29 2008 6:15 AM | Apr 03 2008 2:00 PM | Middleport TS: T6-LT6, T6, T6-TL581 | 5556213 | 8 Hour | CWW | FABC | Mar 29 to Mar 30 0 - 50 MW Mar 30 to Mar 31 0 - 200 MW Mar 31 - Apr 3 100 - 400 MW |
| May 04 2008 4:00 AM | May 09 2008 6:00 PM | Buchanan TS: 19-W7W, 10-W7W, T2, 38W7W-19, 38W7W-10, W7W::BUCHANAN_TS::INGERSOLL_TS, W7W::INGERSOLL_TS::WOODSTOCK_TS, W7W::INGERSOLL_TS::WOODSTOCK_TS, W7W::BUCHANAN_TS::INGERSOLL_TS | 5612015 | 4 Hour | CWW | None | |
| Jul 14 2008 7:00 AM | Jul 19 2008 5:00 PM | Buchanan TS: 19-W3T, W3T::BUCHANAN_TS::KETTLE_CREEK_JCT, W3T::KETTLE_CREEK_JCT::ST.THOMAS_TS, 11W3T, W3T::KETTLE_CREEK_JCT::ST.THOMAS_TS, W3T::BUCHANAN_TS::KETTLE_CREEK_JCT, W3T::KETTLE_CREEK_JCT::FORD_TALBOTVILLE_CTS, 11W3T, W3T::KETTLE_CREEK_JCT::FORD_TALBOTVILLE_CTS | 5615148 | 3 Hour | CWW | None | |
| May 05 2008 6:00 AM | Jun 06 2008 6:00 PM | Trafalgar TS: HL21 | 5629878 | 5 Day | CWW | None | |
| Mar 25 2008 6:00 AM | Apr 18 2008 2:00 PM | Trafalgar TS: T15L17 | 5630051 | 5 Day | CWW | None | |
| Apr 26 2008 6:20 AM | May 09 2008 2:00 PM | Middleport TS: L2L28 | 5768655 | 8 Hour | CWW | None | |
| Oct 20 2008 6:20 AM | Oct 31 2008 2:00 PM | Middleport TS: L2L33 | 5768932 | 8 Hour | CWW | None | |
| Aug 18 2008 6:20 AM | Aug 29 2008 2:00 PM | Middleport TS: L81L85 | 5776356 | 24 Hour | CWW | FABC FABC FETT | Aug 18 to Aug 23 50 - 100 MW Aug 23 to Aug 29 50 - 250 MW 700 MW |
| Apr 28 2008 6:30 AM | May 16 2008 3:00 PM | Detweiler TS: ASC21, A_BUS, AL7, AL6, AL4, 26-M21D | 5777751 | 8 Hour | CWW | FABC | Apr. 28 to May 5 100 - 250 MW May 5 to May 16 100 to 400 MW |
| Jun 02 2008 6:30 AM | Jun 20 2008 3:00 PM | Detweiler TS: AL4, AL7, AL6, A_BUS, 26-M21D, ASC21 | 5779539 | 8 Hour | CWW | FABC | Jun 2 to Jun 4 100 - 250 MW Jun 4 to Jun 14 100 - 400 MW Jun 14 to Jun 19 100 - 250 MW Jun 19 to Jun 20 100 - 400 MW |
| Jan 08 2008 1:07 PM | Jan 22 2008 3:15 PM | Detweiler JCT: D9G-D1W, D9G-D1W | 5787227 | 3 Hour | CWW | None | |
| Jun 02 2008 7:00 AM | Jun 13 2008 6:00 PM | Burlington TS: H1L39, H1L28, H1H2, T6-H1, H1_BUS | 5815236 | 4 Hour | CWW | None | |

Table C9 Toronto Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|---------------------|---|-------------------|----------------|------|---------------------------------------|--------------------|
| Apr 07 2008 8:40 AM | Apr 25 2008 3:10 PM | Hearn SS: SC12, SC12SC, SC12A-A, SC12A | 5298978 | 15 Day | CWW | None | |
| Apr 28 2008 6:30 AM | May 14 2008 2:30 PM | Cherrywood TS: AL543 | 5547707 | 8 Hour | CWW | None | |
| Sep 02 2008 6:30 AM | Sep 18 2008 2:30 PM | Cherrywood TS: L540A | 5547780 | 8 Hour | CWW | None | |
| Oct 14 2008 6:30 AM | Oct 24 2008 4:00 PM | Horner TS: T3-R15K, R15K::HORNER_TS::VANSCO_JCT, R15K::VANSCO_JCT::MANBYWJCT, R15K::MANBYWJCT::MANBY_WEST_TS, R15K::MANBYWJCT::RICHVIEW_TS, R15K::MANBYWJCT::RICHVIEW_TS, R15K::MANBYWJCT::MANBY_WEST_TS, 88-R15K, 38-R15K, R15K::VANSCO_JCT::MANBYWJCT | 5593984 | 2 Day | CWW | None | |
| Mar 18 2008 6:00 AM | May 02 2008 3:00 PM | Claireville TS: AL560 | 5629916 | 7 Day | CWW | None | |
| May 05 2008 6:00 AM | Jun 13 2008 3:00 PM | Claireville TS: AL510 | 5630149 | 7 Day | CWW | None | |
| Feb 06 2008 6:00 AM | Apr 22 2008 8:00 PM | Claireville TS: HL74, HT14, H1-H2, H1_BUS, H2_BUS, HL75, HL73, HL82, H1-H2 | 5740954 | Non-Recallable | CWW | None | |
| May 05 2008 5:00 AM | May 26 2008 5:00 PM | Claireville TS: 51-V71RP, T14L71, KL71 | 5805629 | 2 Day | CWW | None | |

Table C10 West Zone

| Planned Start Date | Planned End Date | Equipment O/S | Outage Request Id | Recall Time | Type | Major Transmission Interface Impacted | Reduction in Limit |
|---------------------|----------------------|--|-------------------|----------------|------|---------------------------------------|---|
| Apr 07 2008 4:00 AM | Apr 25 2008 6:00 PM | Sarnia Scott TS: L21L43 | 4300795 | Non-Recallable | CWW | None | |
| Apr 28 2008 4:00 AM | May 16 2008 5:00 PM | Sarnia Scott TS: L6L23 | 4385678 | Non-Recallable | CWW | None | |
| May 05 2008 4:00 AM | Jun 13 2008 6:00 PM | Lambton TS #2: 27-T7, T7-L4D, T7 | 4622862 | 2 Day | CWW | Michigan Import Michigan Export | May 5 to Jun 4 about 300 MW about 300 MW Jun 4 to Jun 13 575 MW 450 MW |
| Sep 02 2008 5:00 AM | Oct 10 2008 6:00 PM | Lambton TS #2: 27-T8, T8, T8-L4D | 4622886 | 3 Day | CWW | Michigan Import Michigan Export | about 300 MW about 300 MW |
| Jan 22 2008 3:15 PM | Dec 31 2008 11:59 PM | Lambton TS #2: PS4, PS4-2, PS4-2, PS4-1, PS4-1, PS4 | 4764494 | 30 Minute | CWW | None | |
| May 05 2008 8:00 AM | May 29 2008 6:00 PM | Bostwick Road JCT: N21W::BOSTWICK_ROAD_JCT ::WONDERLAND_TS, T6- N21W, 62N21W-36, N21W::BOSTWICK_ROAD_JCT ::WONDERLAND_TS, N21W::BOSTWICK_ROAD_JCT ::BUCHANAN_TS, N21W::BOSTWICK_ROAD_JCT ::BUCHANAN_TS, 19-N21W | 5205060 | 4 Hour | CWW | FABC FABC BLIP NBLIP | May 5 to May 16 100 - 400 MW May 16 to May 29 0 - 150 MW 500 MW 500 MW |
| Apr 18 2008 6:00 AM | May 09 2008 4:00 PM | Buchanan TS: L5L37 | 5249592 | Non-Recallable | CWW | None | |
| Mar 29 2008 4:00 AM | Apr 23 2008 5:00 PM | Lambton TS #2: PL27 | 5372138 | Non-Recallable | CWW | None | |
| Apr 27 2008 4:00 AM | May 23 2008 5:00 PM | Lambton TS #2: PL4 | 5372422 | Non-Recallable | CWW | None | |
| May 25 2008 4:00 AM | Jun 17 2008 5:00 PM | Lambton TS #2: KL4 | 5372561 | Non-Recallable | CWW | None | |
| Jun 18 2008 4:00 AM | Jul 15 2008 5:00 PM | Lambton TS #2: L27L28 | 5372672 | Non-Recallable | CWW | None | |
| Jun 19 2008 4:00 AM | Jul 07 2008 5:00 PM | Lambton TS #2: L27L28, 27-L27V, PL27 | 5372685 | Non-Recallable | CWW | FABC FABC BLIP NBLIP | Jun 19 to Jun 20 100 - 400 MW Jun 20 to Jul 7 0 - 150 MW 500 MW 500 MW |
| Aug 13 2008 4:00 AM | Sep 05 2008 5:00 PM | Lambton TS #2: PL23 | 5372721 | Non-Recallable | CWW | None | |
| Aug 23 2008 4:00 AM | Sep 03 2008 5:00 PM | Lambton TS #2: 27-L23N, PL23, L23L51 | 5372946 | Non-Recallable | CWW | FABC FABC BLIP NBLIP | Aug 23 to Aug 29 50 - 250 MW Aug 29 to Sep 3 0 - 150 MW 500 MW 500 MW |
| Sep 07 2008 4:00 AM | Oct 02 2008 5:00 PM | Lambton TS #2: PL29 | 5372957 | Non-Recallable | CWW | None | |
| Oct 05 2008 4:00 AM | Nov 02 2008 5:00 PM | Lambton TS #2: P1P2 | 5373391 | Non-Recallable | CWW | None | |
| Nov 03 2008 4:00 AM | Nov 25 2008 5:00 PM | Lambton TS #2: KL28 | 5373638 | Non-Recallable | CWW | None | |

