

Appendix D – Transmission System Details

Table of Contents

| | | |
|------------|---|-----------|
| 1.0 | Transmission System Description..... | 2 |
| 1.1 | Transmission System Interfaces..... | 2 |
| 1.2 | Interface Characteristics | 3 |
| 1.3 | Transmission System Zones..... | 7 |
| 1.4 | Transmission System Interconnections' Capabilities and External Markets | 8 |
| 2.0 | Definitions and Limits of Ontario's Interfaces | 11 |
| 2.1 | Definitions of Ontario's Interfaces..... | 11 |
| 2.2 | Limits of Ontario's Interfaces | 13 |
| 3.0 | Definitions and Limits of Ontario's Interconnections | 14 |
| 3.1 | Definitions of Ontario's Interconnections | 14 |
| 3.2 | Limits of Ontario's Interconnections..... | 15 |
| 4.0 | Plans – Hydro One | 17 |
| 5.0 | Planned Transmission Outages..... | 18 |

List of Tables

| | | |
|------------|---|----|
| Table D2.1 | Ontario's Interface Base Limits | 13 |
| Table D3.1 | Ontario's Interconnection Limits..... | 16 |
| Table D4.1 | Committed Plans - Hydro One | 17 |
| Table D5.1 | Transmission Outages Northwest Zone..... | 18 |
| Table D5.3 | Transmission Outages Essa Zone | 20 |
| Table D5.4 | Transmission Outages Bruce Zone..... | 21 |
| Table D5.5 | Transmission Outages West Zone..... | 22 |
| Table D5.6 | Transmission Outages Niagara Zone | 23 |
| Table D5.7 | Transmission Outages South Western Zone | 24 |
| Table D5.8 | Transmission Outages Toronto Zone..... | 25 |
| Table D5.9 | Transmission Outages East Zone..... | 27 |

List of Figures

| | | |
|---------------|---|---|
| Figure D1.1 | Ontario's Internal Zones and External Interconnections..... | 2 |
| Figure D1.2.1 | – Historical Flow Distribution – EWTE/EWTW and FN/FS Interfaces | 4 |
| Figure D1.2.2 | – Historical Flow Distribution – BLIP/NBLIP, FETT and QFW Interfaces..... | 6 |


This appendix contains, in Section 1.0, a description of the Ontario Transmission System followed, in Sections 2.0 and 3.0, by Ontario’s Interface and Interconnection Definitions and Limits. In Section 4.0 are shown Hydro One’s committed transmission facilities addition plans and, in Section 5.0, the transmission outage plan for the studied period is presented along with comments regarding the impact of the outages, where necessary.

1.0 Transmission System Description

1.1 Transmission System Interfaces

There are eight major interfaces in the Ontario electricity system, which will be accounted for in this study, as illustrated in Figure D1.1.

Figure D1.1 Ontario’s Internal Zones and External Interconnections



Interface Definitions

Interface definitions are formed by grouping one or more lines for the purpose of measuring their combined flow and enforcing a power flow limit or as it is more commonly called an interface limit. Interface limits are directional and interfaces may have limits imposed in one or both directions. Section 2.1 shows the major interface definitions used in Ontario. Notice that for each individual transmission element included in an interface definition both the positive direction of power flow and measurement point (e.g. which end of a transmission line the power flow is measured at) are specified.

Interface Capability Limits

Section 2.2 shows the base limits for the major interfaces that correspond to the definitions in Section 2.1; only normal system (all transmission elements in-service) limits are shown. Note that some limits are simply constants (e.g. BLIP) and others are more complicated and may depend on parameters such as specific generator unit statuses, other flows, primary demand, etc. (e.g. NBLIP, FETT, FABC). In cases where interface limits are based on thermal capability, separate ratings are shown for summer and winter conditions.

1.2 Interface Characteristics

The EWTE/EWTW Interface


The East-West Transfer East (EWTE) and East-West Transfer West (EWTW) flows are functionally related to the power flows between Ontario and Manitoba (OMTE/OMTW etc.). In this relationship OMTE/OMTW flows can be generally thought of as the independent variables as they are under phase shifter control.

The maximum limits on the East-West tie are 325 MW to the east and 350 MW to the west. The EWTE and EWTW interfaces are constrained by stability limitations. A sample of historical flow distribution on the East West Ties is shown in the Figure D1.2.1.

The FN/FS Interface

The Flow South (FS) limit is 1,400 MW and the Flow North (FN) limit is 1,900 MW. The Flow North and Flow South interfaces are constrained by voltage and stability limits respectively. A sample of historical flow distribution on the Flow North / South interface is shown in the Figure D1.2.1.

Figure D1.2.1 – Historical Flow Distribution – EWTE/EWTW and FN/FS Interfaces



The CLAN/CLAS Interface

The Claireville North (CLAN) limit is 2,000 MW and the Claireville South (CLAS) limit is 1,000 MW.

The FABC Interface

The Flow Away From Bruce Complex (FABC) limit is a functional relationship with a number of other system parameters. With only a total of four Bruce units available (the other four are on indefinite outage) the FABC limit is high enough that it is never limiting. The FABC limit can also be improved through the use of generation rejection of Bruce units.

The FETT Interface

The FETT (Flow East Towards Toronto) interface limit is a function of a variety of parameters. Normally the limit is near its high end of about 5,700 MW. The interface is constrained by a combination of stability and thermal limits. There is no limit specified for flows to the west, as the level of flows expected in that direction will not cause system concerns. A sample of historical flow distribution on the FETT interface is shown in the Figure D1.2.2.


The QFW Interface

The QFW (Queenston Flow West) interface is limited to 2,000 MW for flows to the west in the winter. In the summer, the limit is 1,800 MW to the west. This interface is constrained by thermal limitations. There is no limit specified for flows to the east, as the level of flows expected in that direction will not cause system concerns. A sample of historical flow distribution on the QFW interface is shown in the Figure D1.2.2.

The BLIP/NBLIP Interface

The BLIP (Buchanan Longwood Input) interface is limited to 3,500 MW to the west due to stability limitations. The NBLIP interface limit is a function of a variety of parameters. Normally the limit is near its high end of about 1,500 MW; the interface is typically constrained by voltage limitations. A sample of historical flow distribution on the BLIP interface is shown in the Figure D1.2.2.

Figure D1.2.2 – Historical Flow Distribution – BLIP/NBLIP, FETT and QFW Interfaces



The FWIC Interface

This interface does not have a pre-defined limit. It is included in this study to provide a boundary for the creation of the East Zone to allow for specific forecasts for this region for such parameters as economic conditions for load growth, total resources, etc.

1.3 Transmission System Zones

The Ontario transmission system has been divided up into nine zones to facilitate the study. Zonal boundaries have been chosen to correspond with the interface definitions in Section 2.1.

Northwest Zone Characteristics

- The total resources generally exceed the peak primary demand.
- The generation is mainly hydroelectric with some coal
- The zone is externally connected to the Manitoba and Minnesota systems.
- Both interconnections are under phase shifter control.
- MAPP (Mid-Continent Area Power Pool) criteria (similar to NPCC) are observed in Manitoba and Minnesota and there is a plan to move toward MAPP criteria limits in the Northwest zone. For many years Manitoba has accepted Northwest zone limits based on criteria less stringent than MAPP, but recently Manitoba joined the MAPP reliability council and as a result Ontario is compelled accordingly.

Northeast Zone Characteristics

- The total resources generally exceed the peak primary demand.
- The generation is mainly hydroelectric with some cogeneration.
- The zone is externally connected to the Quebec grid.
- The interconnection with Quebec is radial.

Essa Zone Characteristics

- The total resources are much less than the peak primary demand.
- The generation is totally hydroelectric.
- There are no external interconnections.

East Zone Characteristics

- The total resources exceed the peak primary demand.
- The generation is a mix of hydroelectric, oil, and gas.
- The zone is externally connected to the Quebec grid.
- The interconnection with Quebec is radial.
- It is also externally connected to New York with phase shifter control.

Toronto Zone Characteristics

- The total resources are much less than the peak primary demand.
- The generation is mostly nuclear and coal.
- There are no external interconnections.

Bruce Zone Characteristics

- The total resources are much greater than the peak primary demand.
- The generation is mostly nuclear.
- There are no external interconnections.

Southwest Zone Characteristics

- The total resources are well balanced with the peak primary demand.
- The generation is mostly coal.
- There are no external interconnections.

West Zone Characteristics

- The total resources are slightly less than the peak primary demand.
- The generation is mostly coal.
- The interconnection with Michigan will be under phase shifter control, by June 2001.

Niagara Zone Characteristics

- The total resources are much higher than the peak primary demand.
- The generation is mostly hydroelectric.
- There is a free-flowing interconnection with New York.

1.4 Transmission System Interconnections' Capabilities and External Markets

The term interconnection is used to describe interfaces that join Ontario to other (external) control areas.

Ontario has interconnections with Manitoba, Minnesota, Quebec, Michigan, and New York.

Interconnection Definitions

Interconnection definitions are shown in Section 3.1.

Interconnection Limits

Interconnection limits are shown in Section 3.2.

Interconnection Characteristics

All of Ontario's non-radial interconnections are under phase-shifter control, except for Niagara New York.

New phase shifters will be installed on the Ontario – Michigan interconnection by June 2001. The purpose of the new phase shifters is to control a loop flow or parallel path flow called Lake Erie Circulation (LEC). LEC occurs naturally through a combination of transmission system impedance with interconnection-wide load/generation dispatch; it is measured as an unscheduled flow across the points of interconnection with New York, at Niagara Falls, and with Michigan. Much of the time, LEC enters Ontario at the New York Niagara interconnection and exits Ontario at the Michigan interconnection. Power flows associated with this condition are often greater than 500 MW; on occasion they exceed 1,000 MW. LEC flows also appear on and aggravate the BLIP and QFW interfaces as they are in a direct series path. With the incorporation of the new

phase shifters it is expected that the incidence of constrained operation of QFW will be greatly reduced.

The Ontario - Manitoba Interconnection

The OMTE and OMTW limits are both 288 MW in summertime, 300 MW in wintertime and are constrained by stability and thermal limitations.

The Ontario - Minnesota Interconnection

The MPFN and MPFS limits are 100 and 150 MW respectively and are constrained by stability and thermal limitations.

The Ontario - Michigan Interconnection

The Michigan interconnection is constrained by thermal limitations and will be under phase shifter control by June 2001.

Before June 2001:

During winter months, the limits are 1600 MW for flows into Ontario and 2,400 MW for flows out of Ontario. In the summer, the limits are 1,500 MW for flows into Ontario and 2,350 MW for flows out of Ontario.

After June 2001:

During winter months, the limits are 1800 MW for flows into Ontario and 2,450 MW for flows out of Ontario. In the summer, the limits are 1,765 MW for flows into Ontario and 2,450 MW for flows out of Ontario.

The Ontario - New York Niagara Interconnection

The New York Niagara interconnection, in the winter, is limited to 1,750 MW for flows into Ontario and 2,050 MW for flows out of Ontario. In the summer, the limit is 1,450 MW for flows into Ontario and 1,950 MW for flows out of Ontario. The interconnection is constrained by thermal limitations in the winter and summer.

The QFW interface is in series with the NY Niagara interconnection. All flows entering Ontario on the NY Niagara interconnection will also appear on the QFW interface; this includes purchases and parallel path flows. Based on past experience and studies, the QFW interface always hits its limit before the limit is reached on the NY Niagara interconnection for flows entering Ontario; as a result, the capability of the NY Niagara interconnection is never fully utilized.

Typically, when QFW hits its limit of 1,800 MW under summer conditions, the flow across the NY Niagara interconnection is 1,100 MW (its limit is 1,450 MW). Similarly, when QFW hits its limit of 2,000 MW under winter conditions, flow across the NY Niagara interconnection is 1,300 MW (its limit is 1,750 MW).

The Ontario - New York East Interconnection

The limit on this interconnection is 400 MW for flows into or out of Ontario. The interconnection is constrained by thermal limitations and is under the control of phase shifters.

The Ontario Northeast - Quebec Interconnection

The Quebec North interconnection is thermally limited to 78 MW under winter conditions and 64 MW under summer conditions, for flows into Ontario from radial generation in Quebec. For flows out of Ontario, the limit is 80 MW and this is simply based on the maximum amount of radial load available to be supplied in Quebec.

The Ontario East - Quebec Interconnection

The Quebec South interconnection is limited to 1,330 MW for flows into Ontario due to stability limitations and available radial generation. For flows out of Ontario the limit is 450 MW and is due to stability and thermal limitations.

2.0 Definitions and Limits of Ontario's Interfaces

2.1 Definitions of Ontario's Interfaces

(* signifies the measurement point)

Buchanan Longwood Input (BLIP) Interface consists of the following circuits:

| | |
|-------|--------------------------------|
| B562L | Bruce A to Longwood* 500 kV |
| B563L | Bruce B to Longwood* 500 kV |
| N582L | Nanticoke to Longwood* 500 kV |
| D4W | Detweiler to Buchanan* 230 kV |
| D5W | Detweiler to Buchanan* 230 kV |
| M31W | Middleport to Buchanan* 230 kV |
| M32W | Middleport to Buchanan* 230 kV |
| M33W | Middleport to Buchanan* 230 kV |

Negative Buchanan Longwood Input (NBLIP) Interface consists of the following circuits:

| | |
|-------|--------------------------------|
| B562L | Longwood* to Bruce A 500 kV |
| B563L | Longwood* to Bruce B 500 kV |
| N582L | Longwood* to Nanticoke 500 kV |
| D4W | Buchanan* to Detweiler 230 kV |
| D5W | Buchanan* to Detweiler 230 kV |
| M31W | Buchanan* to Middleport 230 kV |
| M32W | Buchanan* to Middleport 230 kV |
| M33W | Buchanan* to Middleport 230 kV |

Queenston Flow West (QFW) Interface consists of the following circuits:

| | |
|-------|---|
| Q23BM | Beck2* to Burlington and Middleport (Neale Junction) 230 kV |
| Q25BM | Beck2* to Burlington and Middleport (Neale Junction) 230 kV |
| Q24HM | Beck2* to Hamilton and Middleport (Hannon Junction) 230 kV |
| Q29HM | Beck2* to Hamilton and Middleport (Hannon Junction) 230 kV |
| Q30M | Beck 2 (Allanburg Junction*) to Middleport 230 kV |

Flow East To Toronto (FETT) Interface consists of the following circuits:

| | |
|-------|-----------------------------------|
| B560V | Bruce A to Claireville* 500 kV |
| M570V | Milton to Claireville* 500 kV |
| M571V | Milton to Claireville* 500 kV |
| V586M | Middleport to Claireville* 500 kV |
| R14T | Trafalgar* to Richview 230 kV |
| R17T | Trafalgar* to Richview 230 kV |
| R19T | Trafalgar* to Richview 230 kV |
| R21T | Trafalgar* to Richview 230 kV |
| E8V | Orangeville to Essa* 230 kV |
| E9V | Orangeville to Essa* 230 kV |

Flow North (FN) and Interface consists of the following circuits:

X503E Essa* to Hamner 500 kV
 X504E Essa* to Hamner 500 kV
 D5H Des Joachims* to Holden 230 kV

Flow South (FS) Interface consists of the following circuits:

X503E Hamner to Essa* 500 kV
 X504E Hamner to Essa* 500 kV
 D5H Holden to Des Joachims* 230 kV

East-West Transfer West (EWTW) Interface consists of the following circuits:

W21M Wawa* to Marathon 230 kV
 W22M Wawa* to Marathon 230 kV

East-West Transfer East (EWTE) Interface consists of the following circuits:

W21M Marathon to Wawa* 230 kV
 W22M Marathon to Wawa* 230 kV

Claireville North (CLAN) Interface consists of the following circuits:

E510V Claireville* to ESSA 500kV
 E511V Claireville* to ESSA 500kV
 B82V Claireville* to Brown Hill 230kV
 B83V Claireville* to Brown Hill 230kV

Claireville South (CLAS) Interface consists of the following circuits:

E510V ESSA to Claireville* 500kV
 E511V ESSA to Claireville* 500kV
 B82V Brown Hill to Claireville* 230kV
 B83V Brown Hill to Claireville* 230kV

Flow Away from Bruce Complex (FABC) Interface consists of the following circuits:

B560V Bruce* to Claireville 500kV
 B561M Bruce* to Milton 500kV
 B562L Bruce* to Longwood 500kV
 B563L Bruce* to Longwood 500kV
 B4V Bruce* to Orangeville 230kV
 B5V Bruce* to Orangeville 230kV
 B22D Bruce* to Detweiler 230kV
 B23D Bruce* to Detweiler 230kV
 B27S Bruce* to Owen Sound 230kV
 B28S Bruce* to Owen Sound 230kV

Flow West Into Cherrywood (FWIC) Interface consists of the following circuits:

B540C Bowmanville to Cherrywood* 500kV
 B541C Bowmanville to Cherrywood* 500kV
 B542C Bowmanville to Cherrywood* 500kV
 B543C Bowmanville to Cherrywood* 500kV
 P15C Dobbin to Cherrywood* 230kV
 C28C Chat Falls to Cherrywood* 230kV
 H24C Havelock to Cherrywood* 230kV

| | |
|------|---------------------------------|
| H26C | Havelock to Cherrywood* 230kV |
| M29C | Merivale to Cherrywood* 230kV |
| B23C | Belleville to Cherrywood* 230kV |

2.2 Limits of Ontario's Interfaces

The Ontario major interfaces base limits, for all elements in service are shown in the Table D2.1.

Table D2.1 Ontario's Interface Base Limits

| Interface | Operating Security Limits (MW) |
|-----------|--------------------------------|
| BLIP | 3500 |
| NBLIP | 1500 |
| QFW | 1800 Summer, 2000 Winter |
| FABC | 5200, normally not limiting |
| FETT | 5700 |
| CLAN | 2000 |
| CLAS | 1000 |
| FN | 1900 |
| FS | 1400 |
| E-W | 325 East, 350 West |

3.0 Definitions and Limits of Ontario's Interconnections

3.1 Definitions of Ontario's Interconnections

The Ontario – Manitoba Interconnection

K21W Kenora 230 kV to Whiteshell 115 kV including combination voltage regulator and phase shifting transformer bank T7 at Whiteshell,

K22W Kenora 230 kV to Whiteshell 115 kV including combination voltage regulator and phase shifting transformer bank T8 at Whiteshell,

SK1 Rabbit Lake 115 kV to Seven Sisters 115 kV including an in-line voltage regulating transformer at Seven Sisters (radial operation only).

Ontario Manitoba Transfer West (OMTW) consists of the following circuits:

K21W Kenora* 230 kV to Whiteshell 230 kV

K22W Kenora* 230 kV to Whiteshell 230 kV

Ontario Manitoba Transfer East (OMTE) consists of the following circuits:

K21W Whiteshell 230 kV to Kenora* 230 kV

K22W Whiteshell 230 kV to Kenora* 230 kV

The Ontario – Minnesota interconnection

F3M Fort Frances 115 kV to International Falls 115 kV including two phase shifting transformers operated in series, T10 and T11, located at International Falls.

Minnesota Power Flow North (MPFN) consists of the following circuit:

F3M International Falls 115 kV to Fort Frances* 115 kV

Minnesota Power Flow South (MPFS) consists of the following circuit:

F3M Fort Frances* 115 kV to International Falls 115 kV

The Ontario – Quebec North interconnection consists of the following circuits:

D4Z Dymond* to Rapide Des Iles 115 kV,

H4Z Holden* to Kipawa 115 kV,

The Ontario – Quebec South interconnection consists of the following circuits:

X2Y Chenux to Bryson 115 kV,

Q4C Chats Falls to Quoyon 230 kV,

P33C Chats Falls to Paugan 230 kV,

H9A Hawthorne to Maclaren 115 kV,

H2AR Hawthorne to Maclaren 115 kV,

B5D St. Isidore to Beauharnois 230 kV,

B31L St. Lawrence to Beauharnois 230 kV.

The Ontario – Michigan Interconnection consists of the following circuits:

Before June 2001:

B3N Scott* 230 kV to Bunce Creek 120 kV, including in-line autotransformer.

L4D Lambton* 230 kV to St. Clair 345 kV, including in-line autotransformer.

L51D Lambton* 230 kV to St. Clair 345 kV, including in-line autotransformer.
 J5D Keith* 230 kV to Waterman 230 kV, including in-line combination voltage regulator and phase shifter SR5.

After June 2001:

B3N Scott* 230 kV to Bunce Creek 120 kV, including in-line autotransformer and phase shifter.
 L4D Lambton* 230 kV to St. Clair 345 kV, including two autotransformers in parallel and phase shifter.
 L51D Lambton* 230 kV to St. Clair 345 kV, including in-line autotransformer and phase shifter.
 J5D Keith* 230 kV to Waterman 230 kV, including in-line combination voltage regulator and phase shifter SR5.

The Ontario – New York Interconnection at Niagara consists of the following 60 Hz circuits to the New York Power Authority (NYPA), and Niagara Mohawk (NiaMo):

BP76 Beck2 230 kV to Packard 230 kV (NiaMo), including in-line voltage regulating transformer R76,
 PA27 Beck2 230 kV to Niagara Moses 230 kV (NYPA), including in-line voltage regulating transformer R27,
 PA301 Beck2 230 kV to Niagara Moses 345 kV (NYPA), including in-line 230 to 345 kV autotransformers T301,
 PA302 Beck2 230 kV to Niagara Moses 345 kV (NYPA), including in-line 230 to 345 kV autotransformers T302,
 BL104 Beck1 115 kV to Lockport 115 kV (NiaMo),

and the following two 25 Hz circuits

BSC105 Beck1 115 kV to Harper 69 kV (NiaMo), including an in-line 115 to 69 kV transformer at Parks TS,
 BSH106 Beck G7 to Harper 69 kV (NiaMo).

The Ontario – New York Interconnection at St. Lawrence consists of the following 60 Hz circuits to the New York Power Authority (NYPA):

L33P St. Lawrence 230 kV to FDR Moses 230 kV (NYPA) including in-line voltage regulating transformer R33 and in-line phase shifting transformer PS33,
 L34P St. Lawrence 230 kV to FDR Moses 230 kV (NYPA) including in-line combination voltage regulator and phase shifting transformer PSR34.

3.2 Limits of Ontario's Interconnections

The Ontario interconnection base limits, for all elements in service are shown in the Table D3.1.

Table D3.1 Ontario's Interconnection Limits

| Interconnection | Limit (MW) Flows Out of Ontario MW | Limit (MW) Flows Into Ontario |
|----------------------------|---------------------------------------|----------------------------------|
| Manitoba – Winter* | 300 | 300 |
| Manitoba – Summer* | 288 | 288 |
| Minnesota | 150 | 100 |
| Quebec North – Winter* | 80 | 78 |
| Quebec North – Summer* | 80 | 64 |
| Quebec South | 450 | 1,330 |
| New York East | 400 | 400 |
| New York Niagara – Winter* | 2,050 | 1,750 |
| New York Niagara – Summer* | 1,950 | 1,450 |
| Michigan – Winter* | 2,400 / 2,450** | 1,600 / 1,800** |
| Michigan – Summer* | 2,350 / 2,450** | 1,500 / 1,765** |

*Seasonal Limits are based on thermal ratings and 75% of pre-load. Summer Limits apply from May 1 to October 31 and are based on 0-4 km/hr wind speed and 30 Deg.C ambient temperature (except on ties with Michigan, which are based on 35 Deg.C). Winter Limits apply from November 1 to April 30 and are based on 0-4 km/hr wind speed and 10 Deg.C ambient temperature.

** For the Ontario – Michigan Interconnection the displayed values are, respectively, before June 2001 and after June 2001 (the in service date of the phase shifters).

4.0 Plans – Hydro One

Table D4.1 Committed Plans - Hydro One

| Committed Plans | Purpose | Description | Projected In-service |
|---|--|--|----------------------|
| Establish connection to Maclaren Industries | Increase interconnection capacity to Hydro Quebec | Provide 230 kV interconnection via D5A | Sep. 2000 |
| Install generation rejection scheme in the West System | Mitigate some of the impact of full compliance to NPCC, MAPP and NERC (this project deals with respecting loss of double circuit as single contingency). | Reject Atikokan GS for the loss of A21L/A22L or M23L/M24L. (Improve TEM and LE limits) | Nov. 2000 |
| Install phase-shifters on the interconnection to Michigan | Control Lake Erie Circulation and increase import capability | 845 MVA unit on L51D and L4D; Reconnect T7 auto to L4D for parallel operation with T8 | Jun. 2001 |
| Install shunt capacitor bank at Chatham SS | Increase load meeting capability for the Windsor area | 230 kV Capacitor: 225 MVAR @ 249.4 kV | Jun. 2001 |
| Refurbish Chatham SS | Replace end of life facilities | Replace 230 kV circuit breakers and associated equipment | Jul. 2001 |
| Refurbish St Lawrence TS | Replace end of life facilities | Replace 230 kV circuit breakers and associated equipment | Jul. 2001 |
| Refurbish L1S 115 kV line section | Transmission line refurbishment | Refurbish Crystal Falls GS x Warren DS | Dec. 2000 |

5.0 Planned Transmission Outages

Table D5.1 Transmission Outages Northwest Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|--|-----------|-----------|-------------|--------------|--|--|
| 12 | K3D Rabbit Lake x Vermilion Bay DS 115kV | 18-Sep-00 | 30-Nov-00 | Continuous | 8 | | |
| 13 | ST5 Seven Sisters x Transcona 115kV | 19-Sep-00 | 13-Oct-00 | Continuous | 8 | | |
| 31 | ST6 Seven Sisters x Transcona 115kV | 02-Oct-00 | 13-Oct-00 | Continuous | 8 | | |
| 74 | D26A Dryden x Mackenzie 230kV | 23-Oct-00 | 02-Nov-00 | Continuous | 1 | 250 MW OMTW; 225 MW TEM (Transfer East of Mackenzie) | Not Limiting for expected flow direction |
| 95 | WT34 Whiteshell x Transcona 115kV | 06-Nov-00 | 01-Dec-00 | Continuous | 8 | | |
| 96 | 907 Littlefork TS x SHAN 230kV | 06-Nov-00 | 22-Nov-00 | Continuous | None | | |
| 149 | Whiteshell T8 failed | 04-Jun-00 | 31-Dec-01 | Continuous | None | | |

Table D5.2 Transmission Outages Northeast Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---------------------------------|-----------|-----------|-----------------|--------------|--|---------------------------------------|
| 11 | L1S Verner DS x Warren DS 115kV | 18-Sep-00 | 30-Nov-00 | Continuous | None | 5 MW D4Z or H4Z in Mode 2; 15 MW D4Z in Mode 3 | |
| 28 | W2C Wawa x Chapleau MS 115kV | 01-Oct-00 | 10-Oct-00 | Continuous | 1 | | |
| 44 | L22L25 Martindale 230kV | 02-Oct-00 | 11-Oct-00 | Continuous | 8 | | |
| 57 | A24P Algoma x Mississagi 230kV | 16-Oct-00 | 26-Oct-00 | Continuous | None | | |
| 75 | T28P Wells x Mississagi 230kV | 23-Oct-00 | 27-Oct-00 | Continuous | 12 | | |
| 97 | X27A Hanmer x Algoma 230kV | 06-Nov-00 | 24-Nov-00 | Daily - PM only | 0.5 | | |
| 100 | T27P Wells x Mississagi 230kV | 13-Nov-00 | 24-Nov-00 | Continuous | 12 | | |
| 110 | P26W Mississagi x Wawa 230kV | 27-Nov-00 | 08-Dec-00 | Continuous | 12 | 105 MW EWTE | May limit NW Zone Generation Dispatch |

Table D5.3 Transmission Outages Essa Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|------------------------------------|-----------|-----------|--------------------------------|--------------|--------------------|--------|
| 3 | T5 Waubashene 230kV | 05-Sep-00 | 20-Oct-00 | Continuous | 48 | | |
| 16 | T2 Muskoka 230kV | 25-Sep-00 | 06-Oct-00 | Continuous | 8 | | |
| 32 | S2S Meaford x Stayner 115kV | 02-Oct-00 | 24-Nov-00 | Continuous – No Weekends | 4 | | |
| 63 | D4M Des Joachims GS x Minden 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 3 | | |
| 64 | D4M Des Joachims GS x Minden 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 8 | | |

Table D5.4 Transmission Outages Bruce Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|------------------------|-----------|-----------|-------------|--------------|--------------------|--------|
| 33 | T27 Bruce A 230kV | 02-Oct-00 | 13-Oct-00 | Continuous | 8 | | |
| 34 | E BUS Bruce A 500kV | 02-Oct-00 | 06-Oct-00 | Continuous | 8 | | |
| 35 | R27 Bruce A 28kV | 02-Oct-00 | 13-Oct-00 | Continuous | 8 | | |
| 58 | T4L560 Bruce A 500kV | 16-Oct-00 | 20-Oct-00 | Continuous | 4 | | |
| 76 | L560 BUS Bruce A 500kV | 23-Oct-00 | 27-Oct-00 | Continuous | 8 | | |
| 77 | HT4 BUS Bruce A 500kV | 23-Oct-00 | 27-Oct-00 | Continuous | 8 | | |
| 90 | T25 Bruce A 230kV | 06-Nov-00 | 10-Nov-00 | Continuous | 8 | | |
| 91 | R25 Bruce A 28kV | 06-Nov-00 | 10-Nov-00 | Continuous | 8 | | |
| 92 | L24T25 Bruce A 230kV | 06-Nov-00 | 10-Nov-00 | Continuous | 8 | | |

Table D5.5 Transmission Outages West Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|--------------------------------|-----------|-----------|---------------------|--------------|---|---|
| 5 | HL45 Buchanan 230kV | 11-Sep-00 | 27-Oct-00 | Continuous | None | | |
| 17 | KL1 Scott 115kV | 25-Sep-00 | 03-Oct-00 | Continuous | None | | |
| 18 | HL27 Scott 230kV | 25-Sep-00 | 06-Oct-00 | Continuous | None | | |
| 20 | KT1L7 Seaforth 115kV | 25-Sep-00 | 06-Oct-00 | Continuous | None | | |
| 29 | DL42 Longwood 230kV | 01-Oct-00 | 07-Oct-00 | Continuous | 1 | | |
| 30 | L23L29 Chatham 230kV | 01-Oct-00 | 13-Oct-00 | Continuous | None | | |
| 36 | L29 BUS Chatham 230kV | 02-Oct-00 | 09-Oct-00 | Daily - No Weekends | 4 | | |
| 37 | PL6 Scott 115kV | 02-Oct-00 | 12-Oct-00 | Continuous | None | | |
| 45 | L5L37 Buchanan 230kV | 06-Oct-00 | 19-Oct-00 | Continuous | None | | |
| 46 | 1K2 Buchanan 115kV | 06-Oct-00 | 13-Oct-00 | Continuous | None | | |
| 47 | T4L5 Buchanan 115kV | 09-Oct-00 | 20-Oct-00 | Continuous | None | | |
| 52 | T3 Crawford 115kV | 13-Oct-00 | 29-Oct-00 | Continuous | None | | |
| 53 | J4C Keith TS x Crawford 115kV | 14-Oct-00 | 18-Oct-00 | Continuous | 8 | | |
| 54 | 1P2 Buchanan 115kV | 14-Oct-00 | 20-Oct-00 | Continuous | None | | |
| 55 | T4 Crawford 115kV | 14-Oct-00 | 29-Oct-00 | Continuous | None | | |
| 56 | KL29 Chatham 230kV | 15-Oct-00 | 20-Oct-00 | Continuous | None | | |
| 71 | HL37 Buchanan 230kV | 21-Oct-00 | 03-Nov-00 | Continuous | None | | |
| 72 | L5K Buchanan 115kV | 21-Oct-00 | 27-Oct-00 | Continuous | None | | |
| 73 | DL21 Chatham 230kV | 22-Oct-00 | 27-Oct-00 | Continuous | None | | |
| 81 | L9P Buchanan 115kV | 28-Oct-00 | 03-Nov-00 | Continuous | None | | |
| 83 | L21L45 Chatham 230kV | 29-Oct-00 | 03-Nov-00 | Continuous | None | | |
| 89 | KL45 Chatham 230kV | 05-Nov-00 | 10-Nov-00 | Continuous | None | | |
| 98 | KL24 Chatham 230kV | 12-Nov-00 | 17-Nov-00 | Continuous | None | | |
| 103 | DL28 Chatham 230kV | 19-Nov-00 | 24-Nov-00 | Continuous | None | | |
| 104 | J5D Keith TS x Waterman 230kV | 20-Nov-00 | 24-Nov-00 | Continuous | 1 | 100 MW FABC; 500 MW Positive BLIP & Negative BLIP; 400 MW OH-MICH & MICH-OH | Reduced Interconnection Capacity |
| 109 | L24L28 Chatham 230kV | 24-Nov-00 | 01-Dec-00 | Continuous | None | | |
| 111 | B563L Bruce B x Longwood 500kV | 27-Nov-00 | 15-Dec-00 | Daily | 2 | 700 MW FABC; 500 MW Negative BLIP; 500 MW FETT | Negative BLIP will reduce the interconnection import capability |
| 112 | K BUS Chatham 230kV | 27-Nov-00 | 01-Dec-00 | Continuous | 4 | | |
| 117 | D BUS Chatham 230kV | 04-Dec-00 | 08-Dec-00 | Continuous | 4 | | |
| 140 | W37 Buchanan x Talbot 230kV | 02-Apr-01 | 13-Apr-01 | Continuous | 144 | | |
| 147 | W36 Buchanan x Talbot 230kV | 16-Apr-01 | 27-Apr-01 | Continuous | 144 | | |

Table D5.6 Transmission Outages Niagara Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---|-----------|-----------|--------------------------|--------------|---|--------------|
| 2 | C2P Crowland x Port Colborne TS 115kV | 13-Aug-00 | 17-Dec-00 | Continuous | None | | |
| 6 | B3 Burlington x Dundas 115kV | 11-Sep-00 | 31-Oct-00 | Continuous | 1 | | |
| 7 | HL7 Allanburg 115kV | 11-Sep-00 | 05-Oct-00 | Continuous | None | | |
| 14 | Q30M Beck 2 x Middleport 230kV | 20-Sep-00 | 17-Nov-00 | Continuous – No Weekends | 2 | 100 MW FABC; 200 MW FETT 400 MW QFW | Not Limiting |
| 19 | D BUS Nanticoke 500kV | 25-Sep-00 | 05-Oct-00 | Continuous | 1 | | |
| 38 | D1L29 Hamilton Beach 230kV | 02-Oct-00 | 06-Oct-00 | Continuous | 24 | | |
| 48 | DL1 Allanburg 115kV | 10-Oct-00 | 03-Nov-00 | Continuous | None | | |
| 59 | T8 Hamilton Beach 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 8 | | |
| 60 | DL1 Allanburg 115kV | 16-Oct-00 | 03-Nov-00 | Continuous | None | | |
| 61 | 1D2 Beck 2 230kV | 16-Oct-00 | 27-Oct-00 | Continuous | None | | |
| 62 | H8 BUS Hamilton Beach 115kV | 16-Oct-00 | 20-Oct-00 | Continuous | None | | |
| 78 | B4 Burlington x Dundas 115kV | 23-Oct-00 | 27-Oct-00 | Continuous | 4 | | |
| 84 | DK Newton 115kV | 30-Oct-00 | 03-Nov-00 | Continuous | 12 | | |
| 93 | A36N Allanburg x Niagara Murray 115kV | 06-Nov-00 | 16-Nov-00 | Continuous | None | | |
| 102 | D6V Detweiler x Orangeville 230kV | 16-Nov-00 | 23-Nov-00 | Daily | 1 | | |
| 105 | T1 Hamilton Beach 230kV | 20-Nov-00 | 24-Nov-00 | Continuous | 12 | | |
| 106 | A37N Allanburg x Niagara Murray 115kV | 20-Nov-00 | 30-Nov-00 | Continuous | None | | |
| 113 | T7 Hamilton Beach 230kV | 27-Nov-00 | 01-Dec-00 | Continuous | 12 | | |
| 118 | T6 Hamilton Beach 230kV | 04-Dec-00 | 08-Dec-00 | Continuous | 12 | | |
| 122 | T5 Hamilton Beach 115kV | 11-Dec-00 | 15-Dec-00 | Continuous | 12 | | |
| 125 | T8 Hamilton Beach 230kV | 18-Dec-00 | 22-Dec-00 | Continuous | 12 | | |
| 128 | Q24HM Hamilton Beach x Dofasco Kenilworth CTS 230kV | 15-Jan-01 | 19-Jan-01 | Continuous | None | | |
| 130 | Q29HM Hamilton Beach x Dofasco Kenilworth CTS 230kV | 22-Jan-01 | 26-Jan-01 | Continuous | None | | |

Table D5.7 Transmission Outages South Western Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---------------------|-----------|-----------|-------------|--------------|--------------------|--------|
| 65 | T11 Nanticoke 500kV | 16-Oct-00 | 27-Oct-00 | Continuous | 96 | | |

Table D5.8 Transmission Outages Toronto Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---|-----------|-----------|-----------------------------|--------------|--|--|
| 4 | DL511 Claireville 500kV | 05-Sep-00 | 27-Oct-00 | Continuous | 96 | | |
| 8 | E511V Essa x Claireville 500kV | 11-Sep-00 | 03-Nov-00 | Daily | 4 | 700 MW CLAN; 1200 MW FN (Normal); 100 MW FS with G/R | Flow North may become limiting at off peak hours requiring Northern generation to be operated |
| 9 | T4 Malvern 230kV | 11-Sep-00 | 20-Oct-00 | Continuous | 48 | | |
| 15 | R21T Richview x HANJ 230kV | 23-Sep-00 | 06-Oct-00 | Continuous | 12 | | |
| 21 | T3 Ellesmere 230kV | 25-Sep-00 | 06-Oct-00 | Continuous | 4 | | |
| 27 | R19T HANJ x Richview 230kV | 25-Sep-00 | 06-Oct-00 | Continuous | 12 | | |
| 39 | H BUS Cecil 115kV | 02-Oct-00 | 06-Oct-00 | Continuous | 8 | | |
| 40 | E511V Essa x Claireville 500kV | 02-Oct-00 | 06-Oct-00 | Continuous | 12 | | |
| 41 | L7L8 Cecil 115kV | 02-Oct-00 | 27-Oct-00 | Continuous | 48 | | |
| 49 | KL561 Milton 500kV | 10-Oct-00 | 17-Nov-00 | Continuous | 6 | 400 MW FETT | Not Limiting |
| 66 | T23 Scarboro 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 4 | | |
| 79 | L24CR Lakeview GS x Cooksville x Richview 230kV | 23-Oct-00 | 10-Nov-00 | Continuous - No Weekends | 2 | | |
| 80 | B560V Bruce A x Claireville 500kV | 23-Oct-00 | 27-Oct-00 | Continuous | 8 | 850 MW FABC; 500 MW Negative BLIP; 500 MW FETT | Negative BLIP will reduce the interconnection import capability |
| 82 | T1 Markham MTS 1 230kV | 28-Oct-00 | 05-Nov-00 | Continuous | None | | |
| 85 | L5D Leaside x Duplex 115kV | 30-Oct-00 | 03-Nov-00 | Continuous | 8 | | Some Toronto area outages may be impactful due to coincident Toronto Zone Generator Outages scheduled in Oct and early Nov |
| 86 | T16 Claireville 500kV | 30-Oct-00 | 03-Nov-00 | Continuous | 8 | 150 MW FETT | See above |
| 101 | T8P Pickering B 230kV | 13-Nov-00 | 17-Nov-00 | Continuous | 4 | | |
| 107 | C4R Cherrywood x Malvern 230kV | 20-Nov-00 | 08-Dec-00 | Continuous | 12 | 150 MW FETT | Not Limiting |
| 108 | C5R Cherrywood x Malvern 230kV | 20-Nov-00 | 08-Dec-00 | Continuous | 12 | 150 MW FETT | Not Limiting |
| 114 | L540 BUS Cherrywood 500kV | 27-Nov-00 | 01-Dec-00 | Continuous | 4 | | |
| 115 | B540C Bowmanville x Cherrywood 500kV | 27-Nov-00 | 01-Dec-00 | Continuous | 4 | | |
| 116 | T2 Carlton 115kV | 27-Nov-00 | 01-Dec-00 | Continuous | None | | |
| 119 | B541C Bowmanville x Cherrywood 500kV | 04-Dec-00 | 08-Dec-00 | Continuous | 4 | | |

(Table D5.8 continued)

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---|-----------|-----------|-------------|--------------|--------------------|--------------|
| 120 | L541 BUS Cherrywood 500kV | 04-Dec-00 | 08-Dec-00 | Continuous | 4 | | |
| 121 | T3 Carlton 115kV | 04-Dec-00 | 08-Dec-00 | Continuous | None | | |
| 123 | C4R Malvern x LEAJ 230 | 11-Dec-00 | 22-Dec-00 | Continuous | 12 | 150 MW FETT | Not Limiting |
| 124 | C5R Malvern x LEAJ 230 | 11-Dec-00 | 22-Dec-00 | Continuous | 12 | 150 MW FETT | Not Limiting |
| 126 | H35D Hamilton Beach x Dofasco Bay Front CTS 230kV | 01-Jan-01 | 31-Jan-01 | Continuous | None | | |

Table D5.9 Transmission Outages East Zone

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|--|-----------|-----------|--------------------------|--------------|---|---|
| 1 | T52 Lennox 500kV | 07-Mar-99 | 15-Mar-01 | FO | None | | |
| 22 | D6 PTAW x Chalk River CTS 115kV | 25-Sep-00 | 06-Oct-00 | Continuous | 4 | | |
| 23 | W6MC Stewartville x Marchwood MS 115kV | 25-Sep-00 | 03-Nov-00 | Continuous - No Weekends | 4 | 140 MW Lower Madawaska Total | May bottle generation at local hydro plants unless coincident generator outages are scheduled |
| 24 | X522A Lennox x Hawthorne 500kV | 25-Sep-00 | 06-Oct-00 | Continuous - No Weekends | 4 | 400 MW Flow Into Ottawa (FIO) | Not Limiting for Demand Levels in the Fall of Year 2000 |
| 25 | L22 BUS St Lawrence 230kV | 25-Sep-00 | 05-Oct-00 | Continuous | 6 | | |
| 26 | AL22 St Lawrence 230kV | 25-Sep-00 | 15-Oct-00 | Continuous | 144 | | |
| 42 | L2L21 Hinchinbrooke 230kV | 02-Oct-00 | 06-Oct-00 | Continuous | 1 | | |
| 43 | HL34 St Lawrence 230kV | 02-Oct-00 | 06-Oct-00 | Continuous | 8 | | |
| 50 | X6 Chenaux x Cobden TS 115kV | 10-Oct-00 | 27-Oct-00 | Continuous | 1 | | |
| 51 | X523A Lennox x Hawthorne 500kV | 10-Oct-00 | 27-Oct-00 | Continuous - No Weekends | 4 | 400 MW Flow Into Ottawa (FIO) | Not Limiting for Demand Levels in the Fall of Year 2000 |
| 67 | L22L27 Hinchinbrooke 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 1 | | |
| 68 | HT5L31 Hawthorne 230kV | 16-Oct-00 | 20-Oct-00 | Continuous | 4 | | |
| 69 | M5G Merivale x Lisgar TS 115kV | 16-Oct-00 | 26-Oct-00 | Continuous | 24 | | |
| 70 | HL26 St Lawrence 230kV | 16-Oct-00 | 12-Nov-00 | Continuous | 144 | | |
| 87 | L24A St Lawrence x Hawthorne 230kV | 30-Oct-00 | 10-Nov-00 | Continuous - No Weekends | 4 | 100 MW FIO | Not Limiting for Demand Levels in the Fall of Year 2000 |
| 88 | C27P Dobbin TS x BANN 230kV | 30-Oct-00 | 03-Nov-00 | Continuous | 12 | 240 MW Flow Into Dobbin (FID); 30 MW FIO | Requires local generation support and/or Generator cross-tripping armed |
| 138 | G4 Darlington A 0kV | 30-Mar-01 | 15-Apr-01 | FO | 0.1 | | |
| 94 | P4S Sidney TS x Port Hope 115kV | 06-Nov-00 | 28-Dec-00 | Continuous - No Weekends | 4 | 75 MW FLOW Into Dobbin | Requires local generation support and/or Generator cross-tripping armed |
| 99 | L21L26 St Lawrence 230kV | 12-Nov-00 | 08-Dec-00 | Continuous | 144 | | |
| 127 | L31L33 St Lawrence 230kV | 02-Jan-01 | 26-Jan-01 | Continuous | 144 | | |
| 129 | B31L Beauharnois x St Lawrence 230kV | 15-Jan-01 | 01-Feb-01 | Continuous - No Weekends | None | 400 MW Beauharnois Delivery Limit; 100 MW FIO | Reduced import Capability from Hydro Quebec from 800 MW to 400 MW at Beauharnois |
| 131 | L31 BUS St Lawrence 230kV | 29-Jan-01 | 09-Feb-01 | Continuous | 6 | | |
| 132 | AL31 St Lawrence 230kV | 29-Jan-01 | 23-Feb-01 | Continuous | 144 | | |

(Table D5.9 continued)

| Seq Id# | Element Description | Start | Finish | Outage Type | Recall Hours | Reduction in Limit | Impact |
|---------|---------------------------|-----------|-----------|-------------|--------------|--------------------|--------|
| 135 | L24 BUS St Lawrence 230kV | 26-Feb-01 | 09-Mar-01 | Continuous | 6 | | |
| 136 | L22L24 St Lawrence 230kV | 26-Mar-01 | 19-Apr-01 | Continuous | 6 | | |
| 141 | KL520 Lennox 500kV | 02-Apr-01 | 06-Apr-01 | Continuous | 4 | | |
| 142 | K BUS Lennox 500kV | 02-Apr-01 | 06-Apr-01 | Continuous | 4 | | |
| 143 | T51 Lennox 500kV | 02-Apr-01 | 06-Apr-01 | Continuous | 4 | | |
| 148 | H32L33 St Lawrence 230kV | 23-Apr-01 | 17-May-01 | Continuous | 6 | | |