

CT Loading Assessment

Revenue Metering Standing Committee Meeting April 29, 2010
Richard Zaworski/Neill Wong, Settlements, Metering Installations



- ❑ To review and establish principles to assess conformance to the Wholesale Revenue Metering Standard – Hardware w.r.t. operating range of current transformers (CTs) in registered *metering installations* and to comply with the Chapter 6 of the *Market Rules*

- ❑ Market Rules Chapter 6
 - Sec 4.1.1 – each metering installation shall have *instrument transformers* whose current transformers and voltage transformers meet or exceed the 0.3 accuracy class of ANSI standard C57.13
- ❑ Wholesale Revenue Metering Standard – Hardware
 - Sec 6.9.1 – (New installations) Current transformers shall be selected according to the following factors
 - a. the **maximum sustained primary current** in a current transformer shall not exceed the primary tap multiplied by the continuous current Rating factor of the current transformer
 - b. the **minimum sustained primary current** during normal operation shall not be less than 10% of the primary tap, for ANSI 0.3 accuracy class
 - c. the **minimum sustained primary current** during normal operation shall not be less than 5% of the primary tap, for ANSI 0.15 accuracy class
 - d. the **minimum sustained primary current** during normal operation shall not be less than 1% of the primary tap, for ANSI 0.15S accuracy class
- ❑ Wholesale Revenue Metering Standard – Hardware
 - Sec 6.9.1 – (New installations) Current transformers shall be selected according to the following factors
- ❑ Wholesale Revenue Metering Standard – Hardware
 - Sec 9.2.2 – (Existing Installations) Where parallel connected current transformer secondaries existed within *facilities* constructed before the *Market Rules* come into effect, approval shall be obtained from the IESO to continue use within the *IESO-administered market*.
 - a. current transformers shall not operate below 10% of the secondary ampere rating under normal operating conditions

- ❑ Current practice analysis uses time based 80/20 rule
 - Not a good indicator of conformance to standards. Over one year duration, will only identify that nominal rated current is \geq minimum % accuracy class threshold current for 80% of the time [Link to Slide](#)
- ❑ Suitability of CT Operation is reviewed at time of initial *MI* registration, and typically is reviewed at time of audit
- ❑ Why are we looking at practice today
 - RMSC members requested to look at better alternatives
 - External influences such as the Green Energy Act will place greater emphasis whether standards are met
 - To recognize and support new 0.15/0.15S high accuracy standards
- ❑ To define what “[minimum sustained primary current](#)” means
 - In theory it means above minimum % accuracy class threshold all or 100% of the time
 - In practice, a stakeholdered definition is required!
 - When CT operates below minimum sustained primary current then:
 - CT accuracy is undefined/unknown/not guaranteed
 - other components of the *MI* may also be affected which contributes to the overall inaccuracy

- ❑ % Energy
 - Best indicator of conformance to a standard
 - Does not necessarily demonstrate impact to the market
- ❑ At Risk \$
 - Not a good indicator of conformance to a standard
 - But a better indicator of financial risk as result of not meeting a standard

	Conformance to Standard	Risk
Time	Good ¹	Good
Energy	Best	Best ²
At Risk \$	---	Best

¹only when threshold is met

²if ratio is expressed in absolute value terms

- ❑ Other considerations when assessing conformance to a standard include:
 - Need to recognize “Standard of the Day”

Thresholds need to recognize “Standard of the Day”

Pre January 1, 2010

- Numerous design standards and practices existed dating back to 1960's:
 - pre-Market Opening included both AMIS and DOC
 - 2008 upgrades: post 0.3 ANSI; post 0.3 ERT ANSI

Post January 1, 2010


- 0.15 accuracy standards formalized
- Green Energy Act/Conservation
- Adoption of best metering practices including: HAIT; RF; Multiple ratios; nominal ratio; load considerations; GEA conservation measures/culture

1. Adopt % Energy assessment standard to define “minimum sustained primary current”
2. Being proposed today is to consider:
 - % class Energy (kWh)
 - % out-of-class Energy (kWh)
 - Re-define assessment methodology
 - No longer will assess based on time
 - Adopt % energy method to assess compliance to standard
 - Class energy is that energy measured within X% of the total
3. Apply two energy thresholds:
 - Post Jan 1, 2010 at 90/10
 - Pre Jan 1, 2010 at 65/35

I. WIND TURBINE GENERATION STATION

Example # 1


In this example, the assessment parameters are presented as:



- 0.3 class:** 46.15% @ Current/Time criteria
86.70% @ Class kWh Energy criteria
\$625,858 @ At Risk Dollars criteria
- 0.15 class:** 68.68% @ Current/Time criteria
96.69% @ Class kWh Energy criteria
\$155,831 @ At Risk Dollars criteria
- 0.15S class:** 99.56% @ Current/Time criteria
99.99% @ Class kWh Energy criteria
\$402 @ At Risk Dollars criteria

II. HYDRAULIC GENERATION STATION

Example # 2



In this example, the assessment parameters are presented as:


0.3 class: 46.72% @ Current/Time criteria
98.57% @ Class kWh Energy criteria
\$76,588 @ At Risk Dollars criteria

0.15 class: 48.28% @ Current/Time criteria
98.73% @ Class kWh Energy criteria
\$67,707 @ At Risk Dollars criteria

0.15S class: 53.80% @ Current/Time criteria
99.18% @ Class kWh Energy criteria
\$44,045 @ At Risk Dollars criteria

III. GENERATOR STATION SERVICE

Example # 3



In this example, the assessment parameters are presented as:

0.3 class: 8.52% @ Current/Time criteria
29.94% @ Class kWh Energy criteria
\$1,712,450 @ At Risk Dollars criteria


0.15 class: 51.52% @ Current/Time criteria
66.84% @ Class kWh Energy criteria
\$810,410 @ At Risk Dollars criteria

0.15S class: 99.78% @ Current/Time criteria
99.89% @ Class kWh Energy criteria
\$2,756 @ At Risk Dollars criteria

IV. LDC TRANSFORMER STATION

Example # 4

In this example,




In this example, the assessment parameters are presented as:

- 0.3 class:** 0.0% @ Current/Time criteria
0.0% @ Class kWh Energy criteria
\$2,898,764 @ At Risk Dollars criteria
- 0.15 class:** 14.91% @ Current/Time criteria
16.70% @ Class kWh Energy criteria
\$2,414,529 @ At Risk Dollars criteria
- 0.15S class:** 100% @ Current/Time criteria
100% @ Class kWh Energy criteria
Nil @ At Risk Dollars criteria

V. LARGE INDUSTRIAL CUSTOMER TRANSFORMER STATION

Example # 5a



LOAD DURATION PLOT

2010, FEB 11 10:35 AM

Id
Name:
5 Min Clock Intervals

Chan: 8
Start: 09/01/01 00:01
Stop: 09/12/31 24:00

Max: 1.3SQRTI2
Min: .05SQRTI2

In this example, the assessment parameters are presented as:


0.3 class: 11.02% @ Current/Time criteria
16.66% @ Class kWh Energy criteria
\$1,203,240 @ At Risk Dollars criteria

0.15 class: 70.67% @ Current/Time criteria
87.04% @ Class kWh Energy criteria
\$187,069 @ At Risk Dollars criteria

0.15S class: 99.99% @ Current/Time criteria
100.0% @ Class kWh Energy criteria
\$3.00 @ At Risk Dollars criteria

V. LARGE INDUSTRIAL CUSTOMER TRANSFORMER STATION

Example # 5b



In this example, the assessment parameters are presented as:


0.3 class: 38.16% @ Current/Time criteria
93.51% @ Class kWh Energy criteria
\$69,629 @ At Risk Dollars criteria

0.15 class: 45.23% @ Current/Time criteria
97.97% @ Class kWh Energy criteria
\$21,728 @ At Risk Dollars criteria

0.155 class: 48.25% @ Current/Time criteria
98.28% @ Class kWh Energy criteria
\$18,460 @ At Risk Dollars criteria

VI. LDC FEEDER/PME METER INSTALLATION

Example #6a




In this example, the assessment parameters are presented as:

- 0.3 class:** 32.83% @ Current/Time criteria
55.00% @ Class kWh Energy criteria
\$905,802 @ At Risk Dollars criteria
- 0.15 class:** 82.13% @ Current/Time criteria
96.53% @ Class kWh Energy criteria
\$69,932 @ At Risk Dollars criteria
- 0.15S class:** 89.29% @ Current/Time criteria
99.77% @ Class kWh Energy criteria
\$4,643 @ At Risk Dollars criteria

VI. LDC FEEDER/PME METER INSTALLATION

Example #6b




In this example, the assessment parameters are presented as:

- 0.3 class:** 5.40% @ Current/Time criteria
79.94% @ Class kWh Energy criteria
\$14,085 @ At Risk Dollars criteria
- 0.15 class:** 5.87% @ Current/Time criteria
81.44% @ Class kWh Energy criteria
\$13,031 @ At Risk Dollars criteria
- 0.15S class:** 98.58% @ Current/Time criteria
99.68% @ Class kWh Energy criteria
\$222 @ At Risk Dollars criteria

Designs must factor in and should consider:

- Nominal CT size required
- Design for projected load conditions by applying 90/10 energy based ratio for accuracy over the dynamic range
- Use CT rating factor (CCRF)
- Use appropriate ANSI standard to achieve the required accuracy rating

1. Agreement is being sought regarding moving from %Time based to %Energy based
2. Agreement is being sought to use two thresholds for PRE and POST when assessing CT operation
3. PRE threshold set to 65/35
4. POST threshold set to 90/10
5. Other considerations
6. Next steps???



LOAD DURATION PLOT

Id
Name:
5 Min Clock Intervals

Chan: 8
Start: 09/01/01 00:01
Stop: 09/12/31 24:00

2010, FEB 10 9:43 AM

Max: 2.75QRTI2
Min: .0SQRTI2